

---

**EPA's APTI**  
**Course #450/468**  
***Monitoring Compliance Test***  
***And***  
***Source Test Observation***  
***Student Workbook***



*[This page intentionally left blank.]*



## Notice

This is not an official policy and standards document. The opinions and selections are those of the author and not necessarily those of the Environmental Protection Agency. Every attempt has been made to represent the present state of the art as well as subject areas still under evaluation. Any mention of products or organizations does not constitute endorsement by the United States Environmental Protection Agency (USEPA).

## Usage of This Manual

The Central States Air Resource Agencies Association (CenSARA) is one of several multi- jurisdictional organizations (MJOs) operating for the U.S. Environmental Protection Agency (USEPA), through the Air Pollution Training Institute (APTI), to update more of the frequently used APTI courses. The primary objectives of the MJOs are to:

- Promote the exchange of information between the States;
- Serve as a forum to discuss regional air quality issues of common concern;
- Share resources for the common benefit of the member states; and
- Provide training services to their member air pollution control agencies.

APTI provides courses on air pollution control technology, ambient air and source monitoring, and air quality management. Historically, APTI designed courses that meet the job training needs of governmental agency personnel and others in the field of air pollution. This requires a thorough examination of both the materials for instruction and the characteristics of the student audience. Based on studies conducted by APTI of those who have participated in the various training courses, courses were developed and revised to provide training that enables every student to achieve specific course objectives. A basic goal of APTI was to provide training that will enable a student to do specific jobs in his or her home environmental agency. However, recently APTI has taken a new direction and has given money to the various MJOs, of which CenSARA is one, to update needed training course for their member states.

CenSARA meets these training needs of its member states by identifying, designing, developing and delivering needed, cost-effective, responsive, and focused educational opportunities for state and local air agency staff. Agenda and course materials are obtained from a variety of sources including EPA, colleges and universities, regional training consortia, and individual instructors. Yet, due to changes in environmental regulations, the implementation of new policies, and the advancement of technologies, agendas and course materials become out-of-date. When this happens, staffs' ability to enhance skills, knowledge and abilities are constrained, limiting their ability to excel in the dynamic field of air pollution control. So by providing up-to-date, high quality educational opportunities for staff, their chances to greatly enhance their skills, knowledge and abilities is significantly improved.

Consequently, CenSARA announced a Request for Proposals (RFP) to the environmental training community to solicit technical proposals and cost bids to review current compliance test and observation programs within the USEPA and to **update** as necessary the content title, agenda topics, course length, instructor and student manuals, lectures involving presentation slides, classroom and homework exercises, and other handouts and materials for EPA's APTI Course #450/#468 entitled: *"Monitoring Compliance Test and Source Test Observation."* In response to CenSARA's RFP, EnviroTech Solutions, William T. "Jerry" Winberry, 1502 Laughridge Drive, Cary, North Carolina 27511, [jwinberry@mindspring.com](mailto:jwinberry@mindspring.com), 919-467-2785, was awarded the contract to update EPA's APTI Course #450/#468. Mr. Winberry is the author of this Student Workbook (SW) and every attempt has been made to represent the most recent advances in sampling and analytical methodology

## Disclaimer

This material has been developed and assembled to provide training associated with EPA's APTI Course #450/#468 entitled: *"Monitoring Compliance Test and Source Test Observation."* It is not intended to be used for regulatory purposes, or to be a substitute for, nor interpreted as official Agency policy. Every attempt was made to reflect the technical state of art and regulatory information as of the date of this publication. This is not an official policy and standards document. The opinions and selections are those of the author and not necessarily those of the EPA. Any mention of products or organizations does not constitute endorsement by the EPA.

# **U.S. Environmental Protection Agency Air Pollution Training Institute Course #450/#468**

## **Monitoring Compliance Test and Source Test Observation**

### **Student Workbook (SW)**

The Central States Air Resource Agencies Association (CenSARA) is one of several multi- jurisdictional organizations (MJOs) operating for the U.S. Environmental Protection Agency (USEPA), through the Air Pollution Training Institute (APTI), to update more of the frequently used APTI courses. The primary objectives of the MJOs are to:

- Promote the exchange of information between the States;
- Serve as a forum to discuss regional air quality issues of common concern;
- Share resources for the common benefit of the member states; and
- Provide training services to their member air pollution control agencies.

APTI provides courses on air pollution control technology, ambient air and source monitoring, and air quality management. Historically, APTI designed courses that meet the job training needs of governmental agency personnel and others in the field of air pollution. This requires a thorough examination of both the materials for instruction and the characteristics of the student audience. Based on studies conducted by APTI of those who have participated in the various training courses, courses were developed and revised to provide training that enables every student to achieve specific course objectives. A basic goal of APTI was to provide training that will enable a student to do specific jobs in his or her home environmental agency. However, recently APTI has taken a new direction and has given money to the various MJOs, of which CenSARA is one, to update needed training course for their member states.

CenSARA meets these training needs of its member states by identifying, designing, developing and delivering needed, cost-effective, responsive, and focused educational opportunities for state and local air agency staff. Agenda and course materials are obtained from a variety of sources including EPA, colleges and universities, regional training consortia, and individual instructors. Yet, due to changes in environmental regulations, the implementation of new policies, and the advancement of technologies,

agendas and course materials become out-of-date. When this happens, staffs' ability to enhance skills, knowledge and abilities are constrained, limiting their ability to excel in the dynamic field of air pollution control. So, by providing up-to-date, high quality educational opportunities for staff, their chances to greatly enhance their skills, knowledge and abilities is significantly improved. Consequently, CenSARA has taken the initiative to update EPA's APT! Course #450/#468.

The updated Course #450/#468 is targeted primarily at agency personnel who have the responsibility to monitor compliance test and source test observation of various FRMs and SW- 846 methodologies. The revised course materials provide the best available and most current information as well as relevant example exercises to improve the knowledge and expertise of agency observer personnel. The desired outcome of this effort is that agency staff be able to properly observe compliance test and perform source test observations to protect public health and the environment by developing an understanding of EPA's stack testing programs and strategy, various stack test methodologies for quantifying HAPs from industrial processes, and associated quality assurance/quality control activities and requirements.

The specific objectives of updating APTI Course #450/#468 materials include:

- Explain why sampling of source emissions for PM and HAPs is important in air pollution control agency programs;
- Define symbols and common terms used in the application of FRMs 1-5 and SW-846 source sampling;
- Recognize, interpret and apply sections of the Code of Federal Regulations, Appendix A, pertinent to source sampling for particulate pollutants;
- Understand the construction, operation and calibration of the component parts of the FRM 5 particulate matter sampling train;
- Define "Isokinetic sampling" and illustrate why it is important in sampling for PM;
- Understanding the "working" isokinetic rate equation and its derivation
- Learn how to use specific software for determining isokinetic sampling rates;
- Apply FRMs 1 through 4 in preparation for applying FRM 5 at a source to characterize PM emissions;
- Understand how the "S-type" pitot tube is constructed and standardized and how it is applied in source sampling;
- Understand the difference between systematic error and precision as applied to source test measurements;
- Properly assemble and leak check a FRM 5 sampling train;
- Describe the operation of the VOST, Semi-VOST, Acid Gas and FRM 201/201A sampling trains;
- Describe what are "condensibles" and how the FRM 202 sampling train operates to measure condensibles; and
- Calculate the "% Isokinetic" value for a source test, and interpret the effect of over or under- isokinetic values on the source test results.

One of the products of the #450/#468 update is the Student Workbook (SW). The SW provides copies of visuals presented in each technical lecture. Contained in this SW are the visuals for each of the Sessions and lessons presented in APT! Course #450/#468.

## **I. Background**

Over the last several years, public awareness of air pollution and its sources has increased steadily. Specifically, since the passage of the Clean Air Act Amendments (the Act) of 1990 and the implementation of EPA's maximum achievable control technology (MACT) program, more emphasis has been placed on local, State, and Federal agencies to keep the public informed on health effects of various air pollutants and their levels of exposure. This awareness has required industry to become accountable for air pollution emissions as part of their source's compliance strategy and regulatory agencies to become knowledgeable of the methodology used to quantify reported emissions.

Traditionally, air pollution control agencies require all sources to quantitate their emissions in order to demonstrate compliance. To insure that the source test methods utilized to demonstrate compliance are performed according to EPA guidelines, regulatory agencies observe stack test to document compliance with the methodology. This has meant that sources must know how to properly sample and report emissions using EPA reference methods and that regulatory agencies must know how to properly observe these test to insure that reliable and accurate data is gathered and reported.

In addition, with the passage of the Act and Title IV, Acid Rain, those fossil-fueled-fired-steam generators (FFFSG) covered must report emissions in units of pollutant mass rate (pmr) as part of EPA's emission trading program. This required the installation and certification of velocity monitors if the continuous emission monitoring system (CEMS) data was to be used as part of EPA's market base-trading program. These new regulatory requirements have now required Agency personnel to know how to observe and verify the proper use and implementation of Federal Reference Methods 2F, 2G, and 2H in certification of the velocity CEMS as part of a source's market base-trading emission program.

Consequently, the Act has required regional, state, and local air pollution control agencies to better understand the stack test methodologies that are used to quantitate air pollution emissions from industrial sources. Agencies see a need to provide training to it's personnel on how to properly observe stack test used to meet regulatory compliance for criteria and hazardous air pollutants (HAPs).

## **II. Course Objective**

The objective of EPA's APTI Course #450/#468 is to provide Agency personnel the needed background information, checklist, and guidance associated with EPA methodologies involving stack test for characterizing and quantifying criteria and HAPs from industrial sources. This course will address Federal Reference Methods (FRMs) 1-5 (isokinetic stack testing and stack test basics), FRMs 2F, 2G, and 2H (velocity), stack testing for volatile organic compounds (FRMs 18, 25, 25A/B), SO<sub>2</sub> (FRMs 6, 6A, and 8), NO<sub>x</sub> (FRMs 7, 7C), dioxin/furans and PCBs (FRM 23), heavy metals (FRM 29), and instrumental (FRMs 3A, 6C, and 7E).

The course will present standardized stack test methodology for sampling and analysis of air pollutants as identified in the Code of Federal Regulations (CFR), Part 60, Appendix A. In

addition, information will be presented on EPA's stack test monitoring programs associated with PM-10 (Methods 201 A/B) and condensable particulate (Method 202) monitoring from CFR 51 Subpart M. Specific source test checklists will be demonstrated during the presentation for each test methodology as part of the course. Participants will learn how to use the checklist in performing source test observations, how to observe mandated QA/QC requirements associated with each methodology, and how to use source test databases available to the air pollution scientist.

At the end of this course, the agency personnel will gain an understanding of the unique source test methods used to accurately characterize air pollutant emissions from industrial sources. The agency personnel will learn about EPA's programs that require characterization of air pollutants from industrial sources utilizing FRMs.

### III. Course Manuals

Course presentations and videos will be supported by four manuals. They are:

- **#468 Student Workbook (Hard Copy):** The updated Student Workbook (SW) contains copies of selected slides from each of the lecture presentations, and **Agency Inspector Checklist.**
- **#468 Stack Test Manual (Flash Drive):** The Stack Test Manual contains full copies of selected stack test sampling and analytical methods found in the CFR, Part 60, Appendix A, and SW-846, Standard Methods.
- **Apex Instruments Federal Reference Method 5 Operational Manual:** The Federal Reference Method 5 Operation Manual is a document describing specifically the construction and operation of Federal Reference Method 5 stack testing sampling train.  
<http://www.apexinst.com/cms/wp-content/uploads/2015/03/Model-500-Series-Manual-Method-5.pdf>.



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 1: Introduction Driving Force for HAP's Monitoring**

**U.S. EPA APTI**  
**Compliance Testing and Source Test**  
**Observation**  
*APTI Course #468 Introduction*



1 - 1

**Compliance Testing**  
**and Source Test**  
**Observation**

IDEM: Air Compliance, Stack Testing, and Source

1 - 2



**Stack Measurement in Donora (Circa 1948)** 1 - 3  
Measurements of airflow in study of stack effluents.

**Source Sampling At a**  
**Scrap Metal Dryer**  
**Circa 1970's**




1 - 4

**Source Sampling At a Scrap Metal Dryer**  
**Circa 1970's**



1 - 5



**Measurement of**  
**Source Pollutant**  
**Emissions**

1 - 6



# APTI #450/468 Compliance Test and Source Test Observation


## Lesson 1: Introduction Driving Force for HAP's Monitoring

### Measurement Methods of Source Pollutant Emissions

1. Stack testing
  - Manual methods
  - Instrumental methods
2. Continuous Emission monitoring
  - Instrumental methods
3. Remote Sensing

1 - 7

### Manual Sampling



Extract samples from various points in stack.  
Analyze samples in lab.  
*Procedures described by federal reference methods (FRMs)*


1 - 8

### Manual vs. Instrumental

Manual	Instrumental
Anything related to PM and some gases	Anything related to gases
<ul style="list-style-type: none"> <li>• PM</li> <li>• PM<sub>10</sub></li> <li>• Metals</li> <li>• Semi-volatile</li> <li>• Organisms</li> <li>• HCL &amp; H2SO4</li> </ul>	<ul style="list-style-type: none"> <li>• NO<sub>x</sub></li> <li>• SO<sub>2</sub></li> <li>• CO</li> <li>• Opacity</li> <li>• Volatile Organics</li> <li>• O<sub>2</sub></li> <li>• CO<sub>2</sub></li> <li>• VOC</li> <li>• H<sub>2</sub>S</li> </ul>

1 - 9

### Remote Sensing



EPA Handbook: Optical and Remote Sensing for Measurement and Monitoring of Emissions Flux of Gases and Particulate Matter

1 - 10

### EPA Manual Federal Reference Methods (FRMs)

Used for source compliance testing  
Describe actual testing procedure  
Found in Code of Federal Regulations

1 - 11

### Agency's Purpose for Stack Testing

- Compliance Evaluation
- Regulatory Support
- Emission Inventory
- Method Development
- Certify CEM's

1 - 12

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring

### Industry's Purpose for Stack Testing

- Determine Control Device Efficiency
- Evaluate process operation
- Design new process and equipment
- Demonstrate compliance


1-13

### Types of Emission Points Tested

- Stacks
- Process vents
- Building exhausts
- Tank emissions
- Fugitive emissions

1-14

### Typical Sampling Point Provisions



1-15

### Four H's of Source Testing

- High** -- up to 300 feet
- Hot** -- stacks up to 2000
- Heavy** -- sampling equipment
- Hazardous** -- noxious gases

1-16



1-17

### Source Testing a Wet Mill Corn Dryer



1-18

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring

### Something Source Testers use a lot of?



1 - 19

### Types of Emissions Tested

Particulate matter (Total PM;  $PM_{10}$ ;  $PM_{2.5}$ )

Inorganic gases

Organic gases and vapors

Combinations of solids and gases

1 - 20

### Where Methods are Found


U.S. EPA test methods (CFR)

State Implementation Plans (SIPs)  
and regulations

Industrial and trade associations,  
Publications

<http://www.epa.gov/emc/>

1 - 21




### Method 1

Selection of  
sampling traverse  
points

1 - 2


### Method 2

Determination of  
stack gas velocity and  
volumetric flow rate  
(using Type S pitot  
tube)



1 - 23

### Distributed Sampling Points




1 - 24

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 1: Introduction Driving Force for HAP's Monitoring**

**Method 3**


Determination of the dry molecular weight of flue gas (using Orsat apparatus measuring %O<sub>2</sub>, %CO<sub>2</sub>, and %CO)



1 - 25

**Method 4**


Determination of moisture content of stack gas (by condensation method)



1 - 26

**Method 5**


Sampling method for particulate matter (isokinetic collection of particles on a filter)



1 - 27

**Method 6**


Sampling and analytic method for determining SO<sub>2</sub> emissions (barium-thorin titration)



1 - 28

**Method 7**


Determination of NO<sub>x</sub> emissions (colorimetric phenoldisulfonic acid method)



1 - 29

**Method 8**

Determination of H<sub>2</sub>SO<sub>4</sub> mist and SO<sub>2</sub> emissions (intended for H<sub>2</sub>SO<sub>4</sub> plants)



1 - 30

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring

FRM 10	Determination of CO
FRM 11	Determination of flourides
FRM 12	Determination of inorganic lead emissions
FRM 13, 14	Determination of H <sub>2</sub> S
FRM 15	Determination of H <sub>2</sub> O, COS, CS <sub>2</sub>
FRM 16	Determination of total reduced sulfur
FRM 17	Determination of particulates (in-stack filtration method) 1 - 31

FRM 26	Determination of HCl/Cl <sub>2</sub>
FRM 29	Determination of multi-metals
FRM 201/201A	Determination of PM-10
FRM 316	Determination of formaldehyde
FRM 202	Determination of condensables
SW-846 Methods	Determination of volatiles, semi-volatiles etc. 1 - 32

### Objectives

Instruct on a vast number of methods found in EPA's Federal Register methods (FRMs) and SW-846 test methodology

Instruct Agency personnel in the proper observation and measurement techniques for quantifying particulate and gaseous stack emissions

1 - 33



### Objectives

Focus on groups of compounds

- Volatile Organic Compounds (VOCs)
- Hydrogen Halides and Halogens
- Particulate Matter (Total and Speciated) and Condensibles
- Inorganic-base Compounds (Lead and Metals)

Update changes associated with FRMs 1-5



1 - 34





# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring



### Course Materials

**Student Workbook**  
 Contains the course agenda and copies of selected slides presented in each of the topic areas

**Student Manual**  
 APTI Course #450 Manual and Checklist

1 - 39

### Course Materials

**Federal Reference Method 5 Manual**  
**Operating Manual**  
 Agency observation checklist, and various reference materials

**Federal Register containing FRM 1-5**  
**Course CD- Contains Over 90 Stack Testing Entries**

1 - 40

### Role of the Inspector?

Regulatory Science vs. Measurement Science


“Procedure-Based” vs. “Performance-Based” Method

1 - 41



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring



### Historical Questions?

How do we define particulate matter?  
How do we define VOCs?  
Do stack testing firms need to be certified or individual testers need to be certified?  
How do we deal with onsite changes to Federal Reference Methods (FRMs)?

1 - 44

### Historical Questions?

How do we define “condensable particulate matter (CPMs)?”  
Should our state stack observation program be documented?  
How many test should be required when sampling batch processes?  
What guidelines are available for onsite rejection of a “compliance test?”

1 - 45

### Historical Questions?

How do we report VOC emissions? As “C,” as “propane,” as “VOCs?”  
What requirements must be met in order to allow a method specified under one set of regulations (i.e., incinerator) to be used for a different set of regulations (i.e., HON rule)?

1 - 46

### Historical Questions?

During compliance testing, what guidelines are available for allowing a “procedure-based method” to become a “performance-based method?”  
Are there guidelines available to determine if a source test observation has been performed correctly?  
<https://www.govinfo.gov/content/pkg/FR-2009-07-22/pdf/E9-17402.pdf>  
<https://www.govinfo.gov/content/pkg/FR-1997-10-06/pdf/97-26443.pdf>  
[https://www.epa.gov/sites/production/files/2016-02/documents/flexible\\_approaches\\_to\\_environmental\\_measurement\\_-\\_reaffirmed\\_112015.pdf](https://www.epa.gov/sites/production/files/2016-02/documents/flexible_approaches_to_environmental_measurement_-_reaffirmed_112015.pdf)

1 - 47

### Historical Questions?


As an Agency inspector, what guidelines are available to help me make correct decisions between “Regulatory Science” and “Measurement Science?”  
How do we implement good non-EPA programs that haven't been certified by the Agency into a State Agency program that can't be stricter than the EPA program?

1 - 48


# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring


### Constant Sampling Rate (CSR) and Real-time Methods



### Isokinetic Sampling Rate Methods



### Particulate Sampling Methods



### Stack Test Methods

Why Develop Stack Test Methods and What is the Driving Force In The United States?

1-52

### Objective of Stack Testing

The objective of performing a stack test is to determine the pollutant mass rate (pmr) or emission rate (E) of pollutant being emitted to determine whether compliance limits are being met

1-53


### Measurement Units

Concentration	c (ppm, gr/dscf)
Stack gas flow rate	Q (dscm)
Pollutant mass rate	pmr (lb/hr)
Mass emission rate	E (lb/10 <sup>6</sup> Btu)
Process weight rate	E (lb/lbs product produced)

1-54



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 1: Introduction Driving Force for HAP's Monitoring**



**What is the Driving Force?**

New Source Performance Standards (NSPS-1970)

National Emission Standards for Hazardous Air Pollutants (NESHAP-1977)

Prevention of Significant Deterioration (PSD-1977)

1 - 56

**What is the Driving Force?**

Resource Conservation and Recovery Act (RCRA-1978)

Boiler and Industrial Furnace (BIF-1990)

Clean Air Act Amendments (CAAA-1990)

Maximum Achievable Control Technology (MACT)

Title III Hazardous Air Pollutants (HAPs) list of 188

1 - 57

**Why Have Title III Hazardous Air Pollutants?**

Section 112 of CAA established standards for only seven hazardous air pollutants to date

Asbestos, mercury, beryllium, vinyl chloride, benzene, radionuclides, arsenic

1 - 58

**Why Have Title III Hazardous Air Pollutants?**

Additional controls needed for large number of toxic substances not covered in Section 112

1 - 59

**Title III Hazardous Air Pollutants**

**Title III**

Establishes a list of 188 designated substances to be regulated

Requires sources to apply maximum achievable control technology (MACT)

1 - 60

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring

---

### Title III Hazardous Air Pollutants

Provides that EPA may require additional controls after MACT to  $10^{-6}$  residual risk levels at the property line (Driving detection limits lower)  
Establishes a program associated with accidental releases

1 - 61

### Title III Hazardous Air Pollutants

Requires MACT for all major sources > 10 tons/year or 25 tons/year for combination of toxics  
Requires emission reductions of 75 to 90% below current levels through MACT controls

1 - 62

### Title III Hazardous Air Pollutants

Impact on Industry  
Application of maximum achievable control technology (MACT)  
Standards are technology-based  
May have to control after MACT to  $10^{-6}$  risk level at property line

1 - 63

### Example of MACT Standards

Subpart FFFF (Misc. Organic Chemical Production and Processes [MON])  
Subpart DDDDD (Industrial, Commercial and Institutional Boilers and Process Heaters)  
Hazardous Organic NESHAP (HON) Rule: Regulates SOCOMI  
370 Facilities  
111 of the 188 Title III HAPs

1 - 64

### Where Do We Find the Test Methods?

Federal Test Methods- Methods are those (Federal Reference Methods and others) specified in the applicable standards as the test methods used to demonstrate compliance with emission limits or quantitate emissions in meeting regulatory initiatives

1 - 65

### Where Do We Find the Test Methods?

[www.epa.gov/emc/tmethods.html](http://www.epa.gov/emc/tmethods.html)

1 - 66

# APTI #450/468 Compliance Test and Source Test Observation


## Lesson 1: Introduction Driving Force for HAP's Monitoring

### Regulations

40 CFR Part 60, Appendix A  
Standards of Performance for New  
Stationary Sources (i.e., NSPS), Federal  
Reference Methods (00 Series)

1 - 67

### New Source Performance Standard (NSPS) Reference Methods-00




1 - 68

### Regulations

40 CFR Part 60, Appendix B  
Performance Specification Test (PST)  
Methods (00 Series)  
40 CFR Part 51, Appendix M  
State Implementation Plan (SIP) Methods  
(200 Series)


1 - 69

### Performance Specification Test (PSTs)-00 Series



1 - 70

### State Implementation Plan (SIP)- 200 Series



1 - 71

### Clean Air Act and It's Amendments


40 CFR Part 61  
National Emission Standards for  
Hazardous Air Pollutants (NESHAP)(100  
Series, Appendix B)  
40 CFR Part 63  
Maximum Achievable Control Technology  
(MACT) Methods  
(300 Series, Appendix A)

1 - 72

# APTI #450/468 Compliance Test and Source Test Observation


## Lesson 1: Introduction Driving Force for HAP's Monitoring

### National Emission Standards For Hazardous Air Pollutants (NESHAPs)- 100 Series




1 - 73

### Maximum Achievable Control Technology (MACT)-300 Series



1 - 74

### Maximum Achievable Control Technology (MACT)-300 Series



1 - 75

### Categories of Stack Test Methods by EPA

Category A: Methods proposed or promulgated in Federal Register

Compliance Methods for 40 CFR Parts 60, 61, and 63

Category B: Source category approved “Approved Alternative”

Compliance Methods for specific applications with approval from EPA

1 - 76

### Categories

Category C: “Conditional Methods” evaluated by EPA; methods may be used by state/local in conjunction with federal enforcement; must be “Alternative Method” to be used as meeting 40 CFR Parts 60, 61, and 63

1 - 77

### Categories

Category D: Methods which may be useful in limited applications until more supporting information is provided; “gap filling” methods (Preliminary Methods)

1 - 78

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring

---

### Categories

Category E: "Idea Box" contain method concepts intended to promote information exchange

These methods generally have had no EPA review or analysis

1 - 79

### Example Category Stack Test Methods

Category A (FRMs):

FRMs 1-29, FRM 100s, 200s, and 300s

Category B (Approved Alternatives): ALT-007 (use of dilution probe in Methods 6C, 7B, 3A, 10 and 20)

1 - 80

### Example Category Stack Test Methods

Category C (Conditional): Particulate (PM Screening) Method; conditional test method for Acrylonitrile; halogenated organic method; Method for isocyanates

1 - 81

### Example Category Stack Test Methods

Category D (Preliminary Methods): PRE 5-Determination of oxides of nitrogen from stationary sources (UV Instrumental Analyzer)

1 - 82

### Example Category Stack Test Methods

Category E (Idea Box):

Sampling and analysis for phosgene emissions from stationary sources

All categories of methods found on

[www.epa.gov/emc/tmethods.html](http://www.epa.gov/emc/tmethods.html)

1 - 83

### Resource Conservation And Recovery Act (RCRA)

SW-846 is the compendium of analytical and test methods used in determining regulatory compliance under RCRA


<http://www.epa.gov/sw-846>

1 - 84

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 1: Introduction Driving Force for HAP's Monitoring

### SW-846 Stack Test Methods



1 - 85

### How Do We Define HAPs

CAAA of 1990, Title III now contains a list of 188 HAPs containing both organic and inorganic analytes

Defining the 188 HAPs according to

- Vapor Pressure (in mm Hg at 25°C)
- Boiling Point Temperature (°C)


1 - 86

### General Classification of VOCs

Classification	Vapor Pressure mm Hg	Boiling Point °C
Volatiles (VV/V)	$> 10^{-1}$	$< 200^{\circ}\text{C}$
Semi-volatiles (SV)	$10^{-1}$ to $10^{-7}$	200 - $500^{\circ}\text{C}$
Particles (NV)	$< 10^{-7}$	$> 500^{\circ}\text{C}$


1 - 87

### Boiling Points of Volatile Organic Compounds




1 - 88

### Boiling Points of Volatile Organic Compounds



1 - 89

### Boiling Points of Semi-volatile Organic Compounds



1 - 90

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 1: Introduction Driving Force for HAP's Monitoring**

**General  
 Classification of HAPs**

<b>Volatility Class</b>	<b>Number of HAPs in Class</b>
Volatiles (VV/V)	106
Semi-volatiles (SV)	65
Non-Volatile (NV) Particles	17
<b>Total HAPs</b>	<b>188</b>

1 - 91

**Example of HAPs  
 in Each Volatility Class**

**VP (0.1- 380 mm Hg)  
 BP (< 200°C)**

**VOLATILE**

Benzene	76 mm Hg	80.1°C
Xylene, ortho	5 mm Hg	144.4°C
Hydrazine	16 mm Hg	113°C
Hydrochloric acid	23 mm Hg	110°C

1 - 92

**Example of HAPs  
 in Each Volatility Class**

**VP ( $10^{-7}$  to  $10^{-1}$  mm Hg)  
 BP (200 to 500°C)**

**SEMI-VOLATILE (65 HAPs)**

Benzidine	$10^{-5}$ mm Hg	402°C
Captan	$10^{-6}$ mm Hg	479°C
Phosphorus	$10^{-2}$ mm Hg	280°C
Mercury Compounds	$10^{-3}$ mm Hg	356°C

1 - 93

**Example of HAPs  
 in Each Volatility Class**

**VP (<  $10^{-7}$  mm Hg)  
 BP (>500°C)**

**NON-VOLATILE [Particles] (17 HAPs)**

3,3'-Dimethoxybenzidine	$10^{-13}$ mm Hg	458°C
Antimony	Very Low	656°C
Coronene	$10^{-13}$ mm Hg	525°C

1 - 94

**General Classification  
 of VOCs**

<b>Classification</b>	<b>Vapor Pressure mm Hg</b>	<b>Boiling Point °C</b>
Volatiles (VV/V)	> $10^{-1}$	< 200°C
Semi-volatiles (SV)	$10^{-1}$ to $10^{-7}$	200 - 500°C
Particles (NV)	< $10^{-7}$	> 500°C

1 - 95



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 2: EPA's EPA's National Stack Testing Guidance**

**Compliance Test and Source Test Observation**  
**EPA's National Stack Testing Guidance**



2 - 1



**Purpose/Goals**

- Recognize importance of stack testing as a primary method for determining whether facility has ability to comply with CAA and continues to be in compliance with emission limits
- Expand upon CMS and HPV policy
- Improve uniformity in how tests are conducted, evaluated, and reported
- Improve coordination with states/locals
- Enhance oversight

2 - 5

**Major Issues Addressed By Guidance**

- Time Frame
- Waivers
- Notification
- Observation
- Representative Testing Conditions
- Stoppages
- Postponements
- Test Reports

2 - 6



## Background of National Testing Guidance

- Interim Guidance: February 2, 2004
- Final Guidance: September 30, 2005
- Subsequent rulemaking to allow for extensions in testing deadlines in Force Majeure events effective August 9, 2006
  - Parts 60, 61, 63 of General Provisions amended May 16, 2007
  - Consolidated Federal Air Rule (GP Part 65) amended August 27, 2007
- Guidance issuance: April 27, 2009

2 - 7

## Definition

- Definition and "Scope of Guidance" sections clarify guidance applies only to tests conducted for **compliance** purposes under NSPS, NESHAP, and MACT programs:  
*Any Performance Testing Conducted for the Purposes of Determining and Demonstrating Compliance with the Applicable Standards of 40 CFR Parts 60, 61, and 63 Using Promulgated Test Methods, Other Test Methods or Procedures Cited in the Applicable Subpart(s), or Alternative Test Methods Approved by the Administrator Under §§60.8, 61.13, or 63.7. It Does Not Include Visible Emission Observation Testing.*

2 - 8

## Compliance Monitoring Strategy (CMS)

- Provides national consistency in developing stationary source CAA compliance monitoring programs while allowing states/locals flexibility to address local air pollution/compliance problems
- States/locals submit CMS plans biennially to Regions
- Enter compliance evaluation results in AFS
- Sources covered are Title V majors and synthetic minors that emit or have potential to emit emissions at or above 80 percent of Title V major source threshold (SM80s)

2 - 9

## CMS

- Agency should conduct, or require facility to conduct, a stack test:
  - Whenever the Agency deems appropriate
  - Where there is no other means for determining compliance with emission limits
- Report date and results of all stack tests in AFS, and adjust HPV status, if necessary

2 - 10

## High Priority Violations Policy (HPV)

- Designed to prioritize violations for federal, state, and local agency enforcement efforts
- Covers definition/identification of HPVs, timely and appropriate enforcement response, penalties, and reporting in AFS
- Applies to any major source, any synthetic minor source and any source, major or minor, upon mutual agreement between EPA and state/local at their discretion

2 - 11

## HPV Policy

- HPV status is triggered by failure of a stack test
- Violations of emission limits for pollutants for which facility is not designated as a "major source" may not rise to HPV status, but still must be addressed
- If fail test, facility must:
  - Document failure
  - Submit report
  - Resolve conditions
  - Test again

2 - 12

### **Time Frame**

- Current regulations do not provide for extensions of test deadlines, except in the event of a force majeure
  - Violation of requirement to stack test
  - Violation of requirement to demonstrate compliance with underlying standard
- Failure to conduct test established in permit or enforcement document
  - Violation of permit or enforcement document
  - May be a violation of underlying requirement
- Concern that only way to grant additional time to test is through formal enforcement action regardless of circumstances

2 - 13

### **Time Frame (Cont.)**

- Guidance takes into account inability to meet regulatory testing deadlines due to circumstances beyond facilities' control
- Currently, four scenarios for how delegated agencies should respond to facilities not testing by deadline
  - Scenarios range from "Force Majeure events" beyond control of facility to those instances where the facility knowingly and willfully violates test requirement
  - Prior to Force Majeure rule, delegated agency was to use enforcement discretion by issuing letter (versus a formal AO) acknowledging circumstances and establishing new test date

2 - 14

### **Force Majeure Event**

- Force Majeure rules for Parts 60, 61, and 63 of The General Provisions and Part 65 (Consolidated Federal Air Rule):
  - Allow an extension of the deadline by which source owners or operators are required to conduct an initial or subsequent test required by applicable regulations in the event of a Force Majeure
  - Under such circumstances, no violation and thus no need to use enforcement discretion to extend deadline
  - Guidance is being updated consistent with the Rules

2 - 15

### **Waivers For Identical Units**

- Text includes pertinent regulatory references
- Criteria for determining when stack tests for identical units may be waived
- Concept that margin of compliance may not have to be significant where the emissions variability of identical units is low

2 - 16

### **Notification**

- Sufficiency of both the timing and content of the notification is discussed
- Text clarifies that notification is not necessary if test is outside scope of guidance, unless potential for applicable limits to be exceeded
- Clarifying language on submitting site-specific test plans and the contents of such plans

2 - 17

### **Observation**

- No requirement that agency be present for tests. However, whenever possible, delegated agencies should observe
- If agency unable to observe test, review of test protocol even more important
- If timely notification and opportunity to observe not provided, results may be rejected

2 - 18

### **Representative Testing Conditions**

- Guidance reinforces Agency position that the CAA requires continuous compliance with emissions limits except where explicitly excused
  - Tests should be performed under those representative conditions that:
    - Represent the range of combined process and control measure conditions under which the facility expects to operate (regardless of the frequency of the conditions)
    - Are likely to most challenge the emissions control measures of the facility with regard to meeting the applicable emission standards, but without creating an unsafe condition
- 2 - 19

### **Soot-Blowing**

- Guidance consistent with and relies upon past Agency position for including soot-blowing
  - Emissions from soot-blowing cannot be discarded as the result of an upset condition
  - Erroneous to stop soot-blowing for the purpose of conducting a stack test
- 2 - 20

### **Stoppages/Postponements**

- No regulatory provision allows stoppage, except for force majeure event
  - Depending on circumstances, facility may be in violation of requirement to conduct test, underlying requirement, or both
    - If in jeopardy of failing test, violation of both
    - Currently, Guidance states that if facility is forced to stop due to a force majeure event, agency should evaluate circumstances to determine appropriate enforcement response, if needed
  - Guidance is being updated consistent with rulemaking
  - Postponements should be treated similar to stoppages
    - If fail to complete test within required time, violation of requirement to test
- 2 - 21

### **Test Reports**

- Information necessary to adequately document results
  - At a minimum, test submittal:
    - NSPS: Within 180 days after initial startup date or within 60 days after reaching maximum production rate
    - NESHAP: Within 31 days after test completed
    - MACT: Within 60 days after test completed
- 2 - 22

### **Data Reporting**





- Minimum Data Requirements (MDRs) for reporting air compliance monitoring and enforcement activity
  - Stack test data reported into national air data system (AFS)
  - Test date reported with compliance determination from results
    - Compliance status updated, as appropriate
    - High Priority Violator (HPV): failing test for pollutant for which facility is major
    - Test date is to be reported within 60 days of event
  - Test results reported as pass, fail, or pending
    - Tests may be reported as pending for up to 120 days from test date
  - Reporting of stack test pollutant
    - Mandatory for federal reporters
    - Optional for state reporters
- 2 - 23

### **Reported Tests**

- Reported test failures
    - FY 2008: 619\*
    - FY 2007: 809
  - Among states, variation in number of failures vs. total tests conducted\*
    - FL: 1235 tests – 8 failures; AL: 1976 tests – 23 failures
    - GA: 862 tests – 40 failures; NJ: 105 tests – 33 failures; IA: 426 tests – 73 failures
  - For sources that failed, data issue concerning compliance status. For FY '07:
    - 48% listed "in violation"; 20% listed as HPV
- \*States/EPA have until 12/1 to report FY '08 data 2 - 24

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 2: EPA's EPA's National Stack Testing Guidance



### Additional Information


- Robert Lischinsky  
[lischinsky.robert@epa.gov](mailto:lischinsky.robert@epa.gov)  
 202-564-2628
- Internet Address:  
<https://echo.epa.gov/trends/comparative-maps-dashboards/state-air-dashboard?state=IL&view=activity>

2 - 29

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 3: Introduction to Stack Testing and Gas Physics

### Compliance Test and Source Test Observation Properties of Gases



3 - 1

### Properties of Gases

- Temperature
- Pressure
- Atomic Weight
- Molecular Weight and Moles
- Avogadro's Number
- Ideal Gas Law
- Moving Gases

3 - 2

### Temperature

- Degrees Fahrenheit: °F
- Degrees Centigrade: °C
- $^{\circ}\text{C} = 5/9 (^{\circ}\text{F} - 32)$
- $^{\circ}\text{F} = 9/5 (^{\circ}\text{C}) + 32$

3 - 3

### Absolute Temperature

- Degrees Rankine: R
- Degrees Kelvin: K
- $\text{R} = ^{\circ}\text{F} + 459.49$
- $\text{K} = ^{\circ}\text{C} + 273.16$

3 - 4

### Absolute Pressure, P

- $P = P_b + p_g$
- $P_b =$  Barometric pressure
- $P_g =$  Gauge pressure



3 - 5

### Units of Pressure

- in. Hg
- mmHg
- in. H<sub>2</sub>O
- Atmospheres
- Torr
- pascals

3 - 6

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 3: Introduction to Stack Testing and Gas Physics

---

### 1 Atmosphere =

- 29.92 in. Hg
- 39.90 ft H<sub>2</sub>O
- 14.70 lbs/in.<sup>2</sup>
- 760 mmHg
- 1 torr

3 - 7

### EPA Standard Pressure and Temperature

- P<sub>std</sub> = 29.92 in. Hg
- T<sub>std</sub> = 20° C or 68° F

**for source testing**

3 - 8

### Atomic Weight

A number that indicates how heavy  
(on the average) an atom is compared  
to an atom of another element

(Assign **carbon** atomic wt. = 12)

3 - 9

### Molecular Weight, M

The sum of the atomic weights of all the  
atoms in a molecule

MW of CO  
12 + 16 = 28

3 - 10

n = number of moles  
1 mole =

The molecular weight of a compound  
expressed in lbs (lb-mole )

or

in grams (g-mole )

1 mole of CO = 28 grams

3 - 11

1 gram-mole =


$6.023 \times 10^{23}$  molecules  
(Avogadro's Number)

3 - 12


# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 3: Introduction to Stack Testing and Gas Physics

1 mole = Avogadro's Number  
worth of molecules  
( $6.023 \times 10^{23}$ )  
Occupies  
22.4 L  
At 0° C and 1 atmosphere



3 - 13



1 mol helium at STP  
Volume = 22.4 L  
Mass = 4.00 g

1 mol xenon at STP  
Volume = 22.4 L  
Mass = 131.3 g


3 - 14

Given a mass,  $m$ , of a compound, the number of moles is calculated by:

$$n = \frac{m}{M}$$

3 - 15

### The Ideal Gas Law



3 - 16

### The Ideal Gas Law

Absolute Pressure →  $PV = nRT$  ← Absolute Temperature

Volume →  $PV = nRT$  ← # moles

$PV = nRT$  ← Ideal Gas Law constant

3 - 17

### R

The gas law constant is dependent on units used for EPA reference methods in English units:

$$R = 21.85 \left\{ \frac{(in. Hg)(ft^3)}{(lb - mol)(^{\circ}R)} \right\}$$

3 - 18

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 3: Introduction to Stack Testing and Gas Physics**

Correcting Volume to Standard Conditions

$$V_{s (stack)} = nR \frac{T_s}{P_s}$$

$$V_{std (standard)} = nR \frac{T_{std}}{P_{std}}$$

3 - 19

Dividing top by bottom gives

$$V_{std} = V_s \frac{T_{std} P_s}{P_{std} T_s}$$


3 - 20

Properties of Moving Gases

- Velocity
- Volumetric flow rate
- Isokinetic sampling
- Pollutant mass rate

3 - 21

Velocity



$$V_s = \text{ft/sec or ft/hr}$$

3 - 22

Velocity,  $V_s$  ,  $\frac{ft}{sec}$  ,  $\frac{ft}{hr}$

Determined by Method 2 using the Type S pitot tube

3 - 23

The Pitot Tube Equation

$$v_s = K_p C_p \left( \frac{\sum_{i=1}^n \sqrt{\Delta p}}{n} \right)_{avg} \sqrt{\frac{T_{s(abavg)}}{P_s M_s}}$$

USEAP Method 2, Eq. 2-7


3 - 24



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 3: Introduction to Stack Testing and Gas Physics

### Volumetric Flow Rate



$$Q_s = V_s A_s$$

$$\frac{ft^3}{sec} = \frac{ft}{sec} \times ft^2$$

or

$$\frac{ft^3}{hr} = \frac{ft}{hr} \times ft^2$$

3 - 25

### Isokinetic Sampling

$$\% \text{ Isokinetic} = \frac{V_n}{V_s} \times 100$$

3 - 26

### FRM 5 Isokinetic Rate Equation

$$\%I_{int} = 100 \frac{T_s V_{m(std)} P_{std}}{T_{std} V_s \theta A_n P_s 60 (1 - B_{ws(est)})}$$

$$\%I_{final} = \frac{100 T_{s(avg)} K_3 V_{lc} + \frac{V_{m(avg)}}{T_{m(avg)}} P_{bar} + \frac{\Delta H}{13.6}}{60 \theta V_{s(avg)} P_s A_n}$$

3 - 27


### FRM 5 Isokinetic Rate Equation (Simplified)

$$D_n(est) = \sqrt{\frac{0.0358 Q_m P_m}{T_m C_p (1 - B_{ws(est)})} \sqrt{\frac{T_s M_s}{P_s \Delta P_{est}}}}$$

$$\Delta H = \left\{ 846.72 D_n^4 \Delta H @ C_p^2 (1 - B_{ws})^2 \frac{M_d T_m P_s}{M_s T_s P_m} \right\} \Delta P$$

3 - 28

### Pollutant Mass Rate (pmr)



$$pmr = c_s Q_s$$

Where:  $c_s$  = the pollutant concentration

3 - 29

### Concentration, $c_s$

$$c_s = \frac{m}{V} = \frac{\text{Quantity of pollutant (mass)}}{\text{Quantity of effluent gas (vol)}}$$

Units: g/m<sup>3</sup>, lbs/ft<sup>3</sup>, gr/ft<sup>3</sup>, ppm

Note: 7000 grains (gr) = 1 lb

3 - 30

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 3: Introduction to Stack Testing and Gas Physics

$$pmrS = c_s Q_s$$

$$\frac{\text{lbs}}{\text{hr}} = \frac{\text{lbs}}{\cancel{\text{ft}^3}} \times \frac{\cancel{\text{ft}^3}}{\text{hr}}$$

3 - 31


Emission Rate  
(Combustion Sources)

$$E = \frac{pmr_s}{Q_H} \left( \frac{\text{lbs}}{10^6 \text{ Btu}} \right)$$

Where:  $Q_H$  = heat input rate in units of Btu/hr

3 - 32

Federal Reference Method 5 Equations




3 - 33

# APTI #450/468 Compliance Test and Source Test Observation


## Lesson #4A: FRM 1: Sampling/Velocity Traverse Points

### Compliance Test and Source Test Observation

#### FRM 1: Sampling/Velocity Traverse Points



4A - 2



### FRM 1 History

- 1970 Promulgated
- 1983 Reduced Number of Traverse Points
- 1986 Alternative Procedure for Site Selection
- 1989 Method 1A, Traverse Points in Small Ducts

4A - 5

### FRM 1

- Method 1 specifies both the sampling site location and the location of the sampling points to which the source tester will measure a representative sample
  - Pollutant emissions
  - Total volumetric flow rate


4A - 6

### FRM 1 Basic Principle


- "...the more convoluted the ductwork, the more points will need to be tested."
- Representative measurement
- Modifications to FRM 1
  - Rectangular stacks
  - Only measuring velocity
  - Stacks smaller than 12 inches

4A - 7

### FRM 1 Sampling Site Locations



### Particle mass concentration profile, mg/m<sup>3</sup>




Source: Adapted from Buhne, 1977

4A - 9

### FRM 1 Siting Criteria



### Ideal Siting Criteria



Port is downstream of A  
 Port is upstream of B

### FRM 1 Applicability

- > 12" diameter duct, stack
- Not for use in cyclonic, swirling
- Not for sample locations
  - < 2 Diameter downstream from flow disturbance
  - < 0.5 Diameter upstream from flow disturbance
- Check "as built" drawings for external and internal interferences above and below sampling port locations

4A - 12

### **Exceptions to FRM 1 (Can't use FRM 1)**

- #1: Cyclonic or swirling gas flow (>20 degrees)
- #2: Stack smaller than 0.30 m (12") in diameter or cross-section area is less than 0.71 m<sup>2</sup> (113 in<sup>2</sup>), Use Method 1A

4A - 13

### **Exceptions to FRM 1 (Can't use FRM 1)**

- #3: Measurement site is less than 2 duct diameters downstream or less than 0.5 diameters upstream from a flow disturbance  
(Use Alternative Procedure, Section 11.1.2)

4A - 14

### **FRM 1 Flow Disturbance**

- Bend in duct
- Expansion or contraction in the duct
- Visible flame

4A - 15

### **Stack Extensions Required**

- When stack is too short for proper port location
- Straightening vanes are needed to remove cyclonic or swirling flow
- Possible down draft from wind blowing across stack

4A - 16

### **Sampling Location**

- Determine the upstream and downstream disturbances
- Measure the distance the sampling port is from those disturbances
- Divide the distance by the diameter of the stack
- Ideal location is 8 downstream and 2 upstream

4A - 17



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson #4A: FRM 1: Sampling/Velocity Traverse Points**



**FRM 1 Siting Criteria**

- At 8 duct diameters downstream and 2 duct diameters upstream of a flow disturbance, the siting criteria states
  - Velocity head profile is assumed to resemble laminar flow

4A - 21

**FRM 1 Siting Criteria**


- The minimum number of sampling points can be used
  - 8 or 9 for 12-24 in. stacks
  - 12 for > 24 in. stacks

4A - 22

**FRM 1 Siting Guidance**

- Federal Register provides illustrations for minimum number of traverse points for particulate traverses and velocity traverses (Figure 1-1 in Federal Register)
- Federal Register provides location of traverse points (Figure 1-2 in Federal Register)

4A - 23




4A - 24  
 (Minimum number of traverse points for particulate traverses.)



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson #4A: FRM 1: Sampling/Velocity Traverse Points



### FRM 1 Equal Areas



- The circular duct is divided up into four equal quadrants, each of which is divided into equal areas
- Traverse points are then located at the centroid of these areas
- Two perpendicular diameters
- One diameter must be in the “plain of the bend.”

4A - 26

**Table 1 - 2 Location of Traverse Points in Circular Stacks**  
(Percent of stack diameter from inside wall to traverse point)

Traverse point on a diameter	Number of traverse points on a diameter											
	2	4	6	8	10	12	14	16	18	20	22	24
1	14.6	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	85.4	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3		75.0	29.6	19.4	14.6	11.8	9.9	8.5	7.5	6.7	6.0	5.5
4		83.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5			85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6			95.6	80.6	65.8	35.6	26.9	22.0	18.8	16.5	14.6	13.2
7				89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8				96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9					91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10					97.4	88.2	79.9	71.7	61.8	36.9	31.5	27.2
11						93.3	85.4	78.0	70.4	61.2	39.3	32.3
12							97.9	90.1	83.1	76.4	69.4	60.7
13								94.3	87.5	81.2	75.0	68.5
14								98.2	91.5	85.4	79.6	73.8
15									95.1	89.1	83.5	78.2
16									98.4	92.5	87.1	82.0
17										95.6	90.3	85.4
18										98.6	93.3	88.4
19											96.1	91.3
20											98.7	94.0
21												96.5
22												98.9
23												96.8
24												98.9

4A - 27





### FRM 1 Location of Traverse Points

- Percent distance of traverse point from inside wall of duct determined from Table 1-2 in Method 1
  - >24" stacks, no traverse point within 1 inch
  - <24" stacks, no traverse point within 0.5 inches

4A - 31



4A - 32


### FRM 1 Rectangular Ducts

- In the case of rectangular ducts, an "equivalent diameter",  $D_e$ , is used in the siting and traverse point consideration
  - $D_e = 2LW / (L + W)$
  - Must use balance matrix

4A - 33

### FRM 1 Diameter Equivalent Formula for Rectangular Ducts

$$D_e = \frac{2LW}{(L + W)}$$




**Table 1–1 Cross-section Layout For Rectangular Stacks 40CFR Part 60 Appendix A**

Number of tranverse points layout	Matrix
9 .....	3 x 3
12 .....	4 x 3
16 .....	4 x 4
20 .....	5 x 4
25 .....	5 x 5
30 .....	6 x 5
36 .....	6 x 6
42 .....	7 x 6
49 .....	7 x 7

4A - 35

### Rectangular Duct (3 X 4)



4A - 36

### **Section 11.4.1**

- In most stationary sources, the direction of stack gas flow is essentially parallel to the stack walls. However, cyclonic flow may exist (1) after such devices as cyclones and inertial demisters following venturi scrubbers, or (2) in stacks having tangential inlets or other duct configurations which tend to induce swirling; in these instances, the presence or absence of cyclonic flow at the sampling location must be determined.

4A - 37

### **FRM 1 Verification or Absence of Cyclonic Flow**

- Cyclonic flow may exist (Section 1.1)
  - After such devices as cyclones and inertial demisters following venturi scrubbers
  - In stacks having tangential inlets or other duct configurations which tend to induce swirling

4A - 38

### **Cyclonic Flow Determination (Ducts >4in.)**

- Equipment
  - Manometer
  - Type S pitot tube/level indicator
- Procedure
  - "Null" reading; O.K.
  - Determine delta p if not "null"
  - Acceptance avg.  $\Delta p < 20$  degrees

4A - 39

### **FRM 1 Alternative Measurement Site Selection Procedure**


- Applies at sites  $< 2/0.5$  siting
  - Must use "directional probe" to measure "yaw" and "pitch" angles at more than 40 traverse points
  - Calculate Resultant Angle (Ri)
    - $Ri = \text{Arccos}[(\cos Y_i)(\cos P_i)]$
    - If  $Ri < 20$  degrees, then can use sample location

4A - 40

### **Method 2F Equipment**

- 3D Probes
  - Spherical
    - Easy Leak Check
    - More Sensitive
    - Less Costly
  - Prism (DAT)

4A - 41




4A - 42



### 3-D Probe Measurements

- P1: Impact Pressure
- P2-P3: Yaw Angle
- P4-P5: Pitch Angle
- P1-P2: Total Velocity

4A - 44



### 3-D Probe Measurement

- Position probe at traverse point and verify position of "scribe line."
- Pre leak check
- Record yaw and pitch angles at each traverse point
- Calculate resultant angle
- Post leak check

4A - 46

### 3-D Probe Measurement


- Yaw to "null"; Record gauge reading yaw angle ( $Y_i$ ) at traverse point.
- Record gauge reading pitch angle and determine pitch angle ( $P_i$ ) from calibration curve.
- Complete for each traverse point.
- Calculate Resultant Angle ( $R_i$ )
  - $R_i = \text{Arccos}[(\cos Y_i)(\cos P_i)]$

4A - 47

### Pitch Angle Curve (F1 Calibration Curve)

- $F1 = (P4 - P5) / (P1 - P2)$
- Manufacturer plots F1 vs. Pitch Angle at Qualified Wind Tunnel at Two Flow Rates (60 and 90 ft/sec)

4A - 48



### 3-D Probe Measurement For Acceptance Criteria

- Calculate Resultant Angle (Ri)
  - $Ri = \text{Arccos}[(\cos Y_i)(\cos P_i)]$
- Measurement location is acceptable if
  - $Ri_{avg} = \leq 20$  degrees
  - $S_d = 10$  degrees

4A - 50

### Role of the Inspector FRM 1 Activities

- Verify duct > 12 in. diameter for proper equipment selection
- Verify duct dimensions
- Verify upstream/downstream distances
- Check for blockage (Feel, look into duct for blockage)

4A - 51

### Role of the Inspector FRM 1 Activities

- Verify required number of points
- Adjust the required number of points if required (0.5 in. < 12 in.; 1 in. > 12 in. to stack wall)
- Check for cyclonic flow (average of < 20 degrees for all sampling point)
- Observe "Alternative Site Selection" verification

4A - 52

### Major Points in FRM 1

- Limitation of method (Sec. 1.2)
- For rectangular stacks, equivalent diameter (Sec. 11.2.1.1)
- Minimum number of traverse points (Sec. 11.2.1.1)
- For particle sampling, one diameter in plane of bend (Sec. 11.3.1.2)

4A - 53

### Major Points in FRM 1

- Relocation of traverse points (Sec. 11.3.2.1)
- Definition of cyclonic flow (Sec. 11.4.1)
- Verification of absence of cyclonic flow (Sec. 11.4)

4A - 54

### **Major Points in FRM 1**

- Alternative Measurement Site Location (Sec. 11.5)
  - Directional flow sensor and resultant angle (Sec. 6.1.1)
  - Post leak check required at 3 in. water (Sec. 11.5.3.1)

4A - 55

### **Major Points in FRM 1**

- Alternative Measurement Site Location (Sec. 11.5) Continued
  - Calculate resultant angle at each traverse point (Sec. 11.5.1)
  - Calibration of directional flow sensor (Sec. 11.5.4)

4A - 56

### **FRM 1 Inspector Tools**

- Tape measure
- Field Observation Agency Checklist
- Type S pitot tube (cyclonic flow check) and level indicator
- 3-D pitot tube (alt. meas. site) and level indicator

4A - 57

### **FRM 1 Tips**

- Measure the stack diameter from each sampling port and average values
- Find in-stack restrictions by using gloved hand and visual inspection of internal area
- Don't forget to take into consideration the nipple of the stack or inner lining in calculations

4A - 58

### **FRM 1 Tips**

- If measurement site location is after venturi scrubber or stack has tangential inlets, verify absence of cyclonic flow
- If stack is < 12 in., do not use this method (Use FRM 1A)
- If measurement site location < 2 D/0.5 D, don't use method

4A - 59

### **FRM 1 Tips**

- Add first and last traverse points together to get internal stack diameter and compare to calculated value
- Don't forget to add pipe coupling (nipple) diameter to calculated traverse points
- "White-out" is an excellent tool for marking probe

4A - 60

**Dismiss Stack Test FRM 1**

- Stack geometry not measured properly  
(Wrong number of points)
- Failure to identify cyclonic flow
- Failure to consider small ducts


4A - 61

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 4B: FRM 2: Stack Gas Velocity**

**Compliance Test and Source Test Observation**  
**FRM 2: Stack Gas Velocity**




4B - 1



4B - 2

**POLLUTANT MASS RATE**



4B - 3

Environmental Protection Agency Pt. 60, App. A, Meth. 2





Figure 2-1. Type S pitot tube manometer assembly.

4B - 4



4B - 5

**FRM 2**

- This method is applicable for measurement of the average velocity of a gas stream
- The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Stausscheibe or reverse type) pitot tube

4B - 6



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 4B: FRM 2: Stack Gas Velocity**

**FRM 2 History**


- 1970 Promulgation of FRM 2
- 1983 FRM 2A in Small Ducts
- 1983 FRM 2B Stoichiometry Flow
- 1989 FRM 2C Std Pitot Small Ducts
- 1989 FRM 2D Rate Meter
- 1996 FRM 2E Landfills
- 1999 FRM 2F 3-D Yaw/Pitch Angle
- 1999 FRM 2G Type S/3-D
- 1999 FRM 2H Wall Effects

4B - 7

**Can't Use FRM 2**

- Failed siting criteria (Minimum of 2/0.5 diameters)
- Duct/stack < 12"
- Cyclonic flow exist at location
  - Install straightening vanes
  - Calculate total volume flow stoichiometry
  - Go to another sampling location

4B - 8



4B - 9

**Stack Modifications Due to Cyclonic Flow**



**FRM 2 Pitot Tubes**

- Each type pitot tube measures an impact and stagnation pressure and combines the measurements to obtain a velocity pressure
- Size of manometer requires:
  - $\Delta p > 0.05$  " water, then 0-10 " manometer adequate
  - $\Delta p < 0.05$  " water, then use manometer with 0.005 /division (i.e., micro-manometer)
  - $\Delta p < 0.01$  "water, then use high sensitivity transducer such as Hasting Thermo Probe<sup>11</sup>

**Interference-Free Component Arrangement**

- Pitot tube distance to nozzle: >3/4 inches for 1/2 nozzles
- Center of nozzle and pitot tube opening aligned
- Thermocouple location to pitot tube > 3/4 inch for 3 inches
- Back-recess thermo. > 2 inches
- Gas sampling assembly > 3 inches from pitot tube

4B - 12




### Type S Pitot Tube


Design criteria for assigning

$$C_p = 0.84$$


4B - 13



4B - 14




4B - 15



4B - 16


#### ■ Properly Constructed S-type Pitot Tube



- (a) end view; face opening planes perpendicular to transverse axis;
- (b) top view; face opening planes parallel to longitudinal axis;
- (c) side view; both legs of equal length and centerlines coincident, when viewed from both sides. Baseline coefficient values of 0.84 may be assigned to pitot tubes constructed this way.

4B - 17


#### ■ Types of face opening mis-alignments that can result from field use or improper construction of type S pitot tubes



4B - 18

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 4B: FRM 2: Stack Gas Velocity**

Types of face opening mis-alignments that can result from field use or improper construction of type S pitot tubes (cont.)




The types of face-opening misalignment shown above will not affect the baseline value of  $C_{p_{90}}$  so long as  $\alpha_1$  and  $\alpha_2 \leq 10^\circ$ ,  $\beta_1$  and  $\beta_2 \leq 5^\circ$ ,  $z \leq 0.32$  cm (1/8 in.), and  $w \leq 0.08$  cm (1/32 in.) (Reference 11.0 in Section 16.0)

4B - 19


**Verification of Geometry of Type S Pitot Tube To Assign 0.84**

- $\alpha_1$  and  $\alpha_2$  (+/- 10 degrees)
- $\beta_1$  and  $\beta_2$  (+/- 5 degrees)
- $Z = \leq 0.125$  inches
- $W = \leq 0.031$  inches
- $P_a$  and  $P_b$  0.263 to 0.375
- $D_t = 0.188$  to 0.375

4B - 20



4B - 21






4B - 22



4B - 23




**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 4B: FRM 2: Stack Gas Velocity**




**Type S Pitot Tube  
Calibrate Using a  
Standard Pitot Tube  
and  
Wind Tunnel**

4B - 28



4B - 29



4B - 30

### Pitot Tube Calibration Equation

$$C_{p(s)} = \left[ \frac{\Delta p_{std}}{\Delta p_s} \right]^{1/2} C_{p(std)}$$

4B - 31

### Pitot Tube Calibration Data Sheet

4B - 32

### Velocity Measurement Procedures

1. Leak-check pitot tube and differential pressure gauge.
2. For circular stacks less than 10 ft in diameter, two ports are sufficient. Use four ports when stack diameter is greater than 10 ft.
3. Pitot tubes longer than 10 ft should be structurally reinforced to prevent bending of tube and misalignment errors.
4. Identify each sample port and traverse point with a letter or number.
5. Read velocity head and temperature at least twice at each point and record the average.


4B - 33

### Velocity (cont.)

6. Care should be taken to prevent touching the pitot tube tip to the side of the stack.
7. Plug unused sampling ports and seal port being used as tightly as possible.
8. After traverse, check differential pressure gauge; repeat traverse if zero has shifted.
9. If liquid droplets are present, use a liquid trap in positive pressure leg of pitot tube.
10. A post-test leak check is required after each run of the pitot tube and velocity pressure system.


4B - 34

### Pitch Angle




4B - 35

### Yaw Angle



4B - 36

### Velocity Error vs. Yaw Angle For a Type S Pitot Tube



4B - 37

### Federal Reference Method 2 Average Velocity Over Cross-Section Area of Stack

$$\bar{v}_s = K_p C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{M_s P_s}}$$


4B - 38

### Average Stack Gas Dry Volumetric Flow Rate

$$Q_{std} = 3600 (1 - B_{ws(avg)}) v_{s(avg)} A \frac{T_{std} P_s}{T_{s(avg)} P_{std}}$$

4B - 39

### Static Pressure Measurements



4B - 40

### Stack Pressure ( $P_s$ )

$$P_s = P_b + \frac{P_g}{13.6}$$

4B - 41

### Barometric Pressure

Barometric pressure during testing is obtained by:

- Instrument:
- Mercury, aneroid or other barometer (with required sensitivity)
  - Other
  - Obtain barometric pressure from nearby National Weather Service station (station pressure) and adjust for elevation differences between sampling site and weather station.

4B - 42

### **Pressure Probe and Gauge**

Static pressure measurement must be accurate to within 1 in. Hg (13.6 in. H<sub>2</sub>O).

Pressure sensors typically used to measure static pressure during testing include:

- A piezometer tube and mercury or water-filled U-tube manometer
- The static tap of a pitot tube
- One leg of the Type S pitot tube

4B - 43

### **Applicability**

Method 2 is applicable only at sites that:

- Meet the criteria of Method 1
- Do not contain cyclonic or non-parallel flow

4B - 44

### **Alternatives When Unacceptable Conditions Exist**

(Subject to approval of the Administrator)

- Install straightening vanes.
- Calculate total volumetric flow rate stoichiometrically.
- Move to a measurement site at which flow is acceptable.
- Use procedures as described in Method 2 for cyclonic flow.

4B - 45

### **Type S Pitot Tube Inspection Data Sheet**

- With the S-Type pitot tube, determine whether it meets the design specifications to be able to assign a C<sub>p</sub> of 0.84
- C<sub>p</sub> may be determined in conjunction with standard pitot tube
- Identification number scribed on pitot tube

4B - 46

### **FRM 2 Velocity Equation**

$$v_s = K_p C_p \left( \sqrt{\Delta p} \right)_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

4B - 47

### **FRM 2 Inspector Tools**

- Level indicator
- Modular pitot tube
- Hand-held manometer
- Pocket barometer
- Hand-held digital thermometer and thermocouples

4B - 48

### **FRM 2 Inspector Tools**

- Bull's eye level
- Field observation agency checklist
- Stack sampling nomographs for field estimations
- 3-D pitot tube

4B - 49

### **Major Points in FRM 2**

- 0-10 in. manometer for  $> 0.05 \Delta p$
- $< 0.05 \Delta p$ , use 0.005 in. divisions
- Thermocouple and magnehelic calibration required
- Type S pitot tube: configuration, calibration, and leak check

4B - 50

### **Major Points in FRM 2**

- FRM 2 not applicable at sites not meeting FRM 1 (Sec. 1.2)
- FRM 2 cannot be used in cyclonic or swirling flow (Sec. 1.2)
- Alternative guidance
  - install straightening vanes
  - calculate flow stoichiometrically
  - select another location (Sec. 1.2)

4B - 51

### **Major Points in FRM 2**

- Type S pitot tube should have a known coefficient (Sec. 2.1)
- Ident. # on pitot tube (Sec. 2.1)
- Acceptable design specifications allow  $C_p$  of 0.84 (Sec. 2.1)
- Standard pitot may be used, but must demonstrate not plugged during use (Sec. 2.1)

4B - 52

### **Major Points in FRM 2**

- Design specification of Type S pitot tube (Fig. 2-3)
- Manometer specifications of 0-10 in. for  $>0.05 \Delta p$  (Sec. 2.2)
- Provides guidance on use of more sensitive gauge (Sec. 2.2)
- Provides calibration of magnehelic gauge (Sec. 2.2)

4B - 53

### **Major Points in FRM 2**

- FRM 2 provides guidance on adjustment of barometric pressure with altitude (Sec. 2.5)
- Need to take static pressure measurement only once during the test (Sec. 3.4)
- Must verify the face opening alignment, measure and record (Sec. 4.1)

4B - 54

### **Major Points in FRM 2**

- Guidance with Type S pitot tube in association to probe/nozzle/thermocouple placement (Sec. 4.1)
- Calibrate against standard pitot tube at 3,000 ft/min (Sec. 4.1.2.3)

4B - 55

### **Major Points in FRM 2**

- Must leak check all pitot lines (Sec. 4.1.3.1)
- May calibrate Type S pitot tube at source (Sec. 4.1.5.1.1)

4B - 56

### **Major Points in FRM 2**

- Must verify that probe sheath interference is < 2% of area of stack (Sec. 4.1.5.1.3)
- May use of  $C_p$  for Side A or B or may average (Sec. 4.1.6.1.1)

4B - 57

### **FRMs 2F, 2G, and 2H New Flow Test Methods**

- Method 2F: calculates axial velocity (3-D Probes)
- Method 2G: calculates “near-axial” velocity (Type S or 3-D probes)
- Method 2H: Wall effects (Type S or 3-D probes or default wall effects adjustment factor)

4B - 58

### **Dismiss Stack Test FRM 2**

- Pitot tube leak check at 3 “ water failed
- Pitot tube geometry not to specifications
- Pitot tube orientation during test not proper

4B - 59



# APTI #450/468 Compliance Test and Source Test Observation


## Lesson 5A Stack Test Basics – FRM 3

U.S. EPA APTI  
Compliance Test and  
Source Test Observation

Stack Test Basic Continued

**Method 3**

Determination of the dry molecular weight of flue gas  
(using Orsat apparatus measuring %O<sub>2</sub>, %CO<sub>2</sub>, and %CO)



5A - 1

**POLLUTANT MASS RATE**

$$\bar{C}_s = \frac{PMR_s}{\bar{c}_s O_2} = \frac{\bar{C}_s}{\frac{m_i}{V_m}}$$

for  
Isokinetic Conditions

$$v_s = K_p C_p \sqrt{\frac{T_s \Delta p}{M_s P_s}}$$

Obtain  $C_p, T_s, \Delta p$   
 $M_s, P_s$

Obtain  $\Delta H_{@}, D_n$   
 $B_{ws}, B_{wm}$   
 $P_m, T_m$

5A - 2

Federal Reference  
Method 3 History

- 1970FRM 3      Promulgated
- 1986FRM 3A    Instrumental
- 1990FRM 3B    Orsat for Correction Factor and Excess Air (F<sub>o</sub>- Factor)
- 1996FRM 3C    Landfill Gas

5A - 3


Federal Reference  
Method 3

- Gas analysis: measuring percent of O<sub>2</sub> and percent of CO<sub>2</sub> to determine the dry molecular weight of the flue gas (using Orsat Apparatus)

5A - 4


Orsat Analyzer

**Oxidation  
Reduction  
Selective  
Absorption  
Technique**





5A - 5

Orsat Analyzer



5A - 6

APTI #450/468 Compliance Test and Source Test Observation  
Lesson 5A Stack Test Basics – FRM 3



### FRM 3 Sampling Techniques

- Single point grab sample
- Single point integrated sample
- Integrated multi-point sample

5A - 13

### Single-Point Grab Sampling Train




Figure 3-1. Grab-Sampling Train.

5A - 14

### Single-Point Integrated Sampling Train





Figure 3-2. Integrated Gas-Sampling Train.

5A - 15

### Multi-point Integrated Sampling Train

#### Multi-Point Integrated Sampling



5A - 16

### Multi-Point Continuous Integrated Sampling

- Particulate sample and variations
- Modified Method 5 sampling
- VOST sampling
- For concentrations given to specific conditions (i.e., 12 % CO<sub>2</sub>, 6 % O<sub>2</sub>)
- For emission rate calculations (F-factor)
- For molecular weight determination

5A - 17

### FRM 3 Calculation

#### • Dry Molecular Weight Equation

$$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2 + \%CO)$$

Where:  $M_d$  = dry molecular weight

%CO<sub>2</sub> = present CO<sub>2</sub> by volume (dry basis)

%O<sub>2</sub> = present O<sub>2</sub> by volume (dry basis)

%CO = present CO by volume (dry basis)

%N<sub>2</sub> = present N<sub>2</sub> by volume (dry basis)

0.44 = molecular weight of CO<sub>2</sub> divided by 100

0.32 = molecular weight of O<sub>2</sub> divided by 100

0.28 = molecular weight of N<sub>2</sub> divided by 100

5A - 18

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 5A Stack Test Basics – FRM 3

### Method 3 Data Uses

- Calculate molecular weight of the stack gas
- Emission rate correction
  - FRM 20 contains the equation to correct an emission rate to a % O<sub>2</sub> or % CO<sub>2</sub>

$$C_{adj} = C_d \left[ \frac{(20.9 - \%O_{2corr})}{(20.9 - \%O_{2meas})} \right]$$

5A - 19

### Method 3 Data Uses

- Emission rate calculation
  - FRM 19 contains the equation to determine a heat input-based emission concentration

$$E = C_d F_d \left[ \frac{20.9}{(20.9 - \%O_{2dry})} \right]$$

5A - 20

### Problems with FRM 3

- Leak in pump or bag
- Process gives off CO<sub>2</sub> or O<sub>2</sub>
  - Cement plant- Cannot validate F<sub>o</sub>
  - FGD scrubber- Cannot validate F<sub>o</sub>
- Incomplete combustion cannot validate F<sub>o</sub>- Too low for fuel
- Processes removing CO<sub>2</sub> or O<sub>2</sub>

5A - 21

### FRM 3B Equations

#### *Fuel Factor*

$$F_o = \frac{(20.9 - O_2)}{CO_2}$$

#### *Excess Air*

$$\%EA = \frac{(\%O_2 - 0.5\%CO)}{(0.264\%N_2 - (\%O_2 - 0.5\%CO))}$$

5A - 22

### FRM 3B F<sub>o</sub> Factors

<b>Coal: Anthracite</b>	<b>1.016-1.130</b>
<b>Coal: Bituminous</b>	<b>1.083-1.230</b>
<b>Oil: Distillate</b>	<b>1.260-1.413</b>
<b>Oil: Residual</b>	<b>1.210-1.370</b>
<b>Gas: Natural</b>	<b>1.600-1.836</b>
<b>Gas: Propane</b>	<b>1.434-1.586</b>
<b>Gas: Butane</b>	<b>1.405-1.553</b>
<b>Wood</b>	<b>1.000-1.120</b>
<b>Wood Bark</b>	<b>1.003-1.130</b>

5A - 23

### FRM 3 Major Points

- Applicability (Sec. 1.2)
- Method modifications (Sec. 1.2)
  - A multi-point sampling method/ Orsat at each point
  - Using CO<sub>2</sub> or O<sub>2</sub> and stoichiometric calculations
  - Assigning value of 30.0

5A - 24

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 5A Stack Test Basics – FRM 3

---

### FRM 3 Major Points

- Sampling approaches (Sec. 1.2)
- Leak-check Tedlar bags (Sec. 6.2.6)
- Sampling point in the stack for single point grab (Sec. 8.1)
- Multi-point integration (Sec. 8.3):  
>24 in. 12 Pts; <24 in. 8 Pts

5A - 25

### FRM 3 Major Points

- Sampling at constant rate and same time as FRM 5 (Sec. 8.2.5)
- Analysis time 8 hours (Sec. 8.2.4)
- Leak-check Orsat (Section 11.5)
- $F_o$  Factor (Method 3B)
- Can't use Fryite (Method 3B)
- Triplicate trials

5A - 26

### FRM 3 Inspector Tools

- Field observation agency checklist
- Stack sampling nomographs for field estimations
- Fryite-type combustion gas analyzer

5A - 27

### FRM 3 Tips

- Don't forget to take into account correction for altitude location of sampling port (0.1 in./100 ft)
- Stack gas pressure also requires determination of stack static pressure ( $P_g$ ):  $P_g/13.6$

5A - 28

### FRM 3 Tips

- Leak check sampling bag
- Leak check sampling train lines before sampling
- Leak check Orsat analyzer
- Minimum 12 sampling pts. (>24 in.)
- Minimum 8 sampling pts. (<24 in.)

5A - 29

### FRM 3 Tips

- Validate analytical data
  - Analyze ambient air ( $O_2 = 20.9 \pm 0.3\%$ )
  - Analyze against protocol gases ( $\pm 0.2\%$ )
  - $F_o$  Calculation
  - Nomograph verification

5A - 30

## APTI #450/468 Compliance Test and Source Test Observation

### Lesson 5A Stack Test Basics – FRM 3

---

#### FRM 3 Tips

- Analyze bag sample within 8 hours
- No more than 20 separate analysis for a given set of reagents
- Three separate analysis for each bag
  - $\pm 0.3\%$  if  $\text{CO}_2 > 4\%$
  - $\text{O}_2 < 15\%$
  - then  $\pm 0.2\%$

5A - 31

#### Dismiss FRM 3 Stack Test

- Failed to calibrate Orsat analyzer
- Tedlar bag found to be leaking
- $F_o$  outside of  $\pm 5\%$  of calculated value
- $\text{O}_2/\text{CO}_2$  outside of typical range


5A - 32

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 5B Stack Test Basics - FRM 4


### U.S. EPA APTI Compliance Test and Source Test Observation

#### Stack Test Basic Continued



**Method 4**  
Determination of moisture content of stack gas (by condensation method)

5B - 1




5B - 2

### Two Methods in FRM 4

- Reference method (FRM 5 Condenser Methodology)
- Approximate Methodology
  - FRM 6 Impingers
  - Wet Bulb/Dry Bulb
  - Nomographs

5B - 3




5B - 4

### Federal Reference Method 4



5B - 5

### Wet Bulb/Dry Bulb




5B - 6



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 5B Stack Test Basics - FRM 4**

Psychrometric Chart




5B - 7

Calculating % Moisture Under Saturated Gas Stream

$$\%H_2O = \frac{10 \left( 6.691 - \left( \frac{3144}{(T_s + 390.86)} \right) \right)}{(P_s \times 100)}$$

5B - 8

FRM 4 Approximate Method Sampling Train



5B - 9

B<sub>ws</sub> = Proportion of water vapor in the gas stream.  
 (by volume)

$$B_{ws} = \frac{V_{wc(std)}}{V_{m(std)} + V_{wc(std)}}$$

5B - 10

FRM 4 Key Points

- Reference Method: Condenser Approach (Sec. 8.1)
- Approximation Method: Method 6 impingers, wet bulb/dry bulb, charts (Sec. 6.1.1.2)
- Saturated gas streams may give questionable results (Sec. 4.1)

5B - 11

FRM 4 Key Points

- Design of train (Method 5, sec. 6.1.1.8)
- Number of traverse points (sec. 8.1.1.1)
- Minimum sample vol. (21 scf) and sampling rate (0.75 cfm) (Sec. 8.1.1.2)
- Sampling at a "constant sampling rate" (Sec. 6.1.4)

5B - 12

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 5B Stack Test Basics - FRM 4

---

### FRM 4 Key Points

- Leak rate determined from filter (Sec. 8.2.1)
- Approximate Method  
(Method 6, section 10.1 and Method 5, section 10.6, respectively)

5B - 13

### FRM 4 Key Points

- Two calculations for saturated/ moisture droplet gas stream
  - One measurement on saturation conditions
  - One measurement on impinger technique
- Lower of these two values used in calculations

5B - 14

### FRM 4 Inspector Tools

- Hand-held digital thermometer
- Field observation agency checklist
- Stack sampling nomographs for field estimations

5B - 15

### FRM 4 Tips

- Don't forget to wipe moisture from the outside of each impinger before weighing (Section 11.1 scale (0.5 g – weigh only))
- Do not weigh U-tube connectors
- Condensibles other than water leads to positive bias in results (i.e., acid aerosols and condensable organics)
- Stack gases that are supersaturated or no demisting

5B - 16

### FRM 4 Tips

- Typical moisture ranges
  - Coal: 5-15%
  - Oil: 8-10%
  - Gas: 8-10%
  - After wet scrubbers: 4-70%
  - Wood: 15-30%
  - Kilns: 30-40%
  - Sewage sludge incinerators: 5-30%
- Use wet/dry bulb and nomographs to verify moisture

5B - 17

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 6: FRM 5: Particulate Emissions Sampling**

**Compliance Test and Source Test Observation**

*FRM 5: Particulate Emissions*



6 - 1



6 - 2

**Federal Reference Method 5 Sampling Train**




6 - 3



6 - 4



6 - 5



6 - 6




**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 6: FRM 5: Particulate Emissions Sampling**



**Particles**

**PM stands for particulate matter (also called particle pollution): the term for a mixture of solid particles and liquid droplets found in the air. Some particles, such as dust, dirt, soot, or smoke, are large or dark enough to be seen with the naked eye. Others are so small they can only be detected using an electron microscope.**


6 - 9






# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 6: FRM 5: Particulate Emissions Sampling



6 - 13



6 - 14

Health Effects - Nontoxic Particles	
Concentration of Particles in $\mu\text{g}/\text{m}^3$	Effect
2000 $\mu\text{g}/\text{m}^3$ with 0.4 ppm SO <sub>2</sub> (24-hr avg) episodes of several days duration	Increase in deaths due to bronchitis
1000 $\mu\text{g}/\text{m}^3$ with 0.25 ppm SO <sub>2</sub> (24-hr avg) during episodes	Increase in mortality from all causes including respiratory and cardiac disease
300 $\mu\text{g}/\text{m}^3$ with 0.21 ppm SO <sub>2</sub> (annual avg)	Significant increase in bronchitis symptoms
130 $\mu\text{g}/\text{m}^3$ with SO <sub>2</sub> (annual avg)	Increase in frequency and severity of lower respiratory illness
100-200 $\mu\text{g}/\text{m}^3$ with 0.05 to 0.08 ppm SO <sub>2</sub> (avg seasonal levels)	Increase in incidences of bronchitis reported above this level

6 - 15

- ### How Do We Define Particulate Matter for Source Emissions?
- TPM?
  - FPM?
  - FPM-I?
  - TPM-PM<sub>10</sub>?
  - FPM-I-PM<sub>10</sub>?
  - CPM?
  - MCEM?

6 - 16

### Definition of Particulate Matter

- **Total Particulate Matter (TPM):** The sum of the filterable particulate (i.e., front half of the FRM 5 sampling train) and the condensable particulate matter (i.e., the back half of the FRM 5 sampling train, including water and organic soluble extractions, Method 202)

6 - 17

### Definition of Particulate Matter

- **Filterable Particulate Matter (FPM):** The mass of the filterable particulate matter (i.e., front half of the FRM 5 sampling train) that is captured on the filter at a temperature of 248 °F +/- 25 °F

6 - 18

### **Definition of Particulate Matter**

- **Filterable (In-stack) Particulate Matter (FPM-I):** Particulate matter as measured by FRM 17 at stack temperature and pressure
- **Total Particulate Matter PM-10 (TPM-PM10):** Sum of the filterable PM-10 as measured by FRM 201 and 201A and the condensable particulate matter determined by FRM 202

6 - 19

### **Definition of Particulate Matter**

- **Filterable (In-Stack) Particulate Matter PM-10 (FPM-I-PM10):** Particulate matter with an aerodynamic diameter of < 10 micrometers as measured by FRM 201 or 201A
- **Condensable Particulate Matter (CPM):** Particulate matter captured in the back half of the FRM 5 sampling train, including water and organic soluble extraction components, Method 202.

6 - 20

### **Definition of Extractable Particulate Matter**

- **Methylene Chloride Extractable Particulate Matter (MCEM):** MCEM involves methylene chloride rinse of the probe and filter holder, extracting the condensable hydrocarbons collected in the impinger water and rinses after the filter to the silica gel, all residue determined gravimetrically after evaporation of solvents (i.e., FRM 315)

6 - 21

### **History of FRM 5**

- 1970 FRM 5: Filterable PM @ 248 °F
- 1982 FRM 5A: PM @ 108 °F for Asphalt Roofing, Pre-collector cyclone and trichloroethane (TCE) rinse
- 1986 FRM 5B: Nonsulfuric Acid PM with Sampling and Volatilization of Filter @ 320 °F
- Reserved FRM 5C: Small Ducts (Reserved)
- 1984 FRM 5D: PM @ 248 °F from Positive Fabric Filters

6 - 22

### **History of FRM 5**

- 1985 FRM 5E: PM @ 248 °F from Mineral Wool Plus Captured Condensable in 0.1 N NaOH (TOC)
  - Total Carbon @ 1740 °F
  - Inorganic Carbon @ 300 °F
  - $C_t = C_s + C_c$
- 1986 FRM 5F: Non-sulfuric acid PM @ 320 °F with water rinse and ammonium sulfate subtraction

6 - 23


### **History of FRM 5**

- 1988 FRM 5G: PM @ 90 °F from wood stoves using a dilution tunnel with 100-mm series filters
- 1988 FRM 5H: PM from wood stoves stack with 1<sup>st</sup> filter @ 248 °F, then impingers followed by 2<sup>nd</sup> filter @ 68 F
- 1999 FRM 5I: Low level (<50 mg) PM using FRM 5 sampling train with 47-mm filter @ 248 °F and paired sampling trains (< 10%)

6 - 24

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 6: FRM 5: Particulate Emissions Sampling




- ### Emission Generation Categories
- Transportation
  - Stationary source fuel combustion
  - Industrial processes
  - Solid waste disposal
  - Miscellaneous
- 6 - 26

- ### Stationary Combustion Sources
- Produce energy but no other products. Emissions result from fuel combustion.
- Fixed energy generating sources range in size from home heating furnaces to major power plants.
  - Sources include commercial, institutional, industrial, and steam-electric power plants.
  - Fuels used include coal, oil, natural gas, and wood. Other fuels such as liquefied natural gas, propane, process gas, etc. may also be used.
- 6 - 27

- ### Industrial Processes
- Emits pollutants in the course of manufacturing products:
  - Major sources include chemical processing, food and agricultural industries, metallurgical and mineral product factories, petroleum refining, petrochemical plants, petroleum storage, and wood-processing industries.
  - Smaller sources include painting, dry-cleaning, and degreasing operations.
- 6 - 28

- ### Solid Waste Disposal
- Facilities that dispose of unwanted products and by-products. Emissions result from the disposal process --usually burning.
- 6 - 29





### Basic Operation of FRM 5

- Isokinetic Source Sampling
- “Iso” as denoting equality, similarity, uniformity.
- “Kinetic” is defined as of, pertaining to, or due to motion
  - $\Delta H = K \Delta p$

6 - 31

### Simplified Isokinetic Rate Equation

$$\Delta H = K \Delta P$$

6 - 32

### Isokinetic Sampling and Bias



- To obtain average pollutant concentration, need parameters:
  - Quantity of mass emitted from stack
  - Total quantity of volume from stack

6 - 33






### Isokinetic Sampling and Bias

- Isokinetic sampling provides best approach for accurate data
- Pollutant mass rate (pmr)
  - $pmr_a$  (Ratio-of-areas:  $A_n$  ratio  $A_s$ )
  - $pmr_c$  (Ratio-of-conc.:  $m_n$  ratio  $A_n$ )

6 - 34



APTI #450/468 Compliance Test and Source Test Observation  
 Lesson 6: FRM 5: Particulate Emissions Sampling



**Isokinetic Sampling**

$$\% \text{ Isokinetic} = \frac{V_n}{V_s} \times 100$$

6 - 42

### In Order To Take An Isokinetic Sample, We Must....

- Calculate the motion of the gas stream passing by the sampling system, and
- Recreate that motion in the sampling system

6 - 43

### FRM 5 Isokinetic Rate Equation

$$I_{int} = 100 \frac{T_s V_{m(std)} P_{std}}{T_{std} v_s \theta A_n P_s 60 (1 - B_{ws(est)})}$$

$$I_{final} = \frac{100 T_{s(avg)} \left[ K_4 V_{1c} + \left( \frac{V_{m(avg)} \gamma}{T_{m(avg)}} \right) P_{bar} + \frac{\Delta H}{13.6} \right]}{60 \theta V_{s(avg)} P_s A_n}$$

6 - 44

### FRM 5 Isokinetic Rate Equation (Simplified)

$$D_{n(est)} = \sqrt{\frac{0.0358 Q_m P_m}{T_m C_p (1 - B_{ws(est)})}} \sqrt{\frac{T_s M_s}{P_s \Delta p_{est}}}$$

$$\Delta H = \left\{ 846.72 D_n^4 \Delta H_{@} C_p^2 (1 - B_{ws})^2 \frac{M_d T_m P_s}{M_s T_s P_m} \right\} \Delta P$$


6 - 45

### FRM 5 Isokinetic Rate Equation

- The relationship between “ $v_s$ ” and “ $v_n$ ” is the core understanding of FRM 5 and isokinetic sampling
- Reading the “ $\Delta p$ ” from the pitot tube and setting the proper “ $\Delta H$ ” on the meter box allows one to sample isokinetically

6 - 46

### FRM 5 Nomograph



6 - 47

### FRM 5 Isokinetic Rate Equation

$$\Delta H = \left\{ 846.72 D_n^4 \Delta H_{@} C_p^2 (1 - B_{ws})^2 \frac{M_d T_m P_s}{M_s T_s P_m} \right\} \Delta P$$


6 - 48

### FRM 5 Operation

#### Setting $\Delta H$ Based Upon $\Delta p$ Observation and Calculated K Factor

$$K = \frac{\Delta H}{\Delta p} = K_6 D_n^4 \Delta H_{@} C_p^2 (1 - B_{ws})^2 \frac{M_d T_m P_s}{M_s T_s P_m}$$

6 - 49



#### FRM 5 Causes for not Meeting 100% Isokinetics

- Heavy grain loading, causing plugging of filter so can't achieve proper  $\Delta H$
- Large temperature variations not corrected in isokinetic rate equation

6 - 51

#### FRM 5 Causes for not Meeting 100% Isokinetics

- Moisture value wrong in setting preliminary isokinetic rate equation
- Inability to follow rapid fluctuations in  $\Delta p$  and corresponding calculating/setting  $\Delta H$

6 - 52

#### FRM 5 Causes for not Meeting 100% Isokinetics

- Leak in pitot or sampling lines (broken probe, lopsided filter, broken frit)
- Preliminary selection of wrong nozzle size

6 - 53

#### Difficulty in Maintaining Isokinetics

- Plugging of filter by particles
- Filter becoming wet: low box temperature
- Impinger stem too restricted


6 - 54

### Difficulty in Maintaining Isokinetics

- Filter disc plugging
- Nozzle too small/large for velocity of stack gas

6 - 55

### FRM 5 Sampling Train




6 - 56

### Isokinetic Sampling and Bias

- To obtain average pollutant concentration, need parameters:
  - Quantity of mass emitted from stack
  - Total quantity of volume from stack
- Isokinetic sampling provides best approach for accurate data
- Pollutant mass rate (pmr)
  - $pmr_a$  (Ratio-of-areas:  $A_n$  ratio  $A_s$ )
  - $pmr_c$  (Ratio-of-conc.:  $m_n$  ratio  $A_n$ )

6 - 57

### Percent Isokinetic vs: Pollutant Concentration



6 - 58

### Errors in pmr Calculations Using FRM 5

- $T_s$ : 1.4 %
- DGM: 1.0 %
- $P_s$ : 0.4 %
- $P_m$ : 0.4 %
- $P_b$ : 0.2 %
- $B_{ws}$ : 1.0 % Affects % Iso
- $\Delta H$ : 5.0 %
- $D_n$ : 1.0 %
- $\Delta H_{@}$ : 1.5 %

6 - 59

### What Are the Significant Errors With FRM 5?

- Before obtaining the answer, the tester or observer needs to know three things to determine what is important in significant errors with FRM 5:
  - What is the data to be used for (i.e., proof of compliance, proof of violation, engineering evaluation etc.)?

6 - 60

### What Are the Significant Errors With FRM 5?

- Know three things (cont'd):
  - What are the direction and magnitude of any biases?
  - What is the acceptable bias that will be allowed before rejecting the results?

6 - 61

### Source Compliance

- If test results show compliance:
  - Any magnitude of bias in the data that increases measured results (high bias), accepted as compliance
  - (10 % for high bias and 5 % low bias)
- If test results shows violation:
  - Any magnitude of bias in the data that shows violation of standard, then test data can contain any level of low bias
  - (10 % for low bias and 5 % for high)

6 - 62

ERROR ANALYSIS OF SAMPLING PARAMETERS

Parameter	True value	Error	Erroneous value	Concentration (%) <sup>a</sup>	O <sub>2</sub>	O <sub>2</sub> std	Pollutant mass rate (g) <sup>b</sup>	Requirement
P <sub>bar</sub>	30 in. Hg	1 in. Hg	31 in. Hg	+ 4.1	-1.6	+1.6	+5.9	±0.1 in. Hg
ΔH	30 in. Hg	1 in. H <sub>2</sub> O	30.97 in. Hg	+ 0.2	-	-	+0.2	none
ts	530°K	0°K	530°K	- 0.9	-	-	-0.9	±5-2°F
P <sub>s</sub>	30 in. Hg	2 in. H <sub>2</sub> O	30.16 in. Hg	1 0.1	+0.2	+0.2	+0.3	±1.36 in. H <sub>2</sub> O
ts	400°K	10°F	410°K	- 0.4	+0.8	+0.8	-1.2	±1.56
Δp	1 in. H <sub>2</sub> O	0.1 in. H <sub>2</sub> O	1.1 in. H <sub>2</sub> O	- 2.5	+4.9	+4.9	+2.4	equip. spec.
Moisture	10%	1%	11%	+ 0.1	-0.2	+1.3	+1.4	±1%
Md	29	1% CO <sub>2</sub>	29.15	+ 0.1	-0.3	+0.3	+0.4	±0.1%
Md	29	1% O <sub>2</sub>	29.03	+ 0.1	-0.1	+0.1	+0.2	±0.1%
Md	29	1% CO	29	-	-	-	-	±0.1%
Md	100 mg	1 mg	101 mg	1.0	-	-	1.0	±0.5 mg
Time	120 min	1 min	121 min	- 0.4	-	-	-0.4	none
Y	1.00	0.01	1.01	- 1.0	-	-	1.0	±2%
Cp	0.94	0.01	0.95	- 0.6	+1.2	+1.2	+0.6	±0.03
Nozzle diameter	0.250 in.	0.005 in.	0.255 in.	- 2.0	-	-	-2.0	±0.002 in.
Isokinetic	100%	10%	110%	- 5.0	-	-	-5.0	±10%
F factor	15 O <sub>2</sub>	15 O <sub>2</sub>	65 O <sub>2</sub>	+ 6.7%	N/A <sup>c</sup>	N/A <sup>c</sup>	N/A <sup>c</sup>	±0.15 O <sub>2</sub>
F factor	10% O <sub>2</sub>	15 O <sub>2</sub>	11% O <sub>2</sub>	+10.1%	N/A <sup>c</sup>	N/A <sup>c</sup>	N/A <sup>c</sup>	±0.15 O <sub>2</sub>
F factor	15% O <sub>2</sub>	15 O <sub>2</sub>	10% O <sub>2</sub>	+20.4%	N/A <sup>c</sup>	N/A <sup>c</sup>	N/A <sup>c</sup>	±0.15 O <sub>2</sub>

Note: All errors are a theoretical calculation and it is assumed that a 2% error in isokinetics will cause a 1% error in both concentration and pollutant mass rate emissions. The percentage of error may vary slightly depending on the magnitude of the true value and the different assumptions made.

<sup>a</sup>Error due to calculation and combined isokinetic bias.  
<sup>b</sup>Error due to calculation and combined isokinetic bias.  
<sup>c</sup>Sp<sub>o</sub> effect on the measured value.  
<sup>d</sup>lb/10<sup>6</sup> lbs is actually a concentration standard.  
<sup>e</sup>N/A - not applicable.

6 - 63

### Example #1 (Stack Temperature)

- Asphalt plant with concentration standard of 0.04 gr/scf
- Team measured stack temperature at 350 F, but correct temperature was 320 F
- Question: How much error?
  - From Table, -0.4 %/10 F
  - Therefore, -1.2 % total error
  - Little effect!

6 - 64

### Example #2 (Orifice Meter)

- Dry dog food plant
- Allowable mass emissions 5 lbs/hr
- DGM “Y” determined to be 0.91, but tester using 0.97
  - From Table, 1.0 % error for each 0.01
  - Therefore, 6 % bias high error
  - May want to reject test!

6 - 65

### FRM 5 Principle

- Particulate matter is drawn isokinetically from an applicable source and collected on a glass fiber filter maintained at regulated temperature (usually 120°C ±14°C)
- The particulate mass is determined gravimetrically after removal of uncombined water

6 - 66

### FRM Method 5 Limits

- Particulate matter (PM) target catch as a concentration or amount of an analyte that can be determined with a specific degree of confidence to be different from zero

6 - 67

### FRM 5

- “Front Half” is defined as particulate emissions
- Filter Temperature
  - 248°F
  - 320°F
- Isokinetic Sampling
  - $Velocity_{nozzle} = Velocity_{stack}$
  - 90% - 110%

6 - 68

### FRM Method 5 Limits

- Designed for PM catches of > 50 mg
- Limits for FRM 5
  - Practical quantitation limit (PQL) of 3 mg
  - Method detection limit (MDL) of 1 mg
- Target catch for FRM 5 must be no less than 3 mg; If less, go to FRM 5I

6 - 69

### Required Sampling

- Sampling duration: 60 –120 minutes
- Sampling rate: 0.50-0.75 dscfm
- Minimum sampling volume: 30 – 60 dscf
- Review 40CFR60/61 for minimum sampling duration, volumes and filter/gas temperatures
- Minimum sample volume dependent on analyte MDLs and expected concentrations

6 - 70

### Example

Given the following information use the isokinetic  $\Delta H$  equation to find a  $K$  factor for setting isokinetic rate through the sampling train:

- $Q_m = 0.75 \text{ CFM}$
- $\Delta H_{@} = 1.85$
- Pitot tube  $C_p = 0.85$
- $t_m = 80^\circ\text{F}$
- $P_m = 30.0 \text{ in. Hg}$
- $P_s = 29.6 \text{ in. Hg}$
- $B_{atm} = 0$
- $B_{ws} = 0.12$
- $t_s = 280^\circ\text{F}$
- $M_d = 29 \text{ lb/lb-mole}$
- Average  $\Delta p = 0.80 \text{ in. H}_2\text{O}$

You will need to find  $M_s$ , then solve the equations for nozzle diameter and  $K$ .

6 - 71

### Example Problem (cont.)

Ans:

$$M_s = M_d(1 - B_{ws}) + 18 B_{ws}$$

$$M_s = 29(1 - .12) + 18(.12) = 27.7$$

$$D_n = \sqrt{\left(\frac{0.0357 Q P_m}{T C_p}\right) \frac{1}{(1 - B_{ws})} \sqrt{\frac{T M_s}{P_s \Delta p}}}$$

$$= \sqrt{\frac{(0.0357)(.75)(30.0)}{(540)(.85)} \frac{1}{.88} \sqrt{\frac{(740)(27.7)}{(29.6)(.80)}}}$$

$$= .241$$

6 - 72



### Example Problem (cont.)

choose .25" nozzle

then

$$\Delta H = \left[ 846.72 D_n^4 \Delta H_p^2 (1-B_{ws})^2 \frac{M_d}{M_s} \frac{T_m}{T_s} \frac{P_s}{P_m} \right] \Delta p$$

$$= \left\{ 846.72 (.25)^4 1.85(.85)^2 (.88)^2 \frac{29}{27.7} \left( \frac{540}{740} \right) \left( \frac{29.6}{30.0} \right) \right\} \Delta p$$

$$= 2.59 \Delta p$$

$$\Delta H = 2.59 \Delta p$$

.73

### Example Problem (cont.)

What do you do if  $\Delta p = 1.0$   
 .80  
 .60

Say if moving probe from traverse point to traverse point  
 - get new  $\Delta p$ 's at each point, calculate and set new  $\Delta H$ 's  
 at each point.

How do you set the  $\Delta H$ ?

6 - 74

### FRM 5 Isokinetic Rate Equation

- The relationship between " $v_s$ " and " $v_n$ " is the core understanding of FRM 5 isokinetic sampling
- Reading the " $\Delta p$ " from the pitot tube and setting the proper " $\Delta H$ " on the meter box allows one to sample isokinetically

6 - 75

### Sampling Train Components

- The probe assembly
- The sample box
- The umbilical
- The meter box


6 - 76

### The Probe Assembly

- Nozzle
- Pitot Tube
- Thermocouple
- Probe liner
- Probe sheath

6 - 77

### The Probe Assembly



6 - 78

### **FRM 5 Sampling Probe**

- Typical diameter of 2.54 cm
- Should be stainless steel or equivalent
- Pitot tube must be firmly welded to probe
- Probe design to prevent accidental misalignment in gas stream

6 - 79

### **FRM 5 Sampling Probe**

- Probe design to protect liner
- Material of construction determined by temperature/compounds being monitored
  - Borosilicate glass liners up to 480 C
  - Quartz liners up to 900 C
  - Teflon liners up to 350 C

6 - 80

### **Probe Liner**

- **Borosilicate or quartz glass**
- **Heating System to maintain exit gas temperature of 120° C**
- **Borosilicate temperature to 480° C**
- **Quartz glass temperature to 900° C**

6 - 81

### **FRM 5 Sampling Probe**

- Must have heating system capable of maintaining gas temperature of typically 120 C +/- 14 C
- Temperature must be calibrated


6 - 82

### **Probe Sheath**

- Usually stainless steel
- Pitot tube welded to sheath to prevent misalignment
- Protects liner from breakage

6 - 83

### **Probe liner and sheath**



6 - 84

### FRM 5 Ceramic Probe Heater



6 - 85



6 - 86



6 - 87



6 - 88

### FRM 5 Sample Nozzle

- Seamless stainless steel tubing or glass or Teflon
- Other materials approved by administrator
- Button-hook/elbow design
  - Sharp/tapered leading edge (<30 angle)
  - Constant internal diameter

6 - 89

### FRM 5 Sample Nozzle

- Range of nozzles (0.32-1.27 cm ID)
  - Nozzle must be calibrated
  - Measure 3 readings using micrometer (take average)
  - Low/high readings not exceed 0.004 inches

6 - 90


APTI #450/468 Compliance Test and Source Test Observation  
Lesson 6: FRM 5: Particulate Emissions Sampling

FRM 5 Sampling Nozzle



6 - 91

Sampling Nozzle



6 - 92



6 - 93



6 - 94



6 - 95



6 - 96



6 - 97

### FRM 5 Sample Nozzle

- Nozzles that have been nicked, dented, or corroded must be reshaped and recalibrated
- Each nozzle must have a permanent identification

6 - 98

$$D_{n(est)} = \sqrt{\frac{K_5 Q_m P_m \sqrt{T_s M_s}}{T_m C_p (1 - B_{ws}) \sqrt{P_s \Delta p_{avg}}}}$$

6 - 99

### FRM 5 Isokinetic Rate Equation (Simplified)

$$D_{n(est)} = \sqrt{\frac{0.0358 Q_m P_m}{T_m C_p (1 - B_{ws(est)})} \sqrt{\frac{T_s M_s}{P_s \Delta p_{est}}}}$$


$$\Delta H = \left\{ 846.72 D_n^4 \Delta H_{@} C_p^2 (1 - B_{ws})^2 \frac{M_d}{M_s} \frac{T_m P_s}{T_s P_m} \right\} \Delta P$$

6 - 100

### FRM 5 Nozzle/Pitot Tube/Thermocouple Orientation


- Must meet certain design and configuration specifications
- Inspect during each test to verify orientation

6 - 101



6 - 102






6 - 103


## Type S Pitot Tube

Design criteria for assigning


6 - 104




6 - 105




6 - 106



6 - 107



6 - 108



### Verification of Geometry of Type S Pitot Tube To Assign 0.84

- $\alpha$  1 and 2 (+/- 10 degrees)
- $\beta$  1 and 2 (+/- 5 degrees)
- $Z = \leq 0.125$  inches
- $W = \leq 0.031$  inches
- $P_a$  and  $P_b$  0.263 to 0.375
- $D_t = 0.188$  to 0.375

6 - 110

### Type S Pitot Tube Inspection Data Sheet

- With the S-Type pitot tube, determine whether it meets the design specifications to be able to assign a  $C_p$  of 0.84
- $C_p$  may be determined in conjunction with standard pitot tube
- Identification number scribed on pitot tube

6 - 111

### FRM 2 Velocity Equation

$$v_s = K_p C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{P_s M_s}}$$

6 - 112

### FRM 5 Sampling Train



6 - 113

### Sampling Train Components

- The probe assembly
- The sample box
- The umbilical
- The meter box

6 - 114



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 6: FRM 5: Particulate Emissions Sampling**

### The Sample Box

#### Heated Filter Box

- Heating element to maintain filter temperature of 120° C
- Filter Holder
- Flexibility for vertical and horizontal traverses
- Insulated

#### Impinger Box

- Provide support and protection for glassware
- Insulated
- Holding container for ice to cool impingers

6 - 115

### FRM 5 Heated Filter Box

- Filter heating system capable of maintaining temperature typically 120 °C +/- 14 °C
- Temperature gauge capable of +/- 3 °C
- May be separate from impinger system for convenience

6 - 116



### FRM 5 Heated Filter Box Desired Features

- Light weight, good insulation
- Positive probe alignment locking system
- Easy accessibility to all parts
- Good electrical system
- Durability/flexibility for vertical and horizontal stacks

6 - 121

### FRM 5 Impinger System

- Material of construction depends upon compounds being tested
  - Glass, Teflon, stainless steel
- Design should allow for additional space for impingers beyond FRM 5 requirements
- Need for water drain tap

6 - 122

### FRM 5 Impinger Assembly



6 - 123




6 - 124



6 - 126

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 6: FRM 5: Particulate Emissions Sampling**





### Problems

- Leak in sampling train:  
low gas volume (correct or void)
- Filter/probe temperature  
not within specification
- Contamination during  
sampling/recovery  
(nozzle scraps on nipple,  
dust falls on filter)

6 - 133

### Problems

- Non-Isokinetics
  - Range outside of  $90 < I < 110$ 
    - If  $< 90$ , bias high (large particles)
    - If  $> 110$ , bias low (high sample volume)
  - Multiply E by  $< 90$ : corrected does not  
pass limit: accept test
  - Multiply E by  $> 110$ : corrected not  
greater than limit: accept test

6 - 134

### FRM 5 Train Components/pmr Error

- $P_{bar}$ : + 5.9%
- $\Delta p$ : + 2.4%
- Moisture: + 1.4%
- Nozzle diameter: - 2.0%
- Isokinetic rate: - 5.0%

6 - 135

### Sampling Train Components

- The probe assembly
- The sample box
- The umbilical
- The meter box


6 - 136

### The Umbilical Line

- Sample lines
- Pitot lines
- Electrical connections
- Covered in a protective  
sheath


6 - 137

### FRM 5 Transfer Line



6 - 138

### FRM 5 Sampling Train



6 - 139

### Sampling Train Components

- The probe assembly
- The sample box
- The umbilical
- The meter box

6 - 140

### The Meter Box

- Pump
- Dry gas meter
- Inclined manometer for  $\Delta p$  and  $\Delta H$  readings
- Flow control valves
- Ports for integrated gas sampling

6 - 141

### FRM 5 Meter Console Desirable Features


- Light weight
- Reliable leak free pump
- Good temperature controls
- Rugged construction/  
good carrying handles

6 - 142

### FRM 5 Meter Console Desirable Features

- Accessibility to components and fuse compartment
- Communication system
- Easy to read digital readouts



6 - 143



6 - 144

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 6: FRM 5: Particulate Emissions Sampling





**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 6: FRM 5: Particulate Emissions Sampling**




6 - 151

**FRM 5 Digital Meter Box**




6 - 152

**FRM 5 Sampling Pump**



6 - 153

**FRM 5 Sampling Train**



6 - 154

**Errors in pmr Calculations Using FRM 5**

- $T_s$ : 1.4 %
- DGM: 1.0 %
- $P_s$ : 0.4 %
- $P_m$ : 0.4 %
- $P_b$ : 0.2 %
- $B_{ws}$ : 1.0 % Affects % Iso
- $\Delta H$ : 5.0 %
- $D_n$ : 1.0 %
- $\Delta H_{@}$ : 1.5 %

6 - 155


**Calibration Laboratory for DGM “ $\gamma$ ” and Orifice Meter “ $\Delta H_{@}$ ” Determinations**



6 - 156



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 6: FRM 5: Particulate Emissions Sampling**



**FRM 5 Flex Train**

Schematic of the EPA Method 5 Flexible Sampling Train

6 - 160

**FRM 5 Compact Train**

6 - 161

- FRM 5 Recovery**
- Note final DGM reading
  - Leak check sampling system
  - Remove probe from sampling train
  - Sample train removed to recovery area
  - Nozzle removed and brushed 3-6X with acetone into sample bottle
- 6 - 162

### FRM 5 Recovery

- Probe brushed and rinsed with acetone 3-6X into sample bottle
- Front half of filter brushed and rinsed with acetone into sample bottle with nozzle/probe rinse
- Filter removed carefully and placed into petri dish. Filter disc scrapped to remove filter particles which are added to dish

6 - 163

### FRM 5 Recovery

- Liquids in impingers measured either by weight normally discarded. Can be saved if further analysis required
- Silica gel weighed either in impinger or returned to sample jar


6 - 164

### FRM 5 Sample Recovery Items




6 - 165

### Method 17



### Method 5



6 - 166


## Method 17

### In-stack Filter Applicability

In sources where particulate matter concentration is independent of temperature



6 - 167

## FRM 17



6 - 168

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 6: FRM 5: Particulate Emissions Sampling**



- ### Method 5I Low PM Concentrations
- Initial Federal Register notice - December 30, 1997
  - FRM 5I promulgation in 1999 with Maximum Achievable Control Technology (MACT) Hazardous Waste Incinerator (HWI) Rule
  - EPA contact: Dan Bivins (919) 541-5244
- 6 - 172

- ### Method 5I Low PM Concentrations
- Validated for Hazardous Waste Incinerators (HWI)
  - Application - Calibrating PM CEMS
  - Accuracy improved through:
    - Improved sampling handling procedures
    - Light weight sample filter assembly which is weighted entirely
    - Use of low residue grade acetone
- 6 - 173

- ### Method 5I Low PM Concentrations
- Description
    - Isokinetic sampling using FRM 5 sampling equipment
    - Paired sampling trains
    - Lightweight out-of-stack filter (47 mm) assembly in FRM 5 hot box
    - Entire filter assembly weighing
    - Design for stack with < 50 mg PM (below 45 mg/dscm, ~0.02 gr/dscf)
- 6 - 174

### **Method 5I Low PM Concentrations**

- Components:
  - Pyrex filter inlet
  - Viton seal ring
  - 47-mm filter paper
  - Stainless steel filter frit
  - 47-mm stainless steel clamp
  - Held together by Teflon tape seal
- Designed to be weighted as a single unit

6 - 175

### **Method 5I Low PM Concentrations**

- Limits for FRM 5
  - Practical quantitation limit (PQL) of 3 mg
  - Method detection limit (MDL) of 1 mg
- Therefore, the target catch must be > 3 mg by adjusting sampling time or sampling rate

6 - 176

### **FRM Method 5I Potential Interferences**

- Attention to filter housing during handling, sampling, and port changes
- Balance room conditions
  - Relative humidity < 50 %
  - Same person perform weighting before and after test
  - Electrostatic charges minimized during sample weighting

6 - 177

### **FRM Method 5I Quality Control (QC) Requirements**

- Same as FRM 5
- Recommended field bias blank train. Similar train, taken to field, prepared, leak checked, and recovered but no sampling of source emissions
- Relative standard deviation
  - $RSD = 100\% |(C_a - C_b)| / (C_a + C_b)$
  - Acceptable limits of < 10%

6 - 178

### **FRM 5 Sampling Train**



6 - 179

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 7: The Source Test

### U.S. EPA APTI Compliance Test and Source Test Observation The Source Test



7-1



7-2



7-3

### The Source Test and Protocols

- Dates/Times (timeliness of the submittal?)
- Facility Information
- Unit(s) to be Tested
- Operating and Control Information
- Stack Diagram
- Methods
- Modifications
  - Listed in the method as written
  - Proposed (who has the authority to approve?)

7-4

### Reviewing the Test Protocol

- Rules/Regulations
- Permits
- Previous Testing History

<http://www.dep.pa.gov/BUSINESS/AIR/BAQ/BUSINESSSTOPICS/SOURCETESTING/Pages/default.aspx>

[SOP-Test-Obs-03012019.pdf \(ohio.gov\)](#)

[Emission Monitoring Unit \(Testing Group\) | Ohio Environmental Protection Agency](#)

7-5

### Reviewing the Test Protocol

Protocol spells out the procedures to be followed by tuning the methods.

- Analyzer ranges
- Detection limits
- Sampling times
- etc.

7-6



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 7: The Source Test

### Reviewing the Test Protocol

- Method specific tuning information
- Production Information
- Final report preparation details
- QA/QC Procedures
- Internal stack diameter
- Sampling port location(s)
  - diagram required
- Location(s) relative to disturbances
  - must meet minimum requirements
  - If not > 3D traverse required

7 - 7

### Pre-test Meeting/Conference

- Smoother Testing , Less Procedural Problems
- Preview facility: emissions unit and control
- Discuss Testing – request changes

7 - 8

### Observing Testing – Be Prepared

Have a Test Protocol Handy

- PPE
- Observation Forms
- Camera (if allowed)
- Paperwork (copies)
- Methods
- Permits
- Rules

7 - 9

### Observing Testing – Take Notes

- Field Data recorded
- INK
- Single-line cross out and initialed
- Computer Entered
- Equipment ID information
- Visual inspection of nozzle, pitot tube
  - Alignment in the stack
  - Nozzle diameter

Date		Operator		Company	
Year	Month	First	Last	Name	Address

Time	Temp	Pressure	Flow	Leak	Other	Notes



7 - 10

### Observing Testing – Take Note

- Calibration and span gases used
- Manometers to scale
- Meter Box Values :  $\Delta H@$ ,  $\gamma$  and calibration dates
- Static and barometric pressures



7 - 11

### Observing Testing – Take Note

- Silica Gel
- Leak checks
- Probe and nozzle clean up
- Filter
- Instrumental Methods



7 - 12



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 7: The Source Test

### Observing Testing- What to be Aware of !

- Umbilical cord crimping during leak check
- Adjusting impinger connections during leak checks
- Turning off the pump during leak check
- Not using highest vacuum during leak check
- Adjusting instrument based on readings
- Fabricating data on field data sheets
- Not traversing the stack for cyclonic flow check

7 - 13

### Types of Problems Found

- Unacceptable Sample Locations
- Port Locations
- Upstream & Downstream Diameters
- Equipment & Electrical Needs/Limitations
- Equipment Clearances
- Port Diameters
- Traversing needs (vertical)

7 - 14

### Types of Problems Found

#### • Equipment Errors

- Operating ranges/calibration gases
- Poor condition or not calibrated
- Incorrect train components
- Improper methods

7 - 15



7 - 16

### Types of Problems Found

#### • Procedural Errors

- Cyclonic flow checks
- Leak checks
- Traverse points
- Isokinetics
- Temperatures and ice downs
- Recovery procedures

7 - 17



7 - 18

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 7: The Source Test

---


### Example of Guidelines (See Resource CD)

FRM	Options	Responsible Party	Affects on Emissions
1	Circular Stack: Use of Particulate Traverse Not In Plane of Bend	Tester	Equal or Lower Emissions
2	Use of Standard Pitot Tube Rather than Type-S	Tester	Equal Values (Observe Possible Plugging )
3	Leak Check of Orsat Analyzer	Tester	Inaccurate O <sub>2</sub> and CO <sub>2</sub> Measurements
4	Use of Flexible Tubes Between Impingers	Tester	None
5	Nozzle Design Other Than Button-hook or Elbow	Administrator	None or Less

7 - 19

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector



Compliance  
Test and Source Test  
Observation


*Role of the Agency  
Inspector/Observer*

8 - 1

### Why Compliance Stack Test and Observation Program ?

- Identify Air Pollutants
- Quantify
- Evaluate Test Results

*by prescribed  
EPA Federal Reference  
Methods (FRMs)*



### Example of Typical Industries

- Coal-fired Power Plants
- Asphalt Plants
- Gas Turbines
- Gasoline Terminals
- Coating and Printing Facilities
- Secondary Aluminum
- Cement Plants


8 - 3

### Groups Involved In A Compliance Test

- Officials of the facility being tested
- Consulting stack testing team
- Agency officials in which the facility is located (i.e., State Air Quality Division)


8 - 4

### Source Test Time-line



8 - 5







### Step 1: Objectives, Protocols and Pre-site Survey



8 - 6




# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector



### Function of Stack Test Observer

*“...the principal function of the stack test observer is to evaluate the representativeness of the compliance test in which emissions are sampled while the plant operates under typical conditions considered representative of day-to-day operations.”*

8 - 16

### The Inspector's/Observer's Role

- Be Present! (Phone insp. and windshield insp. are discouraged)
- Have a Plan, Follow the Plan!
- 3-Tier Inspection
- Observations – “familiar” with 40 CFR 60, App. A, Methods 1-4,5; 1.Velocity Profile, 2.Leak Check, 3.Clean-up 4. Observer Check-list
- Operations of facility
- Sample train recovery and data acquisition

8 - 17

### Inspectors Do's and Don'ts

**DO**

- Ask intelligent questions that add value
- Become “familiar” with test methods rules and test plans
- Show Up! Presence is critical
- Be critical but reasonable
- Reward “quality testing”

**DON'T**

- “Umpire” a test
- Challenge a test w/o good cause
- Be unresponsive to requests
- Hesitant to say “I don't have an answer”
- Be Careless

8 - 18

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector



### Seven Areas of Responsibility of Agency Personnel

- **Familiarize:** Agency observer establishes contact with the source and becomes familiar with operations, emissions, and applicable regulations.
- **Division of Air Quality Reviews Scheduled Source Test:** May be part of compliance test or annual test requirements
- **Division of Air Quality Establish Methodology:** Identify testing methodology as prescribed by regulations and receipt of testing plan from facility or contractor

8 - 20

### Seven Areas of Responsibility of Agency Personnel

- **Division of Air Quality Reviews Final Test Plan:** Pre-test meeting between Division personnel, test team leader and facility to finalize test plan.
- **Actual Compliance Test:** The facility Operations Personnel and Division of Air Quality Test Personnel observe testing methodology.

8 - 21

### Seven Areas of Responsibility of Agency Personnel

- **Review of Test Data:** Division of Air Quality determines compliance and official notification are determined.
- **Continuing Enforcement of Compliance:** Follow-up inspections are undertaken, using data generated from source test as a “baseline” for compliance purposes.

8 - 22

### Compliance Evaluation In Terms of Five Criteria

- Process and control equipment must be operated in such a manner as to produce representative atmospheric emissions
- Location of the sample port and sample points must provide samples representative of the atmospheric emissions

8 - 23

### Compliance Evaluation In Terms of Five Criteria

- The sample collected in the sample train must be representative of the sample points.
- The sample recovered and analyzed must be representative of the sample collected in the sample train
- The reported results must be representative of the sample recovered and analyzed

8 - 24



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

---

### Division of Air Quality Personnel Involved In The Testing

- Phase 1: Preparation and planning
- Phase 2: Conducting the test
- Phase 3: Recovery, transport (Optional), and analysis of the samples (Optional)
- Phase 4: The observer's compliance test report

8 - 25

### Role of The Observer

- Determine whether source test is required
- Coordinate process operation
- Coordinate control equipment operation
- Coordinate testing methodology
- Document all activities during the testing program
- Review test reports

8 - 26

### Role of The Observer

- Specify Division requirements
- Make decisions regarding test methodology, process and control equipment operation and reporting requirements
- Determine representativeness of process and control equipment operation

8 - 27

### Role of The Observer

- Determine acceptability of testing methodology
- Compile summary report of test
- Review test report and make recommendation

8 - 28

### Observer Behavior

- The observer should do all within his/her power to see that testing is successfully completed
- The observer should work cooperatively with the source and consultant
- The observer must be specific and forthright in his/her request
- The observer must be respectful of the positions of the other parties involved

8 - 29


### Observer Techniques

- Do not write on process charts and graphs
- Do not turn knobs and dials
- Do not collect unnecessary data
- Do not touch or adjust testing equipment
- Do not question tester or interfere during critical times of the test
- Do not conceal unacceptable acts or procedures

8 - 30

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector



**Phase 1: Preparation and Planning**


- Division of Air Quality must clarify for the plant representative and stack test team leader procedures to be followed (i.e., compliance test guidelines)
- Identification of Federal Reference Methods (FRMs): PM, Condensibles, Filter Temp, Inorganics, Organics etc.
- Operation level of process during testing (i.e. “baselining” the control equipment/source)
- Data acquisition and reporting of process and test methodology parameters

8 - 32

**Phase 1: Preparing and Planning**

- Block-style flowchart is adequate for our needs for “baselining”
- Do not need design-oriented piping and instrumentation (P&I) engineering drawings
- Only system components need to be block-style rather than actual drawing of equipment

8 - 33



**Utility of Preparing a Block-Style Flowchart**

- Identifies health and safety hazards (i.e., high temperature, high positive pressure, fugitive leaks, slippery/wet surfaces etc.)
- Facilitates compliance evaluation
- Document operating conditions with reference to previous compliance test (“Baselining” the process!)
- Simplifies communications with plant personnel

8 - 36


# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

### Symbols Used in Block-Style Flowcharts


- Solid line.....Solid or liquid stream
- Two Parallel Solid Lines.....Gas stream
- Square or Rectangle.....Major equipment
- Reverse Triangle.....Gas emission point
- Circles with "T" inside...Actual temper.
- Circles with "SP" inside....Static pressure

8 - 37



8 - 38

### What To Do?



8 - 39

### Phase 1: Preparing and Planning

- Division of Air Quality review of submitted test protocol
  - Deviation from standard sampling procedures
  - Operation of facility
  - Identification/discuss of test methods
  - Identification and discussion of sampling location
  - Calibration of all monitoring equipment


8 - 40

### Phase 1: Preparing and Planning

- Observer's Needed Documentation
  - Checklist for Federal Reference Methods (FRMs) and SW-846 Methods
  - Checklist for air pollution control equipment
  - Checklist for facility operation parameters
- Pretest Meeting
  - Finalize sampling plan
  - Establish "Baseline" conditions
  - Coordinate testing schedule
  - Checklist for pretest meeting

8 - 41

### What To Do?



8 - 42

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 8: Role of the Agency Inspector**

### Observer Activities

- Observe preliminary velocity traverse and cyclonic flow check
- Observe nozzle size determination
- Review approximate molecular weight and moisture determination
- Review “K-factor” determination

8 - 43

### What To Do?

The Test

- Observe Locating Probe At 1st Point
- Observe Delta p and Calculate Delta H Using “K-factor”
- Observe setting Delta H with Fine Adjust Knob
- Observe Checking Stack Parameters/new “K-factors”

8 - 44

### What To Do?

The Test

- Observe 1st Test
- Observe 2nd Test
- Observe 3rd Test
- Observe Checking Stack Parameters/new “K-factors”

8 - 45

### Phase 2: Conducting The Test

- Observer’s Checklist
  - Health and safety requirements
  - Tentative testing schedule
  - Facility “baseline” conditions
  - Update stack test methodology checklist
  - Handling irregular situations, potential problems and their solutions
  - Calibration forms/checklist

8 - 46



### What to Watch

- Review records of equipment calibration (pre-test/QC)
- Watch cyclonic flow check and preliminary flow traverse

8 - 48

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

---

### Examine Probe Nozzle, Pitot, And Thermocouple Design

- Center of nozzle and pitot opening aligned
- Impact pressure sensor of pitot above nozzle opening

8 - 49

### Examine

- Type-S pitot tube offset 3/4 inch to side of nozzle
- Thermocouple offset 3/4 inch to side of pitot or set back 2 inches from center of pitot opening

8 - 50

### What to Watch

- Vacuum/pressure leak check
- Check traverse point marks, # is correct and within 1/2 inch

8 - 51

### What to Watch

- Nozzle ID calibrated; 3 measurements within +/- 0.004 inch
- Check dry gas meter with restricted orifice: also, a gamma check

8 - 52

### What to Watch

- Pitot tube leak check; both (+) and (-) sides (check at pressure vacuum > 3 inches water and stable for at least 15 seconds)

8 - 53

### Sample Train Leak Check

- Pre-test should be at 15 inches Hg
- Post test at vacuum >= max. vacuum reached during the test

8 - 54

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

---

### Sample Train Leak Check

- Leak rate < 0.02 cfm acceptable
- Leak rate > 0.02 cfm; either record leak rate and correct sample volume or void the test run

8 - 55

### What to Watch

- Check sampling port is sealed
- Look to see that inclined manometer is level all the time
- Check that sampling train is being moved at the correct time and set at the correct traverse point

8 - 56

### What to Watch

- Check that the operator is recording temperatures and setting sampling rate at the proper times
- Reagents stored properly; i.e., at correct temperature and protected from sunlight

8 - 57

### What to Watch

- Sampling isokinetically; Is  $\Delta H$  on meter box equal to  $\Delta H$  on field data sheet?
- Check % Isokinetic rate equation at various points during the sampling scheme:  $\Delta H = k \Delta P$

8 - 58

### What to Watch

- Check that sampling system temperatures are within specifications:
  - Probe temperature
  - Filter temperature
  - Sorbent temperature
  - Impinger train temperature (iced?)

8 - 59

### What to Watch

- Watch sample recovery
  - Nozzle rinse
  - Probe rinse
  - Front half filter housing rinse
  - Filter recovery
  - Resin recovery
  - Proper labeling/storage of recovered samples

8 - 60



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

---

### What to Watch

- Samples properly identified and tied to specific sample runs
- Chain-of-custody properly prepared and maintained with samples

8 - 61

### What to Watch

- Field and trip blanks prepared properly and shipped with field samples
- Documentation retrieved and signed

8 - 62

### Phase 2: Conducting The Test

- Observe "First Test" Items
  - Configuration/preparation of train
  - Initial leak check
  - Positioning at 1st sampling point
  - Record initial data/operation meter box
  - Calculation of "K" factor
  - Verification of isokinetics
  - Movement of probe to other sampling points/ports
  - VE observations

8 - 63

### Phase 2: Conducting The Test

- Observe "First Test" Items
  - Facility Operation (i.e., "Baselining")
    - Fuel flow meters
    - Process monitors
    - Fuel consumption
  - Data from continuous emission monitors (CEMs)
  - Control equipment monitors
    - ESP (voltage, current, rapping rate etc.)
    - Bag houses (∇ p, bag failure logbook etc.)
    - Wet scrubbers (pH, flow rate etc.)

8 - 64

### Phase 2: Conducting The Test

- Observe "Second Test" Items
  - During second test, record and observe process and pollution control equipment data/operation
  - Verification of operation of Method 5 train and recorded data
  - Movement of probe to final sampling points
  - Final leak check/observation of filter condition
  - Sample recovery and "chain-of-custody (COC)" documentation
  - Final VE observation

8 - 65





### Phase 2: Conducting The Test

- Observe "Third Test" Items
  - During third test, record and observe process and pollution control equipment data/operation
  - Verification of operation of Method 5 and recorded data
  - Observation of continuous emission monitor systems (CEMs) and recorded information
  - Final leak check/train recovery of filter and impingers

8 - 66

# APTI #450/468 Compliance Test and Source Test Observation



## Lesson 8: Role of the Agency Inspector





# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

Flow Constriction?  
Preliminary Traverse is Essential For Cyclonic Flow Check

Hennepin County Energy Center  
8 - 73

Adequate Testing Support?  
8 - 74





**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 8: Role of the Agency Inspector**



**Method 5 PM Test**

1974                      2004                      8 - 82

FRM 5 and FRM 202

8 - 83

**Set up**                      **Clean up**


Inspector: Use Discretion                      8 - 84


# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

*Inspector Presence*

*"Be There"*





- Never circumvent Plant Safety Rules
- Adhere to Test Plan
- Communicate during testing
- Gather data, i.e. leak check

8 - 85











86

Times Have Changed...The Need to Test Hasn't

1974





2004




*On-site presence is essential!*


8 - 87






**Roof Top Testing**






**Breaching**

8 - 88




**Roof Top Testing**




**Mobile Lab**

8 - 89

**Petroleum Refinery**



**Refinery Process Unit PM/PM-10 Test**



8 - 90



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

Stack Test Observation is a Team Effort



Set-Up, Leak Checks, Operations and Clean-up Essential



Proper Operations are Critical  
*"Study, Then Pass the Test"*



8-93

Operations - Data Acquisition, You Have To Be There!




Load, production limits and temperatures

8-94



Combustion Turbines - MACT





Method 20

8-96




**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 8: Role of the Agency Inspector**

**Vapor Recovery Unit**

8 - 97

**Mobility While Ensuring QA/QC  
Your Responsibility!**



Method 25A


8 - 98

**Mobility**



8 - 99

**Process or Boiler Upsets**




*When to test, when not to test*

8 - 100


**Opacity Observations...**

Clear skies... Or cloudy?



*Visible plume... or water vapor? 101*

**Dark Plumes or White Plumes?**



8 - 102

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 8: Role of the Agency Inspector**



**Testing Issues**

- Safety first – climbing, weather, platforms
- Port scrapping and stack liners
- Ethanol Plants – VOC Emissions
- Flow Disturbance (i.e. Cyclonic Flow)

8 - 104

Safety...

How do YOU stack up?

8 - 105

A hard hat?

Nomex suit?

Safety glasses?

Safety Shoes?

(OSHA 29 CFR 1910.23)

8 - 106

Distance up equals...

...Distance down!

(OSHA 29 CFR 1910.23)

8 - 107

Be Prepared

Buckle Up...

Hook Up...

Lock Up!

8 - 108




**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 8: Role of the Agency Inspector**

**Weather is Critical**  
Dress Accordingly



8 - 109

**Ladder + Cable + Cage**



Be safe up there!  
*(OSHA 29 CFR 1910.23)*

**Safety...Always**



*Compatible and necessary!*

8 - 111



8 - 112

**Cold Weather Testing**




Dress for it!

8 - 113

Water won't break a fall...

*But railings can prevent one!*



8 - 114

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 8: Role of the Agency Inspector

Weather conditions can vary!





Use good judgment during observation!



8 - 115

Check railings, platforms!



Are they safe?

*(OSHA 29 CFR 1910.23)*

8 - 116

Unsafe Testing



Be careful!

8 - 117

Is this safe for testing?



8 - 118


Clear visibility...



Enhances safety!

8 - 119

Water Vapor and Testing




Be careful!

8 - 120



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 8: Role of the Agency Inspector**



Communications are Essential



Make time for **SAFETY!**

8 - 121

Testers use Harnesses!



State inspectors should too!

8 - 122



Respirators...



Are helpful!

8 - 123



Scaffolding or Ladders



Always Buckle Up!

8 - 124

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 9: FRM 201-201A For PM-10 and PM-2.5**



**FRM 201/201A**

PROBLEM

Since we are sampling particulate matter, we must stay isokinetic. If you are using cyclones, must use the flow rate design for the cyclone to maintain proper particulate cut size!

9 - 4

**FRM 201  
 Exhaust Gas Recirculation (EGR)**

- 40 CFR 51, Appendix M
- $Q_c = Q_s + Q_r$  to maintain constant cut size
- Sample isokinetically at each sample point

9 - 5

**FRM 201  
 Exhaust Gas Recirculation (EGR)**

- Must use cyclone, in-stack; probe pre-heated
- FRM 5 glassware can be used, so condensibles can be added by FRM 202
- EGR method uses new technology

9 - 6



**FRM 201**  
**Exhaust Gas Recirculation (EGR)**

- EGR method is recommended if:
  - A total particulate number is also needed because sampling is isokinetically.
  - Stack gas velocities fluctuate

9 - 7

**FRM 201**  
**Exhaust Gas Recirculation (EGR)**

- EGR modification of FRM 5
  - Nozzle has a recycle attachment
  - The recycle gas is heated to stack temperature
  - Adds in-stack cyclone to capture PM-10
  - Delete out-of-stack filter


9 - 8

**FRM 201**  
**Exhaust Gas Recirculation (EGR)**


- Cyclone does have to be calibrated
- Must leak-check: positive and negative
- Can use condenser rather than FRM 5
- Each point isokinetically and same dwell time

9 - 9

**Schematic of EGR Sampling Train**



9 - 10



9 - 11

**FRM 201A**  
**Constant Sampling Rate (CSR)**

- Uses available equipment
- Sample at constant sampling rate required by the PM-10 cyclone or impactor
- Relaxes FRM 5 +/- 10%, sample within 80 and 120 percent of isokinetic flow based upon stack gas velocity (Must keep sampling rate within delta p min and delta p max)

9 - 12

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 9: FRM 201-201A For PM-10 and PM-2.5**

**FRM 201A**  
**Constant Sampling Rate (CSR)**

- Select nozzle based upon delta p min/max
- Interested in small particles, so isokinetic not as important as FRM 5.
- Dwell time at each point is proportional to stack gas velocity. (sec. 8.7.1)
- Assume a Reynolds number  $N_{RE}$  using Equation 10 in the described CFR method and an estimated sampling rate.

9 - 13

**FRM 201A**  
**Constant Sampling Rate (CSR)**

- Total catch may not be accurate as FRM 5
- Can use impactor or cyclone
- If using impactor, must be calibrated
- FRM 201A can also be used with FRM 202
- CSR is recommended if:
  - Particle sizing is desired
  - Low concentration of PM-10

9 - 14

**FRM 201A**  
**Constant Sampling Rate (CSR)**

- A 4-inch port should be adequate for the single  $PM_{10}$  or  $PM_{2.5}$  sampling apparatus.
- A 4-inch diameter port cannot be use, in any circumstances, when the combined dimension of the cyclone and the exceeds the internal diameter of the port.

9 - 15

**PM – 10 Sampling at Cotton Gins**

16

**EPA Method 201A PM10 and PM2.5 sizing cyclones and in-stack filter holder schematic (CFR, 2010) and photograph**  
 (  $\leq 2.5 \mu m$  10 to 2.5  $\mu m$ ,  $> 10 \mu m$  )

9 - 17


9 - 18

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 9: FRM 201-201A For PM-10 and PM-2.5**

**FRM 201/201A Review**


- Both methods measure PM-10 in-stack
- EGR new technology, CSR uses standard test equipment (i.e., FRM 5)

9 - 19





**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 9: FRM 201-201A For PM-10 and PM-2.5**



**FRM 201/201A Review**

- EGR uses a PM-10 cyclone. CSR can use either a cyclone or impactor
- EGR samples isokinetically, therefore total mass is accurate. CSR doesn't sample isokinetically, therefore mass not as accurate

9 - 26

**FRM 201/201A Review**

- If stack velocities fluctuate, the CSR may require more than one sample train
- PM-10 cyclones do not have to be calibrated if they meet design specification. Impactors (201A) must be calibrated

9 - 27

**FRM 201/201A Review**


- CSR calibration of metering system and leak check procedures same as FRM 5
- CSR requires constant sampling rate and dwell time is proportional to stack gas velocity
- EGR is isokinetically and sampling time same as FRM 5

9 - 28

**FRM 201A previously CTM-040**  
**Determination of PM-10/PM-2.5**

- Predetermined constant sampling rate for combined PM-10 and PM-2.5
- In-stack cyclones used to capture PM-10 and PM-2.5
- Method used with FRM 202

9 - 29



9 - 30

### FRM 201A PM-10 and PM-2.5

- Method applies to in-stack measurement of particulate matter equal to or less than PM-10 and PM-2.5
- Use of optimum sampling rate (within limits of flows for PM-10 and PM-2.5 cyclones) near isokinetic conditions
- Methodology uses two in-stack cyclones (PM-10 followed by PM-2.5) followed by ultimate filter

9 - 31

### FRM 201A PM-10 and PM-2.5

- Sampling train identical to FRM 201A PM-10 except a PM-2.5 cyclone is inserted between the PM-10 cyclone and the ultimate filter
- The particulate mass is determined gravimetrically for each size fraction (i.e., PM-10 cyclone, PM-2.5 cyclone, and < 2.5 filter) after removal of uncombined water

9 - 32

### Method for Determination of PM10/PM2.5

- Variations from isokinetic stack conditions maintained with well-defined flow rate
- Filter after PM-2.5 cyclone to trap final particulate matter
- Sampling train is similar to FRM 17
- Sampling rate selected for combined cyclone heads

9 - 33

### FRM 201A: Method for Determination of PM10/PM2.5

- Flow rate determination for cyclones determined from manufacturer's graph

9 - 34

### FRM 201A: Method for Determination of PM10/PM2.5

- Sampling same as FRM 5 (i.e., sample points and time)
- PM-10/PM-2.5 software package available

9 - 35

### Cascade Impactors

- The following slide shows a cascade impactor sampling system that is designed for direct measurement of particle size ranges. The circular plates have different size slots or round holes that allow particles smaller than the impaction plate collection to pass through to the next plate, until they are distributed by size on all plates. These are directly weighed.
- The disadvantage for use in measuring PM from Cascade impactors is that it does not work well when the total PM catch is small.

9 - 36




**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 9: FRM 201-201A For PM-10 and PM-2.5**

**Cascade Impactors**

- Another primary alternative that could be used is employing a Method 5 PM train fitted with a polycarbonate filter instead of a glass fiber (the polycarbonate filter traps PM on its surface, whereas the glass fiber allows PM to penetrate into the fiber, making it difficult to see). Selective electron microscopy is then used to count the fraction of different PM size ranges.


9 - 37

**Cascade Impactors**




9 - 38

**Cumulative Size Distribution from Raw Impactor Data**




9 - 39

**Control Device Penetration Curve with Confidence Limits**



9 - 40

**U.S. EPA APTI**  
**Compliance Test and Source Test**  
**Observation**  
**F-Factors and Units of the Standard**



10 - 1

**Emission Standards for Sources**

- Concentration of stack gas ( $C_s$ )
- Pollutant mass rate (pmr)
- Emission rate (E)
- Process weight rate (R)

10 - 2

**Concentration of Stack Gas ( $c_s$ )**

Can be expressed in:

- ppm
- g/dscm
- gr/dscf

10 - 3

**For example:**

The New Source Performance Standards (NSPS) for asphalt concrete plants is:

0.04 gr/dscf  $\Leftrightarrow$  90 mg/dscm

10 - 4

**Pollutant Mass Rate (pmr)**

Can be expressed in:

- lb/hr
- g/hr

10 - 5

**Pollutant Mass Rate (pmr)**

pmr = Concentration x Stack gas volumetric flow rate

$$= \frac{\text{lb}}{\text{dscf}} \times \frac{\text{dscf}}{\text{hr}}$$
$$= \frac{\text{lb}}{\text{hr}}$$

10 - 6

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 10: F-Factors and Units of the Standard**

**Emission Rate (E)**

Can be expressed in:

- lb/10<sup>6</sup> Btu heat input
- ng/joule heat input

10 - 7

The emission rate, in terms of the units given in the New Source Performance Standards (NSPS), is related to concentration and mass rate in the following manner:

$$E = \frac{pmr}{Q_H} = \frac{c_s Q_s}{Q_H}$$

Where:

Q<sub>s</sub> = the stack gas volumetric flow rate (units of ft<sup>3</sup>/hr, m<sup>3</sup>/hr)

Q<sub>H</sub> = the heat input rate, the rate at which combusted fuel supplies heat to the boiler or other heat utilization system (Btu/hr, Kcal/hr) 10 - 8

By dimensional analysis, it can be seen that the units of E in terms of pollutant mass per unit of heat input are:

$$\text{■ } E = \frac{\text{lb/hr}}{10^6 \text{ BTU/hr}} = \frac{(\text{lb/ft}^3) (\text{ft}^3/\text{hr})}{10^6 \text{ BTU/hr}} = \frac{\text{lb}}{10^6 \text{ BTU/hr}}$$

10 - 9

**For example:**

The NSPS emission rate for fossil-fuel fired steam generators (FFSG) is:

Particulate emissions limited to  
 0.03 lb/10<sup>6</sup> Btu.

10 - 10

**Reporting In Units Of The Standard: F Factor Methods**

To obtain emission rates in units of lb/10<sup>6</sup> Btu, it is necessary for the source sampler to obtain the following information:

1. Pollutant concentration, c<sub>s</sub>
  - a. Pollutant mass captured
  - b. Dry gas volume sampled
2. Effluent volumetric flow rate, Q<sub>s</sub>
  - a. Stack gas velocity
  - b. Stack temperature
  - c. Stack pressure

10 - 11

**Reporting In Units Of The Standard: F Factor Methods**

- d. Dry gas composition (Orsat) %CO<sub>2</sub>, %O<sub>2</sub>, %N<sub>2</sub>
- e. Moisture content
3. Heat input rate, Q<sub>H</sub>
  - a. Fuel input rate
  - b. Proximate analysis of fuel

10 - 12

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 10: F-Factors and Units of the Standard**

**Process Weight Rate (E)**

Can be expressed in:

- lb/tons of product
- kg/metric tons of product

10 - 13

$$\text{Combustion} = \frac{\text{Pollutant mass rate}}{\text{Heat input Rate}}$$

$$\text{Process} = \frac{\text{Pollutant mass rate}}{\text{Item of mass process rate}}$$

10 - 14

**For Example:**

The NSPS for sulfuric acid plants is:

SO<sub>2</sub> emissions limited to 2 kg

SO<sub>2</sub>/ metric ton H<sub>2</sub>SO<sub>4</sub> produced.

10 - 15

**Concentration Corrected To Standard Conditions**

$$C_{\text{corr}} = C_S \frac{P_{\text{std}} T_s}{P_s T_{\text{std}}}$$

10 - 16

**Correcting Concentration to 12% CO<sub>2</sub>**

$$\bar{C}_{S_{12\text{CO}_2}} = \bar{C}_S \frac{12}{\% \text{CO}_2}$$

10 - 17

**Correcting Concentration to 6% O<sub>2</sub>**

$$\bar{C}_{S_{6\% \text{O}_2}} = \frac{\bar{C}_S (20.9 - 6.0)}{20.9 - \% \text{O}_2}$$

10 - 18

Correcting Concentration to 3% O<sub>2</sub>

$$c_s (3\%O_2) = \frac{18c_s}{21 - \%O_2}$$

10 - 19

Excess Air Correction Factor

$$\%EA = \frac{\%O_2 - 0.5\%CO}{0.26\%N_2 - \%O_2 + 0.5\%CO} \times 100$$

$$c_s (\text{corr}) = c_s \left( \frac{150}{100 + \%EA} \right)$$

10 - 20

Method 19  
 F Factor Methods

10 - 21

Reporting in Units of Standard: F  
 factor Methods

- The F factor is used in calculating particulate emission levels from new stationary sources.
- It was promulgated in the October 6, 1975
- The F factor is intended to reduce the amount of data necessary to calculate particulate emissions in terms of the standard expressed as pounds per million Btu heat inputs (lb/10<sup>6</sup> Btu).
- An F factor is the ratio of the gas volume of the products of combustion to the heat content of the fuel.

10 - 22

Reporting in Units of Standard: F  
 factor Methods

- The dry F factor (Fd) includes all products of combustion less water,
- The wet F factor (Fw) includes all products of combustion, and
- The carbon F factor (Fc) includes only carbon dioxide.

10 - 23

Reporting in Units of Standard: F  
 factor Methods

- All of the quantities for c<sub>s</sub> and Q<sub>s</sub> are obtained in a source test
- Q<sub>H<sub>2</sub></sub> may not be easily obtained.
- The accuracy the source fuel flow and analysis representative may be difficult to determine
- F factors are based on simple principles of combustion

10 - 24



**Reporting in Units of Standard: F factor Methods**

- Developed to avoid many of the problems involved in the calculation of E. By using the F factors, E may be obtained from a formula such as the following:
- $E = c_s F_d \left( \frac{20.9}{20.9 - \%O_2} \right)$
- Where: F<sub>d</sub> is the dry F factor
- The F factor essentially replaces the ratio OS/OH and the term in brackets is merely an

10 - 25

**Reporting in Units of Standard: F factor Methods**

- F factors are useful in calculating emissions for particulate matter.
- In their application to continuous monitoring instrumentation for gases, it is even more valuable.
- F<sub>d</sub> factors and its variants (F<sub>c</sub> and F<sub>w</sub> factors) are useful in reporting continuous monitoring data in terms of lb/10<sup>6</sup> Btu heat input

10 - 26

**Reporting in Units of Standard: F factor Methods**

- F factors enables the source operator to monitor only the pollutant gas concentration and the oxygen or carbon dioxide concentrations.
- Without this method, it would be necessary to continuously monitor stack gas velocity, temperature, fuel input rate, and so on.
- This would be possible, but impractical and expensive

10 - 27

**Reporting in Units of Standard: F factor Methods**

- Before proceeding with the derivation of the F factors, it is necessary to give a few definitions used in combustion analysis, namely those for proximate analysis, ultimate analysis, and gross calorific value. The definitions generally apply to the fuel “as received” at the plant.
- 

10 - 28

**Reporting in Units of Standard: F factor Methods**

- Proximate analysis is a fuel analysis procedure that expresses the principal characteristics of fuel as follows:
- |  |              |   |
|--|--------------|---|
| <ul style="list-style-type: none"> <li>1. % moisture</li> <li>2. % ash</li> <li>3. % volatile matter</li> <li>4. % fixed carbon</li> </ul> | } Total 100% | <ul style="list-style-type: none"> <li>5. % sulfur</li> <li>6. Heating value (BTU/lb)</li> <li>7. Ash fusion temperature</li> </ul> |
|--|--------------|---|

10 - 29

**Reporting in Units of Standard: F factor Methods**

- Ultimate analysis is the determination of the exact chemical composition of the fuel. The analysis is generally given in terms of percent hydrogen, percent carbon, percent sulfur, percent nitrogen, and percent oxygen.
- Gross calorific value (GCV), also termed the “high heating value,” is the total heat obtained from the complete combustion of a fuel, referred to a set of standard conditions. The GCV is obtained in the proximate analysis as the “heating value.”

10 - 30

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 10: F-Factors and Units of the Standard**

**Reporting in Units of Standard: F factor Methods**

$$Q_S = (\text{correction air excess}) \frac{V_t}{GVC} \frac{Q_H}{Q_H}$$

Dimensionally, this says

$$\frac{\text{ft}^3/\text{hr}}{\text{BTU}/\text{hr}} = \frac{\text{ft}^3}{\text{hr}}$$

$Q_S$  and  $Q_H$  can be determined at the source.  $V_t$  is obtained from the ultimate analysis of the fuel.

10 - 31

**Reporting in Units of Standard: F factor Methods**

■ Remembering the first equation given in this lesson,

$$E = c_s Q_S / Q_H$$

■ and through substitution

$$E = \frac{c_s V_t}{GCV} \frac{1}{(\text{excess air correction})}$$

The quantity  $V_t/GCV$  is then defined as the  $F_d$  factor and the following simplified equation is obtained:  $E = (c_s F_d) 1/(\text{excess air correction})$

10 - 32

**Reporting in Units of Standard: F factor Methods**

■ For Method 5, the oxygen concentration of the source must be determined simultaneously and at the same traverse. Since the excess air correction using percent oxygen is:

$$(20.9 - \% O_2) / 20.9$$

■ and the equation to be used for calculating emissions for Method 5 is:

$$E = (c_s F_d)(20.9/20.9 - \% O_2)$$

10 - 33

**Reporting in Units of Standard: F factor Methods**

■ Since there are different types of F factors (see Table below). The differences arise in the way in which the excess air corrections are determined.

■ It should also be noted that the F factor method may be used with the percent  $O_2$  and  $c_{ws}$  determined on a wet basis if the moisture content  $B_{ws}$  of the stack is known:

$$E = (c_{ws} F_d) ((20.9/20.9(1 - B_{ws}) - \% O_2))$$

■ *Note:* The subscript w stands for measurements made on a wet basis.

10 - 34


**F Factors Table**

Factor	Excess Air Units	Measurement Required for Emissions Determination	Calculations	Comments
$F_d$	$\frac{\text{dscf}}{10^6 \text{Btu}}$	% $O_2$ (dry basis)	$E = c_s F_d \left[ \frac{20.9}{20.9 - \%O_{2d}} \right]$	$c_s$ determined on dry basis
$F_c$	$\frac{\text{dscf}}{10^6 \text{Btu}}$	% $CO_2$ (dry or wet basis)	$E = c_s F_c \left[ \frac{100}{\%CO_2} \right]$	$c_s$ on dry or wet basis consistent with $CO_2$ measurement
$F_w$	$\frac{\text{wscf}}{10^6 \text{Btu}}$	% $O_2$ (wet basis)	$E = c_{ws} F_w \left[ \frac{20.9}{20.9(1 - B_{ws}) - \%O_{2w}} \right]$	The "wet" F factor, $c_{ws}$ and % $O_2$ on wet basis $B_{ws}$ = average moisture content of ambient air
$F_o$	—	—	$F_o = \frac{20.9 F_d}{100 F_c} = \frac{20.9 - \%O_2}{\%CO_2}$	Miscellaneous factor useful for checking Orsat data <b>10 - 35</b>

**Calculation and Tabulation of F Factors**

The  $F_d$  factor method carries with it the assumption that  $V_t/GCV$ , the ratio of the quantity of dry effluent gas generated by combustion to the gross calorific value, is constant within a given category. This ratio, of course, is the  $F_d$  factor.

$V_t$  is determined from the stoichiometry of the combustion reaction. If a hydrocarbon is burned in air, gaseous products will result, the volumes of which can be calculated. For example



For each pound of fuel undergoing perfect combustion, a known amount of gaseous products will result. Using the stoichiometric relationships resulting from chemical reactions (similar to the preceding example) and given the gross calorific value of the fuel per pound, the following relationships have been developed for the F factors.


10 - 36

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 10: F-Factors and Units of the Standard

### Calculation and Tabulation of F Factors

- The  $F_d$  factor method based on the assumption that  $V_t/GCV$ , is constant within a given category.
- $V_t$  is determined from the stoichiometry of the combustion reaction. When hydrocarbons are burned in air, gaseous products will result and the volumes can be calculated. For example,



For each pound of fuel undergoing perfect combustion, a known amount of gaseous products will result. 10 - 37

### Calculation and Tabulation of F Factors

$$F_d = \frac{227.0 (\%H) + 95.7 (\%C) + 35.4 (\%S) + 8.6 (\%N) - 28.5 (\%O)}{GCV} \quad (\text{metric units})$$

$$F_d = \frac{10^6 [3.64 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O)]}{GCV} \quad (\text{English units})$$

$$F_c = \frac{20.0 (\%C)}{GCV} \quad (\text{metric units})$$

$$F_c = \frac{321 \times 10^6 (\%C)}{GCV} \quad (\text{English units})$$

$$F_w = \frac{347.4 (\%H) + 95.7 (\%C) + 35.4 (\%S) + 8.6 (\%N) - 28.5 (\%O) + 13.4 (\%H_2O)}{GCV_w}$$

$$F_w = \frac{10^6 [5.56 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O) + 0.21 (\%H_2O)]}{GCV_w}$$

10 - 38

### Calculation and Tabulation of F Factors

If the source utilizes a combination of fossil fuels, a simple addition procedure can be used to compute the F factor.

$$F = xF_1 + yF_2 + zF_3$$

Where:  $x, y, z$  = the fraction of total heat input derived from gaseous, liquid, and solid fuels, respectively

$F_1, F_2, F_3$  = the value of F for gaseous, liquid, and solid fossil fuels, respectively

10 - 39

### Calculation and Tabulation of F Factors

- Several F factors have been calculated for various types of fossil and waste fuels. It has been found that for a given type of fuel the F factor does not vary over a significantly large range. In general, it has been reported that the  $F_d$  factor can be calculated to within a  $\pm 3\%$  deviation and the  $F_c$  factor can be calculated to within a  $\pm 5.9\%$  deviation. The calculated factors are given in the Table below.

10 - 40

### F Factors for Various Fuels

Fuel Type	$F_d$		$F_w$		$F_c$	
	dscm/j	dscf/10 <sup>6</sup> Btu	wscm/j	wscf/10 <sup>6</sup> Btu	scm/j	scf/10 <sup>6</sup> Btu
Coal:						
Anthracite <sup>2</sup> -----	2.71x10 <sup>-7</sup>	10,100	2.83x10 <sup>-7</sup>	10,540	0.530x10 <sup>-7</sup>	1,970
Bituminous <sup>2</sup> -----	2.63x10 <sup>-7</sup>	9,780	2.86x10 <sup>-7</sup>	10,640	0.484x10 <sup>-7</sup>	1,800
Lignite -----	2.65x10 <sup>-7</sup>	9,860	3.21x10 <sup>-7</sup>	10,950	0.513x10 <sup>-7</sup>	1,910
Oil <sup>3</sup> :	2.47x10 <sup>-7</sup>	9,190	2.77x10 <sup>-7</sup>	10,320	0.383x10 <sup>-7</sup>	1,420
Gas:						
Natural -----	2.43x10 <sup>-7</sup>	8,710	2.85x10 <sup>-7</sup>	10,610	0.287x10 <sup>-7</sup>	1,040
Propane -----	2.34x10 <sup>-7</sup>	8,710	2.74x10 <sup>-7</sup>	10,200	0.321x10 <sup>-7</sup>	1,190
Bulane -----	2.34x10 <sup>-7</sup>	8,710	2.79x10 <sup>-7</sup>	10,390	0.337x10 <sup>-7</sup>	1,250
Wood -----	2.48x10 <sup>-7</sup>	9,240			0.492x10 <sup>-7</sup>	1,830
Wood bark -----	2.58x10 <sup>-7</sup>	9,600			0.516x10 <sup>-7</sup>	1,920
Municipal -----	2.57x10 <sup>-7</sup>	9,570			0.488x10 <sup>-7</sup>	1,820
Solid waste -----						

<sup>1</sup> Determined at standard conditions: 20°C (68°F) and 760 mmHg (29.92 in. Hg)

<sup>2</sup> As classified according to ASTM D388-77

<sup>3</sup> Crude, residual, or distillate

10 - 41

### Calculation and Tabulation of F Factors

- Three important points that should be made regarding application of the F factor to Method 5 are:
- 1. Only the dry F factor using percent O<sub>2</sub> for the excess air correction may be used in the calculation. The  $F_c$  and  $F_w$  factors may not be used.

10 - 42

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 10: F-Factors and Units of the Standard**

**Calculation and Tabulation of F Factors**

- 2. The oxygen sample is to be obtained simultaneously with the Method 5 run at the same traverse points. This essentially requires that an additional probe be placed along with the Method 5 probe and an additional pump be used to obtain an integrated bag sample over the duration of the run. However, only 12 sample points are required. If there are more than 12 traverse points determined by Method 1, an independent integrated gas sampling train could be used to traverse 12 points in the duct simultaneously with the particulate run.

10 - 43

**Calculation and Tabulation of F Factors**

- 3. The procedures in 40 CFR Part 60.46 apply to new fossil-fuel fired steam generators (new sources are those constructed or modified after August 17, 1971). For existing fossil fuel steam generators, which are regulated by state standards, the state or local regulations should be checked for application of the F factor method.

10 - 44

**Other Uses for F Factors**

- 1. If values for QS (the stack gas volumetric flow rate), and QH (the heat input rate), are obtained during the source test, as they often are, several cross-checks can be made by comparing various calculated F factor values with the tabulated values. Equations that can be used to do this are as follows.

10 - 45

**Other Uses for F Factors**

$$F_d (\text{calc}) = \frac{Q_s (20.9 - \%O_2)}{Q_H \cdot 20.9}$$

$$F_w (\text{calc}) = \frac{Q_{sw} 20.9 (1 - B_{wa}) - \%O_{2w}}{Q_H \cdot 20.9}$$

$$F_c (\text{calc}) = \frac{Q_s \%CO_2}{Q_H \cdot 100} = \frac{Q_{sw} \%CO_{2w}}{Q_H \cdot 100}$$

10 - 46

**Other Uses for F Factors**

- If after calculating Fd, Fc, or Fw, a large discrepancy exists between the calculated value and the corresponding value in the table, the original data for Qs, QH, and the Orsat data should be checked. This is an easy way of conducting a material balance check.
- 1. Using a tabulated value for Fd, Fc, or Fw and the data obtained during the stack test for Qs and %O2, a value of QH may be obtained from the equations.

10 - 47

**Other Uses for F Factors**

- 2. If ultimate and proximate analyses are available, they may be used to calculate an F factor using one of the equations. The calculated value can then be checked with the tabulated values and should be within 3 to 5% agreement, depending on the type of fuel and F factor.
- The F<sub>0</sub> factor is the ratio
- $F_0 = (20.9/100)(F_d/F_c)$
- $F_0 = (20.9 - O_2)/\%CO_2$
- A value differing from those tabulated would necessitate a recheck of the Orsat data.

10 - 48

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 10: F-Factors and Units of the Standard

### Errors and Problems in the Use of F Factors

- The following factors may contribute to errors in reporting emissions by using F factors:
- Deviations in the averaged or “midpoint” F factor value itself.
- Errors in the Orsat analysis and the consequent %O<sub>2</sub> and %CO<sub>2</sub> values.
- Failure to have complete combustion of the fuel (complete combustion is assumed in the derivation of all of the F factor methods).

10 - 49

### Errors and Problems in the Use of F Factors

- Loss of carbon dioxide when wet scrubbers are used affecting the F<sub>d</sub>, F<sub>c</sub> and F<sub>w</sub> factors.
- Addition of carbon dioxide when lime or limestone scrubbers are used, affecting the F<sub>c</sub> factor.

10 - 50

### Errors and Problems in the Use of F Factors

- Since the F factors given are averaged values, differences in the ultimate analysis between fuel samples could easily account for the deviation. Also an error of a few percent in the oxygen concentration could cause a relatively large error in the value of E, or more importantly, could mean the difference between compliance and noncompliance. A publication by Mitchell and Midgett (1976) entitled “Field Reliability of the Orsat Analyzer,” states:

10 - 51

### Errors and Problems in the Use of F Factors

- “The results from five collaborative tests of the Orsat method indicate that the use of Orsat data to determine the molecular weight of flue gases is a valid procedure, but the use of such data routinely to convert particulate catches to such reference conditions as 12% CO<sub>2</sub> and 50% excess air may introduce sizeable errors in the corrected particulate loading...”

10 - 52

### Errors and Problems in the Use of F Factors

- Complete combustion is assumed for the derivation of all F Factor Methods.
- For incomplete combustion when carbon monoxide, are present in the effluent stream, the volume of effluent gas and carbon dioxide per pound of fuel burned will differ from the values used in calculating the F Factors.
- Adjustments to the measured CO<sub>2</sub> or O<sub>2</sub> concentration can be made, which would minimize this error, if the % CO is determined in the flue gas.

10 - 53

### Errors and Problems in the Use of F Factors

- $(\%CO_2)_{adj} = \%CO_2 + \%CO$
- $(\%O_2)_{adj} = \%O_2 - 0.5 \%CO$
- With these adjustments, the error amounts to minus one-half the concentration of carbon monoxide present.
- Thus, if 1% CO (an extreme case) is present, an error of minus 0.5% is introduced. Without adjusting the CO<sub>2</sub> or O<sub>2</sub> concentration, a combustion source having 11% CO<sub>2</sub>, 1 % CO, and 6% O<sub>2</sub> will result in about plus 9% error for the F<sub>c</sub> Factor Method and about plus 3% for the F<sub>d</sub> Factor and F<sub>w</sub> Factor Methods.

10 - 54



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 10: F-Factors and Units of the Standard

### Errors in Source Sampling and F factor Examples

ERROR ANALYSIS OF SAMPLING PARAMETERS							
Parameter	True value	Error	Erroneous value	Concentration (%)	Q <sub>s</sub> (dscfm)	Pollutant mass (lb/hr)	Requirement <sup>1</sup>
P <sub>bar</sub>	30 in. Hg	1 in. Hg	31 in. Hg	+4.1	+1.6	+5.9	30.1 in. Hg
Δh	30 in. Hg	1 in. H <sub>2</sub> O	30.07 in. Hg	+0.2	-0.1	+0.2	none
ts	30 in. Hg	5%	30.15 in. Hg	+0.3	+0.2	+0.3	21.26 in. H <sub>2</sub> O
ts	600°R	10°R	610°R	+1.7	+0.8	+1.4	21.55
Δp	1 in. H <sub>2</sub> O	0.1 in. H <sub>2</sub> O	1.1 in. H <sub>2</sub> O	+10.0	+4.9	+4.4	Equip. spec.
Moisture	10%	1%	11%	+1.0	+0.3	+0.4	20.15
Md	29	15 CO <sub>2</sub>	29.15	+0.1	+0.1	+0.2	20.15
Md	29	15 O <sub>2</sub>	29.03	+0.1	+0.1	+0.2	20.15
Md	29	15 CO	29	0.0	0.0	0.0	20.15
Md	100 mg	1 mg	101 mg	+1.0	+0.4	+0.5	20.15
Time	120 min	1 min	121 min	+0.8	+0.4	+0.4	20.15
Y	1.00	0.01	1.01	+1.0	+0.5	+0.5	20.15
Cp	0.84	0.01	0.85	+1.2	+0.6	+0.6	20.15
Nozzle diameter	0.250 in.	0.005 in.	0.255 in.	+2.0	+1.0	+1.0	20.000 in.
Isokinetic diameter	100%	10%	110%	+10.0	+5.0	+5.0	100%
F Factor	55 O <sub>2</sub>	1% O <sub>2</sub>	56 O <sub>2</sub>	+1.8	N/A <sup>6</sup>	N/A <sup>6</sup>	20.15 O <sub>2</sub>
F Factor	105 O <sub>2</sub>	1% O <sub>2</sub>	106 O <sub>2</sub>	+0.9	N/A <sup>6</sup>	N/A <sup>6</sup>	20.15 O <sub>2</sub>
F Factor	15% O <sub>2</sub>	1% O <sub>2</sub>	16% O <sub>2</sub>	+6.7	N/A <sup>6</sup>	N/A <sup>6</sup>	20.15 O <sub>2</sub>

Note: All errors are a theoretical calculation and it is assumed that a 2% error in isokinetics will cause a 1% error in both concentration and pollutant mass rate emission. The percentage of error may vary slightly depending on the magnitude of the true value and the different assumptions made.

<sup>1</sup>Error due to calculation and combined isokinetic bias.

<sup>2</sup>Error due to calculation and combined isokinetic bias.

<sup>3</sup>No effect on the measured value.

<sup>4</sup>lb/10<sup>6</sup> Btu is actually a concentration standard.

<sup>5</sup>N/A - not applicable.

### Example F Factor Problem

- The Bradshaw Furniture Company has an industrial steam generating unit of greater than 250 x 10<sup>6</sup> Btu/hr heat input. The unit fires Bituminous coal and has an extractive CO<sub>2</sub> monitor. Recent testing showed an effluent SO<sub>2</sub> concentration of 750 ppm (wet basis) and 12.8 % CO<sub>2</sub>(dry basis). The average stack moisture content is 7% H<sub>2</sub>O.
- What is the emission rate in lb/10<sup>6</sup> BTU

10 - 56

### What is the emission rate in lb/10<sup>6</sup> BTU

- Use F<sub>C</sub> and convert C<sub>SO2</sub> from ppm to lb/dscf


$$(750 \text{ ppm}) \times 10^{-6} \frac{\text{ft}^3 \text{ SO}_2}{\text{ft}^3 \text{ air/ppm}} \times (64 \text{ lb SO}_2) \times \frac{(\text{lb-mole})}{392.75 \text{ ft}^3} = 1.22 \times 10^{-4} \text{ lb/dscf}$$

$$1.22 \times 10^{-4} \text{ lb/dscf} \times \frac{(1 \text{ ft}^3 \text{ wet})}{(1 - 0.07) \text{ ft}^3 \text{ dry}} = 1.31 \times 10^{-4} \text{ lb/dscf}$$

$$E = C_s F_C \frac{100}{\text{CO}_2} = 1.31 \times 10^{-4} \text{ lb/dscf} \left( \frac{1800 \text{ ft}^3/10^6 \text{ BTU}}{100/12.8} \right)$$

$$= 1.85 \text{ lb SO}_2/10^6 \text{ BTU}$$

10 - 57



### Example 4-2: Calculation of Fuel-Specific F Factor

The CEMS measures SO<sub>2</sub> and O<sub>2</sub> content on a dry basis, so in lieu of using a default F factor, the facility can use fuel analysis results and Equation 4-2 to calculate an F<sub>4</sub> factor (scf/MMBtu). The F<sub>4</sub> factor is calculated at standard conditions of 20°C (68°F) and 29.92 inches of mercury.

The fuel analysis revealed the following mole fractions:

Methane	0.44	Propene	0.03
Ethane	0.04	Butane	0.17
Hydrogen	0.06	Butene	0.01
Ethene	0.01	Inerts	0.04
Propane	0.2		

Equation 4-2 is used to calculate F<sub>4</sub> as follows:

$$F_4 = K \times [(X_{CH_4} \times MEV_{CH_4}) + (X_{C_2H_6} \times MEV_{C_2H_6}) + (X_{C_3H_8} \times MEV_{C_3H_8}) + (X_{C_4H_{10}} \times MEV_{C_4H_{10}}) + (X_{C_2H_4} \times MEV_{C_2H_4}) + (X_{C_3H_6} \times MEV_{C_3H_6}) + (X_{C_4H_8} \times MEV_{C_4H_8}) + (X_{H_2} \times MEV_{H_2}) + (X_{C_2H_2} \times MEV_{C_2H_2}) + (X_{C_3H_4} \times MEV_{C_3H_4}) + (X_{C_4H_6} \times MEV_{C_4H_6}) + (X_{C_2H_6} \times MHC_{C_2H_6}) + (X_{C_3H_8} \times MHC_{C_3H_8}) + (X_{C_4H_{10}} \times MHC_{C_4H_{10}}) + (X_{C_2H_4} \times MHC_{C_2H_4}) + (X_{C_3H_6} \times MHC_{C_3H_6}) + (X_{C_4H_8} \times MHC_{C_4H_8}) + (X_{inerts} \times MHC_{inerts})]$$

$$F_4 = 10^6 \times [(0.44 \times 7.28) + (0.04 \times 12.94) + (0.06 \times 1.61) + (0.01 \times 11.34) + (0.2 \times 18.61) + (0.03 \times 17.01) + (0.17 \times 24.28) + (0.01 \times 22.67) + (0.04 \times 8.55)] \div [(0.44 \times 842) + (0.04 \times 1475) + (0.06 \times 269) + (0.01 \times 1335) + (0.2 \times 2100) + (0.03 \times 1947) + (0.17 \times 2717) + (0.01 \times 2558) + (0.04 \times 0)]$$

$$= 10^6 \times 12.55 = 1425$$

$$= 8,809 \text{ dscf/MMBtu}$$

10 - 59

### Example 4-3: Calculation of Exhaust Flow Rate from F Factor

From Example 4-2, the F factor is 8,809 dscf/MMBtu. The measured SO<sub>2</sub> concentration is 20 ppm (dry basis), the measured O<sub>2</sub> concentration is 6% (dry basis), the higher heating value is 1,300 Btu/scf, and the fuel flow rate is 300 dscfm. Equation 4-3 should be used to calculate the exhaust flow rate from F factor as follows:

$$Q_e = F_4 \times Q_f \times HHV \times \frac{20.9}{(20.9 - \%O_{2,dry})}$$

$$Q_e = (8,809) \times (500) \times (1,300 \times 10^6 \text{ Btu/MMBtu}) \times \frac{20.9}{(20.9 - 6)}$$

$$Q_e = 8,031 \text{ dscfm}$$

Use this value of Q<sub>e</sub> in Equation 4-1 without the temperature, pressure, and moisture correction terms to estimate hourly emissions as follows:

$$E_{SO_2} = (Q_e) \times \left[ \frac{(C_s)}{100\%} \right] \times \frac{MW}{MVC} \times M_N \times K$$

$$E_{SO_2} = 8,031 \times 1 \times (20 - 1,000,000) \times 64.06 \times 849.5 \times 6 \times 2.2046 = 1.6 \text{ lb/hr}$$

### Example 4-4: Calculation of Emissions Factor from F Factor

Given the same measurements as Example 4-3, calculate hourly SO<sub>2</sub> emissions.

First, the following equation should be used to convert the concentration to the correct units (from Table 19-1 of EPA Method 19, multiply the SO<sub>2</sub> concentration in ppm by 1.660 × 10<sup>-3</sup> to convert to lb/scf [see also Equation 4-7 of this section]):

$$C_s = 20 \text{ ppm} \times (1.660 \times 10^{-3}) \text{ lb/scf/ppm}$$

$$C_s = 3.322 \times 10^{-2} \text{ lb/scf}$$

Second, Equation 4-4 should be used to calculate the emission factor:

$$EF_{SO_2} = C_s F_4 \frac{20.9}{(20.9 - \%O_{2,dry})}$$

$$EF_{SO_2} = (3.322 \times 10^{-2}) \times (8,809) \times \frac{20.9}{(20.9 - 6)}$$

$$EF_{SO_2} = 0.041 \text{ lb/MMBtu}$$

Finally, Equation 4-5 should be used to calculate the hourly emissions (the fuel flow rate is 300 dscfm, or 30,000 dscf/hr [500 dscfm × 60 minutes per hour (min/hr)]):

$$E_{SO_2} = EF_{SO_2} \times Q_e \times HHV$$

$$E_{SO_2} = (0.041) \times (30,000) \times (1,300 \times 10^6 \text{ Btu/MMBtu})$$

$$E_{SO_2} = 1.6 \text{ lb/hr}$$


If the combustion source operated steadily and continuously for an entire year and the emission rate remained perfectly constant over that year, then the annual emissions would be 1.6 lb/hr × 8,760 hr/yr = 2,000 lb/ton = 7.0 tons/yr.

10 - 60

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 11: FRM 202 Condensable PM

### U.S. EPA APTI Compliance Test and Source Test Observation FRM 202 Condensable Particulate Matter (CPM)




11 - 1

### EPA's Defines Emitted Particulate Matter (PM) in 40CFR51.100

*“Particulate matter emissions mean all finely divided solid or liquid materials, other than uncombined water, emitted to the ambient air as measured by an applicable reference method, or an equivalent or alternative method, specified in the regulations, or by a test method specified in an approved State Implementation Plan (SIP).”*

11 - 2



11 - 3

### Basic Measurement Methods for Particulate Matter (PM)

- External Heated Filter: Total particulate matter as measured by FRM 5 at defined temperature
- In-stack Filtration: Total particulate matter as measured by FRM 17 at stack temperature and pressure
- In-stack Cyclone: PM<sub>10</sub>/PM<sub>2.5</sub> particulate matter using FRM 201/201A

11 - 4

### Basic Measurement Methods for condensable PM

- FRM 6: Determination of Sulfur Dioxide Emissions from Stationary Sources
- FRM 8: Determination of Sulfuric Acid Mist and Sulfur Dioxide Emissions from Stationary Sources
- FRM 202: Determination of Condensable particulate Emissions from Stationary Sources

11 - 5

### Basic Measurement Methods for condensable PM

- Method 315 - Particulate and Methylene Chloride Extractable Matter from Aluminum Production Facilities
- Other Test Method 37 (OTM-37): Measurement of Direct PM<sub>2.5</sub> and PM<sub>10</sub> Emissions at Low Concentrations by Dilution Sampling (Constant Sampling Rate Procedure)

11 - 6

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 11: FRM 202 Condensable PM

### Regulatory Background CPM

- FRM 8 (1971): New source measurement method for SO<sub>3</sub>/H<sub>2</sub>SO<sub>4</sub> emissions
- PM<sub>10</sub> NAAQS (1987): EPA acknowledges the effect of PM<sub>10</sub> on human health
- FRM 201/201A (1990): New source measurement methods for PM<sub>10</sub> for quantifying emissions

11 - 7

### Regulatory Background CPM

- FRM 202 (1991): EPA acknowledges that some emissions in the vapor phase at stack conditions are converted to the condensed phase (as a liquid or solid) immediately upon discharge into the ambient air and those compounds are not captured on a particulate filter during stack testing

11 - 8

### Regulatory Background CPM

- PM<sub>2.5</sub> NAAQS (1997): EPA acknowledges that effect of fine particulate matter (i.e., PM<sub>2.5</sub>) on human health
- Conditional Test Method 039 (2004): Measurement of PM<sub>2.5</sub> and PM<sub>10</sub> Emissions by Dilution Sampling (Constant Sampling Rate Procedures)

11 - 9

### Regulatory Background CPM

- Conditional Test Method 040 (2004): EPA proposes test method for combined PM<sub>10</sub> and PM<sub>2.5</sub>, now incorporated into Method 201/201A
- Other Test Method 37 (May 2018): Measurement of Direct PM<sub>2.5</sub> and PM<sub>10</sub> Emissions at Low Concentrations by Dilution Sampling (Constant Sampling Rate Procedure)

11 - 10

### Condensable Particulate Matter

- Condensable particulate matter (CPM) consists of species that are emitted from a source in the vapor phase at stack gas temperature but condenses into a liquid or solid aerosol at ambient temperature

11 - 11

### Historical Measurement Methods for CPM

- Condensable Particulate Matter by FRM 202: Particulate matter captured in the back half of the FRM 5 sampling train, including water and organic soluble extraction components
- Total Particulate: The sum of the filterable particulate (i.e., front half of the FRM 5 sampling train) and the condensable particulate matter (i.e., the back half of the FRM 5 sampling train, including water and organic soluble extractions)

11 - 12

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 11: FRM 202 Condensable PM**

**Recent History**

- Pre - PM<sub>10</sub> & PM<sub>2.5</sub> NAAQS
  - Recognized condensable PM impact
    - Dust PM was cause of most non-attainment areas for TSP
    - Condensable PM was a small consideration
  - Condensable PM method proposed 1990
    - Was a “Consensus Method” addressing several State specific compliance test methods
    - Incorporates several analytical options

11 - 13

**Why A Condensable Test Method?**

- New NAAQS for particulate matter (PM<sub>2.5</sub>)
- New emission inventories required
- More comprehensive emission factors required

11 - 14

**Why A Condensable Test Method?**

- More comprehensive test methods are now required to address non-attainment questions
- Expanded use of dispersion models
- Expanded use of receptor models

11 - 15

**Components of Direct PM<sub>2.5</sub>**

- Filterable PM<sub>2.5</sub>
  - Solid or liquid material at stack temperature and higher (measured at ~250° to 320° F)
  - Stable in atmosphere and collected on ambient sampler
- Condensable PM<sub>2.5</sub>
  - Vapor or gas at stack temperature
  - Condenses to liquid or solid at stack exit
  - Stable in atmosphere and collected on ambient sampler

11 - 16

**Precursors to Condensable PM**

Ammonia	Nitrates
HCl	Organics
HF	Chlorides
Sulfates	

11 - 17

**List of Precursors Reactions to Condensable PM**

- |                                     |   |
|-------------------------------------|---|
| • Condensable Organics              | • $H_xC_y(g) = H_xC_y(a)$                       |
| • SO <sub>3</sub>                   | • $SO_3(g) + H_2O(g) = H_2SO_4(a)$              |
| • SO <sub>3</sub> w/NH <sub>3</sub> | • $SO_3(g) + H_2O(g) + 2NH_3 = (NH_4)_2SO_4(s)$ |

11 - 18

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 11: FRM 202 Condensable PM

### List of Potential Precursors Reactions to Form Condensable PM

- HCl
- HF
- Trace Metals
- Nitrates
- $\text{HCl(g)} + \text{H}_2\text{O(g)} = \text{HCl(l)}$
- $\text{HF(g)} + \text{H}_2\text{O(g)} = \text{HF(l)}$
- $\text{M(g)} = \text{M(l)} \text{ or } \text{M(s)}$
- $\text{NO}_3\text{(g)} + \text{H}_2\text{O(g)} = \text{HNO}_3\text{(l)}$

11 - 19

### FRM 202 for Measurement of CPM

- Needed to measure CPM instead of solid PM
- Allows the determination of both filterable and Condensable PM simultaneously

11 - 20

### Condensable Test Method

- Allow for speciation of collected particulate
  - Elements Al through Pb
  - Major Ions (Sulfates, Nitrates, Ammonium, Sodium, Potassium etc.)
  - Total Mass, Carbon (Elemental and Organic)
  - Others (Semi-volatiles, Dioxins/Furans, PCBs, Volatiles etc.)

11 - 21

### Reasons to Consider Condensable PM<sub>2.5</sub> Emissions

- Condensable fraction of direct PM<sub>2.5</sub> can be significant
  - 10 to 50 percent of PM<sub>2.5</sub> emissions depending on control measures, temperature, other source-specific conditions

11 - 22

### Reasons to Consider Condensable PM<sub>2.5</sub> Emissions

- Combustion, metallurgical & wood product sources emit large quantities of vapors that condense to form PM<sub>2.5</sub>
  - Acids (e.g., sulfuric acid from coal combustion)
  - Neutralized acids (e.g.,  $[\text{NH}_4]_2[\text{SO}_4]$ ,  $\text{NH}_4\text{Cl}$ )
  - Organic materials (e.g., alkanes, PAHs, PCBs, PCDDs, acids)
  - Metals (e.g., As, Se, Sb, Pb Compounds)

11 - 23

### Reasons to Consider Condensable PM<sub>2.5</sub> Emissions

- A small fraction of point sources are responsible for the majority of condensable PM emissions

11 - 24



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 11: FRM 202 Condensable PM

### Inventories and PM<sub>2.5</sub> Emissions

- Filterable PM
  - Historically only PM included in databases
  - Some States include filterable PM<sub>10</sub> or PM<sub>2.5</sub>
- Condensable PM
  - Current knowledge is spotty
  - Some SIP databases fail to include PM<sub>cond</sub> (even when required)
  - When PM<sub>cond</sub> included - calculated from emissions factors (e.g., AP-42) that are often based on incorrect test methods

11 - 25

### Inventories and PM<sub>2.5</sub> Emissions

- Inventories reflect database errors
  - Federal inventory includes some adjustments
  - Underestimate some sources' contributions, overestimate others

11 - 26

### Issues to Consider for CPM

- Most current regulations do not address PM<sub>cond</sub> Effect on SIP Regulations
  - Focus on filterable PM
  - Force control technology towards filterable PM
- Some regulations do include PM<sub>cond</sub>, but with incorrect test methods

11 - 27

### Issues to Consider for CPM

- Final rule creates a transition period
  - Regulations addressing PM<sub>cond</sub> encouraged but not required
  - Develop more precise and accurate PM<sub>cond</sub> emissions for inventories and rules


11 - 28

### CPM in Relation to Air Quality Issues

- Potential impacts on PSD review applicability for PM<sub>10</sub> and PM<sub>2.5</sub> (Threshold levels: Rural vs. urban)
- Potential impacts on dispersion modeling analysis
  - Current NAAQS and PSD increments (Class I areas)
  - Monitoring *de minimis* levels
- Visibility impairment (VISCREEN vs. MESOPUFF-II models)
- Human health issues

11 - 29

Size Distribution and Sources of Atmospheric Particles.



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 11: FRM 202 Condensable PM

### Biases from Condensable PM

#### Positive

- Some condensable PM that are not intended to be regulated condense below stack temperature and are collected on heated filter

11 - 31

### Biases from Condensable PM

#### Negative

- Some condensable PM that are to be regulated do not condense at filter temperature and pass through the filter and are not counted

11 - 32

### Steps to Handle Condensable PM

- Determine if condensable PM are to be regulated by applicable emission regulations
- Design proper sampling and analytical procedures to match intention of the regulation

11 - 33

### Cautions on Condensable Sampling Techniques

- EPA Reference Method 5 sample box temperature may not be an accurate indication of sample gas temperature
- Condensed particulate matter may change its chemical composition after condensation

11 - 34

### Cautions on Condensable Sampling Techniques

- Although temperature is major parameter for collection of condensable PM, several other factors can greatly affect condensable PM (i.e., moisture content, dilution air, presence of other compounds)

11 - 35




Figure 1. Schematic of Condensable Particulate Sampling Train

11 - 36

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 11: FRM 202 Condensable PM**

---

**EPA FRM 202**

- Used with filterable PM method
- Requires post sample conditioning in field
- Uses existing methodology and equipment
- Is used by several State agencies

11 - 37

**FRM 202**  
**CPM Sampling Program**

- Impinger portion of a FRM 17 type sampling train
- Nitrogen purge to remove dissolved SO<sub>2</sub>

11 - 38

**FRM 202**  
**CPM Sampling Program**

- 8.5.4.2 CPM Container #1, Aqueous liquid impinger contents. Quantitatively transfer liquid from the dropout and the backup impingers prior to the CPM filter into a clean, leak-proof container. Rinse all sampling train components twice with water.

11 - 39

**FRM 202**  
**CPM Sampling Program**

- 8.5.4.3 CPM Container #2, Organic rinses. Follow the water rinses of the back half with an acetone rinse. " Then repeat the entire rinse procedure with two rinses of hexane and save the hexane rinses in the same container as the acetone rinse.

11 - 40

**FRM 202**  
**CPM Sampling Program**

- 8.5.4.4 CPM Container #3, CPM filter sample. Use tweezers and/or clean disposable surgical gloves to remove the filter from the CPM filter holder. Place the filter in the Petri dish labeled with test identification and "CPM Container #3, Filter Sample."

11 - 41

**FRM 202**  
**CPM Sampling Program**

- 8.5.4.5 CPM Container #4, Cold impinger water. You must weigh or measure the volume of the contents of CPM Container #4 either in the field or during sample analysis (see Section 11.2.4). If the water from the cold impinger has been weighed in the field, it can be discarded.

11 - 42

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 11: FRM 202 Condensable PM

### EPA FRM 202

- Requires post sample separation in field
- Requires post sample adjustments in lab
- Limited speciation


11 - 43

### FRM 202

- FRM 202 is subject to false positive bias because of conversion of non-particulate species into CPM in the method's sampling train


11 - 44

### FRM 202 Sampling Train



11 - 45

### FRM 202 Post Nitrogen Purge



11 - 46

### FRM 202 Biases

- Normally non-condensable gases may react with other gases or condensables to form condensable PM
- Oxidation of dissolved  $\text{SO}_2$  in the impinger water to form  $\text{H}_2\text{SO}_4$
- Stabilization of  $\text{H}_2\text{SO}_4$  with  $\text{NH}_4\text{OH}$  when pH of the impinger solution is  $> 4.5$

11 - 47

### FRM 202 Biases

- Use of water impingers to concentrate condensibles has bias given the potential to affect chemical reaction rate. Chemical reaction rates generally increase with concentration

11 - 48

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 11: FRM 202 Condensable PM

### % Condensable Particulate Matter (FRM 202)

Source Category	% of Total Catch in Back Half
Fossil fuel fired gen.	50
Incinerator	20-30
Asphalt Plant	40-85
Smelters	35-85

11 - 49

### Results of FRM 202 For Condensable PM

- Coal-burning Boilers: condensable PM were ~76 % of the total PM<sub>10</sub> stack emissions
- Oil/Natural Gas/Kerosene Combustion Turbines: condensable PM were ~ 68 % of the total PM<sub>10</sub> stack emissions
- Oil/Natural Gas Boilers: condensable PM were ~ 49 % of the total PM<sub>10</sub> stack emissions

11 - 50

### FRM 202 Testing Conclusion

- Condensable particulate matter (CPM) is composed mostly of inorganic matter, independent of source type (boiler or turbine) or fuel burned (coal, oil or natural gas)
- Inorganic matter is composed of mostly sulfate associated compounds

11 - 51

### FRM 202 Testing Conclusion

- Close relationship between ambient sulfate concentrations and fine PM (i.e., PM)
- Based on review of FRM 202 stack tests, the condensable PM emissions can make a significant contribution PM constitutes a portion of the total PM<sub>10</sub> emissions from Fossil Fuel-Fired Steam Generators (FFSGs)

11 - 52

### Special Considerations When Using Method 202

- May not be applicable at sources that emit high levels of ammonia
- If SO<sub>2</sub> is present, the sample must be purged with N<sub>2</sub>, but recent studies indicate that not all the SO<sub>2</sub> is purged from the impingers

11 - 53

### EPA Activities to Resolve PM<sub>cond</sub> Test Methods Issues

- Recommending use of Method 202 with purge and use of condensable PM<sub>2.5</sub>  
(USEPA EMC Website for RM 202)  
<https://www.epa.gov/sites/production/files/2016-06/documents/m-202.pdf>
- Assessing “improvements” to Method 202
  - Apply technologies tested in Canada and US
  - Reduce artifacts from ~10 mg to >2 mg

11 - 54



**EPA Activities to Resolve  
PM<sub>cond</sub> Test Methods Issues**

- Revise M202 in Appendix M
  - More precise (no options)
  - More accurate (reduce artifacts)
  - Post on EPA/EMC web site in July 2007
  - Propose in 2007/2008
  - Promulgate 2008/2009

11 - 55

**EPA Updated Method 202**


- Recommending use of Method 201A (existing filterable PM<sub>10</sub> test method) with supplemental hardware for filterable PM<sub>2.5</sub> added to updated 202
- Revise Method 202 in Appendix M
  - Add filterable PM<sub>2.5</sub> measurement
  - Add condenser followed by dry impingers
    - First two impingers in water
    - Second two impingers in ice water
  - Promulgate 2008/2009

11 - 56

### U.S. EPA APTI

#### Compliance Test and Source Test Observation

*FRM 29/SW-846, Method 0060, Multi-Metals Sampling, FRM 12 for Inorganic Lead and FRM 306 for Chromium*



12 - 1



12 - 2

### Applicability

- This method is used to determine the concentration of metals in stack emissions from hazardous waste incinerators and similar combustion processes
- May also determine particulate matter concentration concurrently utilizing FRM 5

12 - 3

### Metals Detected

- The following 17 metals can be detected by FRM 29/Method 0060:
  - Antimony (Sb)
  - Arsenic (As)
  - Barium (Ba)
  - Beryllium (Be)
  - Cadmium (Cd)
  - Total Chromium (Cr)
  - Cobalt (Co)
  - Copper (Cu)
  - Lead (Pb)
  - Manganese (Mn)

12 - 4

### Metals Detected

- Mercury (Hg)
- Nickel (Ni)
- Phosphorus (P)
- Selenium (Se)
- Silver (Ag)
- Thallium (Th)
- Zinc (Zn)

12 - 5

### Interferences

- Stainless steel and other metals associated with the sampling train and recovery components will interfere with the quantitation of metals
- Can't use metal components

12 - 6

### Interferences

- Spectral interferences can be minimized through the proper selection of analytical methodology
- “Dated” reagents may provide high metal background concentration, thus, high bias

12 - 7

### FRM 29/Method 0060 Design Requirements

- Gas flow measurement system (FRM 2-4)
- Modified Method 5 sampling train
- Addition of three more impingers


12 - 8

### FRM 29/Method 0060 Sampling Train


- Probe with quartz nozzle and liner
- Pitot tube/temperature sensor array
- Heated filter assembly
- Seven impingers
- Pump/dry gas meter/orifice assembly

12 - 9

### FRM 29/Method 0060 Sampling Train



### FRM 29/Method 0060 Sampling Train



12 - 11

### FRM 29/Method 0060 Operational Requirements

- See Field Observation Checklist
- Multi-point integrated sampling
- Isokinetic sampling rate
- 2-hr sample with minimum sample volume of 45 cf

12 - 12

**FRM 29/Method 0060  
Operational Requirements**

- Probe/filter at 120°C (248°F)
- PM metals (and FRM5 PM) collected in front half, gaseous metals collected in back half

12 -13

**FRM 29/Method 0060  
Operational Requirements**

- Recovery of front half and back half separate
- Samples are acid digested to dissolve inorganics and remove organic constituents
- If stack gas moisture < 100 mL, then can eliminate first impinger

12 - 14

**FRM 29/Method 0060  
Impinger Arrangement**

- 1st Impinger- empty (Optional)
- 2nd & 3rd Impinger- 5% HNO<sub>3</sub>/10% H<sub>2</sub>O<sub>2</sub> (vapor multi-metals)
- 4th Impinger- empty

12 - 15

**FRM 29/Method 0060  
Impinger Arrangement**

- 5th & 6th Impinger- 4% KMnO<sub>3</sub>/10% H<sub>2</sub>SO<sub>4</sub> (For mercury vapor)
- 7th Impinger- Silica gel

12 - 16

**FRM 29/Method 0060  
Glassware Preparation**

- Hot tap water rinse
- Wash with hot soapy water
- Rinse 3 times with tap water, then 3 times with cleaned, DI water
- Soak in 10% HNO<sub>3</sub> for 4 hours

12 - 17

**FRM 29/Method 0060  
Glassware Preparation**

- Rinse 3 times with cleaned, DI water
- Rinse with acetone and air dry
- All openings covered with paraffin until used

12 - 18

**FRM 29/Method 0060  
Sample Train Requirements**

- Glass or Teflon<sup>®</sup> nozzle
- Nonmetallic probe line
- Nonmetallic brushes

12 - 19

**FRM 29/Method 0060  
Sample Train Requirements**

- Daily preparation of  $\text{KMnO}_4$  solution
- Polypropylene tweezers
- Storage bottles of glass with Teflon lined caps

12 - 20

**FRM 29/Method 0060 Operation**

- Preliminary field determination (sample location, nozzle size, probe length) same as FRM 5
- Sample train preparation (charging of impingers etc.) same as FRM 5

12 - 21

**FRM 29/Method 0060 Operation**

- Prevent  $\text{KMnO}_4$  from contacting other glassware and prevent  $\text{H}_2\text{O}_2$  from mixing with  $\text{KMnO}_4$
- Leak check in accordance with FRM 5
- Sample collection in general accordance with FRM 5

12 - 22

**FRM 29/Method 0060 Operation**

- No metal components in the sample train and during sample recovery

12 - 23

**FRM 29/Method 0060 Sample Train  
Recovery Containers**

- 1- Petri Dish (Filter)
- 2- Acetone rinse from probe nozzle/liner, and front half of filter holder (exactly 100 mL)
- 3-  $\text{HNO}_3$  rinse of probe nozzle/liner, and front half of filter holder (exactly 100 mL)

12 - 24



**Sample Train  
Recovery Containers**

4- Combined impingers 1, 2 and 3 (measured) and HNO<sub>3</sub> acid rinse of impingers and back half of filter holder (exactly 100 mL)

12 - 25

**Sample Train  
Recovery Containers**

5A- Impinger 4 (measured) and HNO<sub>3</sub> rinse of impinger 4 (100 mL)  
5B- KMnO<sub>4</sub> impingers contents (measured) and KMnO<sub>4</sub> (100 mL) + water (100 mL)

12 - 26

**Sample Train  
Recovery Containers**

5C- 8 M HCl (25 mL) rinse of the two impingers and transferred to container containing water (200 mL)

12 - 27

**Sample Train  
Recovery Containers**

6- Silica gel contents (note color, weigh)  
7- Acetone blank (100 mL)  
8A- HNO<sub>3</sub> reagent blank (300 mL)  
8B- Water reagent blank (100 mL)

12 - 28

**Sample Train  
Recovery Containers**

9- 5 % HNO<sub>3</sub>/10% H<sub>2</sub>O<sub>2</sub> reagent blank (200 mL)  
10- KMnO<sub>4</sub> reagent blank (100 mL)  
11- 8 M HCl reagent blank (200 mL of water + 25 mL of 8 M HCl)  
12- Filter blank

12 - 29

**Analysis**

- Weigh filter if need FRM 5 PM
- Acid digestion of filter and sample train recovery reagents
- Analysis by Inductively Coupled Argon Plasma (ICAP) for all metals (except mercury)
- Aliquots taken of recovery reagents for mercury analyzed by Cold Vapor Atomic Absorption Spectroscopy (CVAAS)

12 - 30

### Calculation

- $M(i) = (C)(F)(V)$   
where:
  - C = concentration of metal from calibration curve, ug/mL
  - F = dilution factor
  - V = total volume of digested sample

12 - 31

### Calculation

- Total metal concentration in sample train:  
 $M(f) = [M(ifah)-M(fhb)] + [M(ibh)-M(bhb)]$
- where:
  - M(f) = total mass of each metal in complete sample train
  - M(ifah) = total mass of each metal in front half (fh) of sample train

12 - 32

### Calculation

$$M(f) = [M(ifah)-M(fhb)] + [M(ibh)-M(bhb)]$$

- M(fhb) = total metal found in front half blank
- M(ibh) = total metal found in back half of sampling train
- M(bhb) = total metal found in back half blank

12 - 33

### Calculation

- Stack gas concentration is calculated:
  - $C(\mu\text{g}/\text{m}^3) = M(\mu\text{g})/(\text{Std. volume of gas sampled, m}^3)$

12 - 34

### FRM 29/Method 0060 Key Points

- All active sample train components must be made of glass or Teflon® (no metal components)
- All active sample train components must be cleaned through a detailed clean-up scheme

12 - 35

### FRM 29/Method 0060 Key Points

- FRM 5 PM can also be determined concurrent with Method 0060
  - Front half of train: particulate metals
  - Back half of train: gaseous metals
- If not sampling for mercury, do not need impingers 4, 5 & 6 in the sample train

12 - 36

**FRM 29/Method 0060**

**Key Points**

- Storage containers must be made of glass with Teflon<sup>®</sup>-lined caps
- Front half of train captures particulate metals while back half captures gaseous metals
- Imperative to use exactly 100 mL of rinsing solutions for blank correction in final concentration calculation

12 - 37

**FRM 29/Method 0060**

**Key Points**

- If sampling for total metals only (not FRM 5 PM), then filter does not have to be desiccated or weighed
- Do not need 1st impinger if water is determined to be < 100 mL
- Impinger reagents made daily
- Must use exact volume of rinses for background correction

12 - 38

**FRM 29/Method 0060**

**Key Points**

- Special cleaning of glassware
- Exact blank volumes/composition must be acquired for blank correction


12 - 39

**U.S. EPA APTI  
 Compliance Test and Source Test  
 Observation  
 Course #468**

**FRM 12, Inorganic Lead**

12 - 40

**FRM 12  
 Sampling Train**



12 - 41

**40CFR63, Subpart X: National  
 Emission Standards for  
 Secondary Lead Smelters**

- 06/09/94: Proposed rule
- 06/23/95: Final rule for new and existing secondary lead smelters
- 06/13/97: Direct final rule (Amendments to final rule)
- 08/18/99: Proposed amendments Title V
- 12/14/99: Final rule

12 - 42

### Test Methods Identification

- FRM 1: Port location
- FRM 2: Volumetric flow rate
- FRM 3 or 3A: Correct conc. meas.
- FRM 4: Moisture content
- FRM 12: Determination of inorganic lead

12 - 43

### FRM 12 Applicability

- This method is used to determine the concentration of particulate matter (PM) lead and gaseous lead emissions from stationary sources
- Sources comprise mostly of 23 smelters (15 major and 8 area sources) located in 13 states

12 - 44

### Summary of Method

- FRM 5 sample train with glass nozzle and probe liner
- Filter temperature maintained @ 248°F
- Particulate lead caught on filter while gaseous lead caught in impingers
- Analysis by acid digestion followed by flame atomic absorption (FAA)

12 - 45

### FRM 12 Design Requirements

- Gas flow measurement system (FRM 1-4)
- FRM 5 sampling train
- Operated isokinetically


12 - 46

### FRM 12 Sampling Train

- Probe with quartz nozzle and liner
- Pitot tube/temperature sensor array
- Heated filter assembly
- Standard FRM 5 impingers with impingers 1 and 2 containing 100 mL of 0.1 HNO<sub>3</sub>
- Pump/dry gas meter/orifice assembly

12 - 47

### FRM 12 Sampling Train



12 - 48

### Sample Recovery

- FRM 12 Recovery
  - Container #1: Recover filter for lead PM same as FRM 5
  - Container #2: Front-half 0.1 N HNO<sub>3</sub> rinse up to front-half filter compartment
  - Container #3: Note color of silica gel to determine whether it has been completely spent. Transfer the silica gel to its original container, weigh on site or transport back to laboratory for weighting

12 - 49

### Sample Recovery

- FRM 12 Recovery
  - Container #4: Measure and collect the impinger nitric acid solutions from first three impingers; Rinse twice with 30 mL 0.1 N HNO<sub>3</sub> each impinger and collect in container #4
  - Container #5: Reagent blank of 200 mL of 0.1 N HNO<sub>3</sub>

12 - 50

### Sample Analysis

- Container #1: Filter cut into strips and digested with 10 mL of 50% of HNO<sub>3</sub>, heat on hot plate, add 10 mL of 3 % H<sub>2</sub>O<sub>2</sub> and 50 mL of DI water, heat for 20 minutes. Filter and dilute to 100 mL. Also must determine filter blank (FB) with 2 unexposed filters from same lot following same procedure

12 - 51

### Sample Analysis

- Containers #2 and #4: Transfer to Erlenmeyer flask, heat on hot plate to dryness, add 30 mL of 3 % H<sub>2</sub>O<sub>2</sub> and 50 mL of hot DI water, heat for 20 minutes. Filter and dilute to 250 mL

12 - 52

### Sample Analysis

- Container #3: Weigh silica gel to nearest 0.5 grams (B<sub>ws</sub>)
- Container #5: Dry the 200 mL on a steam bath to dryness, add 15 mL of 50 % H<sub>2</sub>O<sub>2</sub> and 50 mL of hot DI water, dilute to a total volume of 100 mL

12 - 53

### Sample Analysis

- Flame Atomic Absorption (FAA)
  - Calibration of FAA using standard solutions
  - Check matrix effects by using the method of additions
    - Spiked sample vs. unspiked sample
  - Stability of calibration curve
    - Run a blank and standard after every 5<sup>th</sup> sample

12 - 54

**FRM 12**

**Operational Requirements**

- See Field Observation Checklist for FRM 5
- Multi-point integrated sampling
- Isokinetic sampling rate
- 1-hr sample with minimum sample volume of 45 cf

12 - 55

**FRM 12**

**Operational Requirements**

- Probe/filter at 120°C (248°F)
- Lead PM collected on front-half of sampling train, while gaseous lead collected in impingers

12 - 56

**FRM 12**

**Impinger Arrangement**

- 1<sup>st</sup> and 2<sup>nd</sup> Impinger- 100 mL 0.1 N HNO<sub>3</sub>
- 3<sup>rd</sup> Impinger- Dry
- 4<sup>th</sup> Impinger- 200-300 g silica gel

12 - 57

**FRM 12 Operation**

- See Field Observation Checklist for FRM 5
- Preliminary field determination (sample location, nozzle size, probe length) same as FRM 5
- Sample train preparation (charging of impingers etc.) same as FRM 5

12 - 58

**FRM 12 Operation**

- Pre-/post leak check in accordance with FRM 5
- Sample collection in general accordance with FRM 5
- Sample recovery in general agreement with FRM 5 except rinsing with 0.1 N HNO<sub>3</sub>

12 - 59

**FRM 12 Key Points**

- All active sample train components must be made of glass (no mention of Teflon components)
- All active sample train components must be cleaned

12 - 60



### FRM 12 Key Points

- FRM 5 PM can be determined concurrent with FRM 12
  - Front half of train: particulate matter (PM) with acetone rinse
  - Impinger solution: 0.1 N HNO<sub>3</sub>
  - Use of glass fiber filter with low background lead concentration
  - Treat and analyzes the entire sample train contents, including the impingers, for lead

12 - 61

### FRM 12 Key Points

- FRM 17 may be used provided that:
  - Use of glass-lined probe and at least 2 impingers each containing 100 mL of 0.1 N HNO<sub>3</sub> after the in-stack filter
  - Recovery of probe and impinger contents for lead. Recovery of sample from the nozzle with acetone if a PM determination is to be made

12 - 62

### U.S. EPA APTI Compliance Test and Source Test Observation

Federal Reference Method 306:  
Sampling and Analysis for Chromium  
Emissions from Decorative and Hard  
Chromium Electroplating/Anodizing  
Operations

12 - 63

### Principle

- Gaseous and particulate chromium pollutants are withdrawn isokinetically from the source and collected in a unheated FRM 5 sample train without filter
- Gaseous and particulate chromium pollutants are collected in the impingers containing 0.1 N NaOH or 0.1 N NaHCO<sub>3</sub>

12 - 64

### FRM 306 Summary


- Chromium extracted isokinetically from the source
- FRM 5 sampling train except:
  - Unheated quartz probe/nozzle; No SS
  - No heated filter box
  - Replacement of water in impingers with 0.1 N NaOH or 0.1 N NaHCO<sub>3</sub>
  - Don't have to brush probe for recovery

12 - 65

### FRM 316 Summary

- 2-hour sample run
- Options for analysis
  - Total chromium: Collect all impinger
  - Cr<sup>+6</sup>: Evaluate pH of first impinger; Should be > 8.5 pH
- Audit sample required

12 - 66



**Discussion**

- Sampling Train: Tradition FRM 5 Without Heating; No Filter or Filter Component; All Quartz Components
- Sampling: Isokinetic, FRMs 1-4, Sample Time > 2 Hrs
- Analytical Finish: Inductively Coupled Plasma Emission Spectrometry (ICP); Cr<sup>+6</sup> by Ion Chromatography (IC)

12 - 68

**Discussion**

- Cr<sup>+6</sup> Emissions?
  - If Cr<sup>+6</sup> emissions, then at end of sampling run, 1<sup>st</sup> impinger must have pH of >8.5 or must discard sample run (No requirement for total chromium)
  - Must store samples at 4 °C until analysis (Total chromium can store samples at room temperature)
  - Samples must be analyzed within 14 days (60 days for total chromium)
  - Analysis by ion chromatography equipped with post-column reactor (IC/PCR)

12 - 69

**Discussion**

- Total Chromium (TC) Emissions?
  - High Concentrations: Inductively coupled plasma emission spectrometer (ICP) @ 267.72 nm
  - Low concentrations: Digestion with HNO<sub>3</sub>, then graphite furnace atomic absorption spectroscopy (GFAAS) @ 357.9 nm

12 - 70

**Discussion**

- Interferences: Stack and ICP Interferences
  - High SO<sub>2</sub> Concentrations reduces 0.1 N NaOH concentration in impingers
  - Spectral: Overlapping of spectral lines (Fe, Mn, U)
  - Physical: Dissolved solids in sample
  - ICAP background interferences
- Concentration: No Blank Correction

12 - 71

**Discussion**

- GFAA Interferences
  - Spectral: CN<sup>-</sup>
  - Chemical: Ca and PO<sub>4</sub><sup>-</sup>
- IC/PCR
  - Compounds which cause Cr<sup>+6</sup> to Cr<sup>+3</sup> etc.
  - Coeluting compounds

12 - 72

### Sampling

- Must traverse the stack to each sampling point determined by FRM 1 (may need probe extension)
- Sample a minimum of 2 minutes per point and required minimum sample time of > 2 hrs
- Must follow all FRM 5 QC requirement (i.e., leak checks, nozzle selection, isokinetic sampling maintained etc.)

12 - 73

### Sampling

- Assemble sampling train, but keep all openings covered with Teflon or aluminum foil (0.1 N NaOH in impingers)
- Clean portholes prior to test run
- If stack is under negative pressure, one may start pump prior to putting filter into stack at 1<sup>st</sup> sampling point
- Block off opening around the probe to prevent in-leakage

12 - 74

### Sampling

- Add ice to condenser impinger to maintain exit temperature < 68 °F
- Sample isokinetically and make adjustments if variable change by 10 %
- At end of run, wipe off particulate matter on outside of probe nozzle and perform final leak check

12 - 75

### Recovery

- Recover impinger solutions and measure for moisture determination and place in labeled container along with completed COC
  - Option #1: Total Cr Sample Option
  - Option #2: Cr<sup>+6</sup> Sample Option

12 - 76

### Recovery

- Option #1: Total Cr Sample Option
  - Measure volume of liquid in first, second, and third impingers
  - Rinse nozzle, probe liner, connecting glassware and all three impingers with ~ 200-300 mL of 0.1 N NaOH
  - Do not have to refrigerate
  - Must be analyzed within 60 days
  - Retain the silica gel for follow-up weighting for moisture determination

12 - 77

### Recovery

- Option #2: Cr<sup>+6</sup> Sample Option
  - Measure volume of liquid in first, second, and third impingers
  - Measure pH with indicator strip of 1<sup>st</sup> impinger. Must be > 8.5 for 0.1 N NaOH or > 8.0 for NaHCO<sub>3</sub>. If not, discard and redo test

12 - 78

### Recovery

- Option #2: Cr<sup>+6</sup> Sample Option
  - Rinse nozzle, probe liner, connecting glassware and all three impingers with ~ 200-300 mL of 0.1 N NaOH
  - Refrigerate @ 4 °C until analysis
  - Must be analyzed within 14 days
  - Retain the silica gel for follow-up weighting for moisture determination

12 - 79

### Recovery

- Prepare a field reagent blank for analysis (i.e., 0.1 N NaOH) into a second bottle
- Seal all bottles and store properly until analysis
- Complete chain-of-custody (COC)

12 - 80

### In-stack Detection Limits (ISDL)

- 1.4 µg Cr/dscm for ICAP
- 0.15 µg Cr/dscm for GFAAS
- 0.015 µg Cr<sup>+6</sup>/dscm for IC/PCR with preconcentration

12 - 81

### ISDL

- The specified standard for Cr+6 is 0.03 mg/dscm. The ISDL is predetermined to be one tenth of the standard, 0.003 mg/DSCM (3.0E-6 mg/L). The sample will be prepared in a 250 ml (0.25 L) flask and the ion chromatograph used in the sample analysis has a detection limit of 40 ng/ml (0.04 mg/L). What sample volume is required to obtain an ISDL of 0.003 mg/L?

12 - 82

### ISDL (cont.)

$$\text{Required Sample Volume} = \frac{0.04 \frac{\text{mg}}{\text{L}} \times 0.250 \text{L}}{3.0 \times 10^{-6} \frac{\text{mg}}{\text{L}}} = 3333.3 \text{ L} = 3.33 \text{ dscm}$$

In order for the specified ISDL to be obtained, at least 3.33 dscm of stack gas must be collected in the sampling train

12 - 83

AU-144: Determination of Hexavalent Chromium in Drinking Water Using Ion Chromatography (thermofisher.com)

**U.S. EPA APTI  
Compliance Test and Source Test  
Observation**

*FRMs 26/26A and SW-846,  
Methods 0050/0051  
Determination of HCl and Cl<sub>2</sub>*

13 - 1

**Applicability**

- SW-846, Method 0050 and FRM 26A are both isokinetic methods which provide procedures for the determination of HCl/Cl<sub>2</sub> from hazardous waste incinerators and municipal waste combustors, especially suited for those sources with wet scrubbers emitting acid particulate matter (e.g., HCl dissolved in water droplets)

13 - 2

**Applicability**

- A typical analytical detection limit for HCl is 0.2 µg/ml (sec. 13.3)
- SW-846, Method 0050 and FRM 26A is for water-droplet stack gas environments requiring isokinetic sampling. Additionally, FRM 5 can be performed concurrent with FRM 26A and SW-846, Method 0050

13 - 3

**Interferences**

- Volatile material which produces chloride ions upon dissolution during sampling
- Diatomic chlorine (Cl<sub>2</sub>) for sampling HCl (Cl<sub>2</sub> disproportionate to HCl and Hypochlorous acid (HClO) in water)

13 - 4

**FRM 26A/Method 0050  
Design Requirements**

- Gas flow measurement system (FRMs 2-4)
- Modified Method 5 sampling train
  - All glass/Teflon filter assembly
  - Can't use stainless steel
- Addition of two more impingers to the traditional FRM 5 sampling train

13 - 5

**FRM 26A/Method 0050  
Sampling Train**

- Glass lined probe and nozzle
  - Can't use stainless steel unions in probe assembly
  - If stack gas >210°C, must use one piece nozzle/probe made of quartz
- Pitot tube/temperature sensor array
- Optional glass cyclone


13 - 6

### FRM 26A/Method 0050 Sampling Train

- Heated filter assembly
  - Filter and filter gaskets must be Teflon
- Condensing impingers (glass)
- Pump/dry gas meter/orifice assembly

13 - 7

### FRM 26A/Method 0050 Sampling Train



13 - 8



13 - 9

### FRM 26A/Method 0050 Operational Requirements

- Multi-point integrated sampling
- Isokinetic sampling rate
- 2-hr sample at an anticipated rate of 0.75 cfm (0050 section 7.2.4)
- 1-hr sample at an anticipated rate of 2 l/m (FAQ #2)
- Probe/cyclone/filter between 120 and 134°C (248 and 273°F)

13 - 10

### FRM 26A/Method 0050 Operational Requirements

- Post-sampling purge: If there is any possibility that liquid has collected in the glass cyclone and/or on the filter (30 minutes) to remove trapped HCl/Cl<sub>2</sub> from filter to impingers (Method 0050) (sec. 7.5.13)

13 - 11

### FRM 26A/Method 0050 Operational Requirements


- Leak-free system
- Performance Evaluation (PE) sample required

13 - 12



### FRM 26A/Method 0050 Chemistry


- Impingers 1,2 &3 remove HCl from sample gas stream by the following equation



13 - 13

### FRM 26A/Method 0050 Chemistry

- Impingers 4 & 5 remove Cl<sub>2</sub> from the stack gas stream by the following equation



- Must keep basic to prevent Cl<sub>2</sub> losses

13 - 14

### FRM 26A/Method 0050 Impinger Arrangement

- 1st Impinger(Optional)-  
50 mL of 0.1 N H<sub>2</sub>SO<sub>4</sub>
- 2nd and 3rd Impingers-  
100 mL of 0.1 N H<sub>2</sub>SO<sub>4</sub>

13 - 15

### FRM 26A/Method 0050 Impinger Arrangement

- 4th and 5th Impingers-  
100 mL of 0.1 N NaOH
- 6th Impinger-  
200-300 g of Silica Gel

13 - 16

### FRM 26A/Method 0050 Operation

- Preliminary field determination (sample location, nozzle size, probe length) same as FRM 5
- Sample train preparation (charging of filter and impingers) same as FRM 5

13 - 17

### FRM 26A/Method 0050 Operation

- Pre-leak check (optional) in accordance with FRM 5
- Sample collection in general accordance with FRM 5  
(should be 2-hr sample run - Method 0050)

13 - 18

### FRM 26A/Method 0050 Operation

- The last impinger of the 0.1 N NaOH must be maintained strongly basic during sampling. Monitor pH of solution frequently or continuously during the run to prevent loss of Cl<sub>2</sub>.

13 - 19

### FRM 26A/Method 0050 Operation

- If solution PH drops, resolve by:
  - Use stronger base (0.5 N)
  - Add volume to impinger (~200 mL)
  - Recharge impinger during sampling
  - Halfway through run, check pH of last impinger to validate basic nature of absorbing solution

13 - 20

### FRM 26A/Method 0050 Operation

- Leak check before/after component changes during sample run
- Post-sampling Ascarite purge of system (30 minutes per Method 0050)
- Post-leak check in accordance with FRM 5
  - Leak rate must be <0.02 cfm

13 - 21

### Sample Train Recovery Containers

- 1- Petri dish (filter) – Optional; for PM
- 2- Acetone rinse from probe nozzle/liner and front half of filter holder - Optional; for PM

13 - 22

### Sample Train Recovery Containers

- 3- Combined impingers 1, 2 and 3 (measured) and water rinses
- 4- Combined impingers 4 and 5 (measured) and water rinses (add 2 mL of Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> (Sodium Thiosulfate))  
The addition of Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> keeps the hypochlorous acid from dissociating

13 - 23

### Sample Train Recovery Containers

- 5- Silica gel contents  
(note color, weigh)

13 - 24

### Analysis

- Weigh filter, Optional; FRM 5 PM
- Analysis of recovery reagents for Cl<sup>-</sup> by SW-846, Method 9057, ion chromatography

13 - 25

### FRM 26A/Method 0050 Key Points

- Sampling system uses FRM 5 sampling train, so can also quantitate PM
- Sampling is isokinetic, total sampling time should be two hours (0050 sec. 7.2.4)
- Methodology quantitates HCl from Cl<sub>2</sub> emissions

13 - 26

### FRM 26A/Method 0050 Key Points

- Complete Performance Evaluation (PE) sample prior to test
- The in-stack limit for HCl for the method is approximately 0.02 mg/dscm of stack gas. The method has a negative bias below 20 ppm HCl

13 - 27

### FRM 26A/Method 0050 Key Points

- Post-sampling purge to move HCl from the cyclone/filter to impingers for 30 minutes at average  $\Delta H$  (Method 0050)

13 - 28

### FRM 26A/Method 0050 Key Points

Must maintain a basic solution in the last impinger of NaOH at 0.1 N by

- Using stronger base
- Using more volume in impinger
- Changing impinger during run
- Checking frequently during run

13 - 29

### FRM 26A/Method 0050 Key Points

- Can't change nozzle during sampling to maintain isokinetics
- Can't use stainless steel in probe assembly
- If stack gas >210°C, then must use one piece nozzle/probe assembly
- Filter analyzed for particles, but not for Cl<sub>2</sub>/HCl

13 - 30

### FRM 26A/Method 0050 Key Differences

- Method 0050
  - allows a filter temperature of  $248 \pm 25$  °F
  - Ambient conditioning is required
  - High post leak rate – void sampling run
- FRM 26A
  - requires a filter temperature between 120 and 134°C (248 and 273°F) Ambient conditioning is optional
  - High Leak Rate – allows one to follow FRM 5, Section 12.3 (allows for correction)

13 - 31

### FRM 26/SW-846 Method 0051 Sampling and Analysis for HCl and Cl<sub>2</sub> Emissions (Constant Rate Approach)

13 - 32

### Applicability

- This method provides procedures for the determination of gaseous HCl and Cl<sub>2</sub> from hazardous waste incinerators and municipal waste incinerators

13 - 33

### Interferences

- This method is designed to collect gaseous HCl and Cl<sub>2</sub> in relatively dry, particulate-free gas streams
- Must use FRM 26A/SW-846, Method 0050 (Isokinetic) with sources controlled by wet scrubbers that emit acid particulate matter and have water droplets

13 - 34

### FRM 26/Method 0051 Design Requirements

- Modified Method 6 sampling train
- Addition of 3-way stopcock and two more impingers to Method 6 sampling train
- 3-way stopcock used to purge probe

13 - 35

### FRM 26/Method 0051 Sampling Train




- Glass lined probe and Teflon elbow inlet
  - nozzle points downstream
- Heated Teflon mat Pallflex filter and three-way stopcock valve
  - can't use glass wool as particle control due to bias effects

13 - 36

FRM 26/Method 0051  
 Sampling Train

- Midget impinger system (5 midget + 1 Mae West/drying tube)
- Pump/rotameter/dry gas meter

13 - 37



Operational Requirements

- Single point (> 1 meter from stack wall) integrated sampling
- Purging of probe for 5 minutes prior to sampling

13 - 41

Operational Requirements

- Probe/filter temperature must be maintained between 120 and 134 °C (248 and 273 °F).
- Sampling at 2 L/min for 60 minutes  
 – 120 liters total sample volume

13 - 42


### Operational Requirements

- Leak-free system
- Performance evaluation (PE) sample

13 - 43

### Two Tier Leak Check


- Stopcock, probe and filter
- Impingers and meter box assembly



13 - 44

### FRM 26/Method 0051 Chemistry


- Impinger #1 empty
- Impingers #2 & #3 remove HCl from sample gas stream by the following equation:



13 - 45

### FRM 26/Method 0051 Chemistry

- Impingers #4 & #5 remove Cl<sub>2</sub> from the stack gas stream by the following reaction:



13 - 46

### FRM 26/Method 0051 Impinger Arrangement

- 1st impinger (Optional)
  - empty
- 2nd and 3rd impingers
  - 15 mL of 0.1 N H<sub>2</sub>SO<sub>4</sub>

13 - 47

### FRM 26/Method 0051 Impinger Arrangement

- 4th and 5th Impingers
  - 15 mL of 0.1 N NaOH
- 6th Impinger/drying tube
  - 30 g silica gel

13 - 48



### FRM 26/Method 0051 Operation

#### Field Observation Checklist

- Preliminary field determination (sample location, recovery area) same as FRM 6
- Sample train preparation (charging of filter and impingers) same as FRM 6

13 - 49

### FRM 26/Method 0051 Operation

#### Two Tier Leak Check

- Pre-leak check (-10 in. Hg) stopcock, probe, and filter prior to inserting probe into stack
- Pre-leak check (-10 in. Hg) impinger and meter box assembly before testing

13 - 50

### FRM 26/Method 0051 Operation

- Purge probe/filter assembly at 2 L/min for 5 minutes
- Position probe/Teflon®-elbow pointing downstream
- Sample collection in general accordance with FRM 6
- Sample at 2 L/min for 60 minutes
  - 120 liters total sample volume

13 - 51

### FRM 26/Method 0051 Operation

- The last impinger of the 0.1 N NaOH must be maintained strongly basic during sampling
- Monitor pH of solution frequently

13 - 52

### FRM 26/Method 0051 Operation

- To resolve
  - Use stronger base (0.5 N)
  - Add volume to impinger (30 mL)
  - Recharge impinger during sampling
  - Half-way through run, check pH of last impinger to validate basic nature

13 - 53

### FRM 26/Method 0051 Operation

- Leak check before/after component changes during sample run
- Post-leak check in accordance with FRM 5

13 - 54

### Sample Train Recovery Containers

- 1- Combined impingers #1, #2 and #3 (measured) and water rinses
- 2- Combined impingers #4 and #5 (measured) and water rinses  
(add 2 mL of Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> to prevent hyperchlorous acid from dissociating)

13 - 55

### Sample Train Recovery Containers

- 3- Silica gel contents (note color; not weighted)

13 - 56

### Analysis

- Analysis of recovery reagents for Cl<sup>-</sup> by SW-846, Method 9057, Ion Chromatography (IC)

13 - 57

### FRM 26/Method 0051 Key Points

- System uses a modified FRM 6 sampling train
- Sampling is performed at 2 L/min for 60 minutes

13 - 58

### FRM 26/Method 0051 Key Points

- Methodology quantitates HCl from Cl<sub>2</sub> emissions
- Must maintain last impinger of NaOH strongly basic
  - Use stronger base (0.5 N NaOH)
  - Add more volume to impingers
  - Change out during sample run

13 - 59

### FRM 26/Method 0051 Key Points

- Two tier pre-test leak check (-10 in. Hg):
1. Stopcock, probe, and filter
  2. Impinger and meter box assembly
- Can also determine moisture of stack gas

13 - 60

**FRM 26/Method 0051**

**Key Points**

- Glass lined probe/Teflon® elbow and Teflon® filter assembly only
- Methodology limited to relatively dry, particulate-free gas streams
- Weigh filter, but can't analyze for HCl/Cl<sub>2</sub>

13 - 61

**U.S. EPA APTI  
 Compliance Test and Source Test  
 Observation**

**Defining Volatile Organic Compounds  
 (VOCs)**

14 - 1

**How Do We Define HAPs**

- CAAA of 1990, Title III now contains a list of 186 HAPs containing both organic and inorganic analytes

14 - 2

**CAAA of 1990 Number of HAPs in  
 Each Volatility Class**

Volatility Class	Number of HAPs in Class
<b>Volatile (VV/V)</b>	<b>106 (56%)</b>
<b>Semi-Volatile (SV)</b>	<b>65 (35%)</b>
<b>Non-Volatile [Particles] (NV)</b>	<b>17 (9%)</b>

188

14 - 3

**Organic Compounds**

- Organic compounds (OCs) are those compounds which have a carbon-carbon bond
- Toxic air pollutants are those pollutants known or suspected to cause cancer or other serious health effects
- Many organic compounds are toxic air pollutants

14 - 4

**Testing for VOCs Difficult**

- Some State and Federal Regulations are based upon VOC emissions, not TOC or TNMOC
- The terms TOC, VOCs, NMOCs etc. are often erroneously applied interchangeably
- There is no straightforward way to measure the VOC emissions since there is no way to separate all VOCs by vapor pressure

14 - 5

**Testing for VOCs Difficult**

- All of the reference methods for organic compounds have inherent limitations that restrict their applicability
- There is no one method that can satisfy characterization of organic emissions from an industrial source

14 - 6

### Historical Definition of VOCs

- 1970-1980's: Vapor pressure > 77 mm Hg. CAA of 1970 provided for NAAQS for HCs
- 1971: EPA's develop SIP program including definition for VOCs (~ 77 mm Hg)

14 - 7

### Historical Definition of VOCs

- Late 1980's: Photochemical reactivity (40CFR51.100) and excluding Freon's
- 1990's: Clean Air Act Amendments of 1990 definition of hazardous air pollutants (HAPs), including VOCs

14 - 8

### 40 CFR Part 51.100

- "Volatile organic compounds (VOC) means any compound of carbon, excluding carbon monoxide, carbon dioxide, carbonic acid, metallic carbides or carbonates, and ammonium carbonate, which participates in atmospheric photochemical reactions. This includes any such organic compound other than the following:
  - Methane, ethane, methylene chloride, CFCs, HCFCs, HFCs, etc.

14 - 9

### Organic Chemistry

- "... *Organic chemistry is the chemistry of the compounds of carbon.*"
- Historically, chemical compounds were divided into two groups:
  - Inorganic compounds were those obtained from minerals;
  - Organic compounds were those obtained from animal sources, that is, from materials produced by living organisms. They all contain the element carbon.

14 - 10

### Historical Definition of VOCs




- 2000's: Various state agencies define VOCs (0.1 mm Hg to 77 mm Hg) by:
  - Vapor Pressure (in mm Hg at 25°C)
  - Boiling Point Temperature (°C)

14 - 11

### General Classification of VOCs

Classification	Vapor Pressure mm Hg	Boiling Point °C
Volatiles (VV/V)	> 10 <sup>-1</sup>	200°C
Semi-volatiles (SV)	10 <sup>-1</sup> to 10 <sup>-7</sup>	200 - 500°C
Particles (NV)	< 10 <sup>-7</sup>	500°C

14 - 12



- ### Six (6) Key Factors to Consider in Test Method Selection
1. The chemical composition of the VOCs being tested
  2. The expected concentration range of the VOCs being emitted
  3. The chemical properties (i.e., vapor pressure, boiling point, solubility etc.) of the emitted VOCs
- 14 - 16

- ### Six (6) Key Factors to Consider in Test Method Selection
4. The characteristics of the effluent (i.e., temperature, moisture, %CO<sub>2</sub> etc.)
  5. The advantages and disadvantages of each of the test methods
  6. The state and federal testing requirements documented in their regulations
- 14 - 17

- ### Methods Associated with Monitoring VOCs
- FRM 18: Individual Organic Compounds by Gas Chromatography
  - FRM 25: Measurement for Total Gaseous Non-methane Organic Emissions
  - FRM 25A: Total Gaseous Organic Concentration by Flame Ionization Analyzer
- 14 - 18



### Methods Associated with Monitoring VOCs

- FRM 25B: Total Gaseous Organic Concentration by Non-Dispersive Infrared Analyzer (NDIR)

14 - 19

### Methods Associated with Monitoring VOCs

- SCAQMD Method 25.3/EPA's CTM 035: Low-level Concentration of VOCs
- SW-846, Method 0010 and 0030: Semi-volatiles and volatile organic compounds respectively
- FRM 315: Polycyclic Organic Matter (POM) by MCEM

14 - 20

### Definitions

- Volatile Organic Compounds (VOCs): Organic compounds that participate in atmospheric photochemical reactions and have vapor pressure (vp) >  $10^{-1}$  mm Hg
- An organic compound that participates in atmospheric photochemical reactions. The exempt compounds are listed in 40CFR51.100

14 - 21

### Definitions

- Semi-volatile Organic Compounds (SVOCs): Organic compounds with v.p.  $10^{-1}$  to  $10^{-7}$  mm Hg and b.p 200-500 °C
- Those organic compounds which can be quantified by SW-846, Method 0010 and analyzed by SW-846, Method 8270D

14 - 22

### Definitions

- Polycyclic Aromatic Hydrocarbons (PAHs) or Polycyclic Organic Matter (POM): Organic compounds with more than one benzene ring and which have a boiling point > 200 °C
- Methylene Chloride Extractable Matter (MCEM): Organic compounds which are extracted by  $\text{MeCl}_2$

14 - 23

### Definitions

- Total Hydrocarbons (THCs): Sum of total organic compounds containing only C and H
- Total Non-Methane Organic Compounds (TNMOCs): Sum of all VOCs and all exempt compounds excluding methane
- Total Non-Methane/Non-Ethane Organic Compounds (TNM/NEOCs): Sum of total VOCs and exempt compounds excluding methane and ethane

14 - 24

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 14: Defining Volatile Organic Compounds (VOCs)

### Definitions

- FRM 18 results can be converted to mass emission rates since this method reports concentrations in terms of the actual organic compounds. We know the molecular weight of each analyte along with volumetric flow rate to get VOC mass flow rate.
- Total Organic Compounds (TOCs): Organic compounds detected by a flame ionization analyzer (FIA)

14 - 25

### Definitions

- Hazardous Air Pollutants (HAPs):** Those compounds identified in the Clean Air Act Amendments of 1990, Title III list of 185 HAPs



14 - 26

### Applicability of Organic Sampling Methods

FRM	Conc. Range
FRM 25 B	0.5-10 %
FRM 25	50 ppm-10 %
FRM 18	1 ppm – 1 %
FRM 25 A	1 ppm – 1 %
Method 25C	< 1 ppm
(CTM 035) SCAQMD	< 50 ppm(C) or 25 ppm(C) in trap

14 - 27

### Applicability of Methods


	FRM 18	FRM 25	FRM 25A
Measures...	VOCs	TGNMO	THC
Principle...	GC/MD	GC/FID	FID
Carbon Resp...	1:1	1:1	Var.
Results Exp As..	VOC	As C	Cal Gas

14 - 28

### Applicability of Methods







Nature of Emission	Report Emission As	Affected Facility
VOCs unknown/variable	Propane	Asphalt Plants
Single VOC > 75 %	That single VOC	Cement Plants Resource Recovery Bakeries
Single VOC < 75 %	Surrogate	SOCMI Surface Coat Graphite Art

14 - 29









14 - 30

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 14: Defining Volatile Organic Compounds (VOCs)**



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 14: Defining Volatile Organic Compounds (VOCs)**



### Reporting of Emissions?

- “As Carbon?”
- “As TGNMOCs?”
- “As Propane?”
- “As VOCs?”
- “As THC?”
- “As.....What?”

14 - 43

### Reporting of Emissions

- FRM 18, because of the GC/MS analysis, reports results in terms of the concentration of specific organics
- FRM 25 is a method for measuring total gaseous nonmethane organic compounds (TGNMOCs) with a GC column and FID. Therefore, a one-to-one response of all carbon atoms in the sample are as methane (i.e., carbon counter) .

14 - 44

### Reporting of Emissions

- FRM 25A involves determining total hydrocarbons concentrations by introduction of the sample directly into the FID without a GC step to speciate. Results are expressed in terms of the gas used to calibrate the FID (usually methane or propane). FRM 25A does not provide a one-to-one response for all of the carbon atoms present in the sample.

14 - 45

### Reporting of Emissions

- FRM 18 results can be converted to mass emission rates since this method reports concentrations in terms of the actual organic compounds. We know the molecular weight of each analyte along with volumetric flow rate to get VOC mass flow rate.

14 - 46

### Reporting of Emissions

- For FRM 25, we need to know the VOC-to-carbon weight ratio to get VOC mass emission rate.
  - Methanol molecular weight = 32
  - Carbon molecular weight = 12
    - $32/12 = 2.67$  VOC to carbon weight ratio. We would multiply everything by 2.67 to calculate VOC mass emission rate

14 - 47

### Reporting of Emissions

- Converting FRM 25A results to “as VOCs” mass flow is similar to FRM 25 except one must take into account not only the molecular weight factor, but also the relative response factor (RRF) for the FID between the analytes in the gas stream and the calibration gas.

14 - 48

### Relative Response Factors

VOC	C:O Ratio	RRF
Methane	1:0	1.00
Propane	1:0	1.00
Formalde	1:1	0.00
Methanol	1:1	0.40
Ethanol	2:1	0.70
MEK	4:1	0.75
Ethy. Ox	2:1	0.50
CO	1:1	0.00

14 - 49

### Suggested Reporting of Emissions

- For federally regulated source (i.e., NSPS, NESHAPs, MACT etc.), report VOC emissions according to the specific subpart
- If VOC emissions are unknown, highly variable nature, the results should be reported in terms of propane (i.e., Incinerators, boilers, asphalt plants, cement plants, and recovery boilers etc.)

14 - 50

### Suggested Reporting of Emissions

- If composition of the effluent is known and a single VOC > 75%, then emissions reported in terms of that compound (i.e., SOCOMI facilities etc.)
- If composition of the effluent is known and a single VOC < 75%, then emissions reported in terms of a surrogate compound (i.e., surface coatings, graphic arts etc.)

14 - 51

### Suggested Reporting of Emissions

- If testing is for control device efficiency, then emissions can be reported "as carbon" or "as VOCs."
- If testing is to determine if a source is subject to a regulation whose applicability is based upon VOC emission rates, to determine compliance with VOC emission rate standard, or to set permit fees, then the results must be reported "as VOCs" rather than "as carbon."

14 - 52

### Suggested Reporting of Emissions

- This means one has to take into account molecular weight (MW) and for FRM 25A, relative response factor (RRF) in determining VOC emission rate.
  - Reporting as carbon in such circumstances would understate the impact of the emissions on the environment and therefore, would lead to incorrect conclusions regarding compliance or rule applicability.

14 - 53

### Reporting of Emissions

#### Example Calculation 1

Calculating the VOC mass emission rate from a source emitting mostly ethanol (C<sub>2</sub>H<sub>5</sub>OH) using EPA Method 25A data in terms of propane...

$$\left( \frac{\text{ppmvw as C}_3\text{H}_8}{(1 - B_{\text{air}})} \right) (K_{\text{Meth}})(\text{MW}_c)(Q_{\text{air}}) \left( \frac{\text{MW}_{\text{C}_2\text{H}_5\text{OH}}}{(\# \text{ C atoms }_{\text{C}_2\text{H}_5\text{OH}})(\text{MW}_c)} \right) \left( \frac{\text{RRF}_{\text{C}_2\text{H}_5\text{OH}}}{\text{RRF}_{\text{C}_3\text{H}_8}} \right) = \frac{\text{lbs C}_2\text{H}_5\text{OH}}{\text{hour}}$$

$$\left( \frac{\text{ppmvw as C}_3\text{H}_8}{(1 - B_{\text{air}})} \right) (3)(12.01)(Q_{\text{air}}) \left( \frac{46.07}{(2)(12.01)} \right) \left( \frac{1.00}{0.70} \right) = \frac{\text{lbs C}_2\text{H}_5\text{OH}}{\text{hour}}$$

14 - 54



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 14: Defining Volatile Organic Compounds (VOCs)

---

---

### Reporting of Emissions

#### Example Calculation 2

Calculating the VOC mass emission rate from a source emitting mostly ethanol (C<sub>2</sub>H<sub>5</sub>OH) using EPA Method 25 data in terms of carbon...

$$\left( \frac{\left( \frac{\text{ppmvw as C}}{(1 - B_{\text{wt}})} \right) (MW_c) (Q_{\text{sd}})}{385.3 \times 10^6} \right) \left( \frac{MW_{\text{C}_2\text{H}_5\text{OH}}}{(\# \text{ C atoms}_{\text{C}_2\text{H}_5\text{OH}}) (MW_c)} \right) = \frac{\text{lbs C}_2\text{H}_5\text{OH}}{\text{hour}}$$

$$\left( \frac{\left( \frac{\text{ppmvw as C}}{(1 - B_{\text{wt}})} \right) (12.01) (Q_{\text{sd}})}{385.3 \times 10^6} \right) \left( \frac{46.07}{(2)(12.01)} \right) = \frac{\text{lbs C}_2\text{H}_5\text{OH}}{\text{hour}}$$

14 - 55

**U.S. EPA APTI**  
**Compliance Test and Source Test**  
**Observation**  
**Overview and Comparison FRMs 18, 25,**  
**25A and CTS 035**



15 - 1

**Lecture Objectives**

- ➔ Compare the Methods
- ➔ Discuss Their Advantages and Disadvantages
- ➔ Describe Current EPA Guidance on Their Use

15 - 2

**Background**

- ❑ FRM 25 - measures total VOC
- ❑ FRM 25A - measures total hydrocarbons (THC)
- ❑ FRM 18 - measures individual organic compounds

15 - 3

**Background**

- Generally, “stack testing” is performed using FRM 25A or FRM 18
- FRM 25/25A were created in order to determine the removal efficiency of
- VOC’s for control devices

15 - 4

**Background**

- Typically, once a method is promulgated (and sometimes before it is) the method will be used for a variety of purposes including functions that it was not designed to perform
- FRM 25 and FRM 25A are not applicable to mass emission rate

15 - 5

**Background**

- FRM 25
  - Samples are time integrated
  - Analysis is completed off site
- FRM 25A
  - Sampling is continuous
  - Analysis is done on site

15 - 6

### **Background**

- **FRM 18**
  - Samples can be time integrated or semi-continuous
  - Analysis can be on site or off site

15 - 7

### **Background**

- **FRM 25** - All compounds are converted to methane before measuring with an FID
- **FRM 25A** - All compounds are measured directly, as a whole, with an FID

15 - 8

### **Background**

- **FRM 18** - Each compound is separated and measured individually with an FID

15 - 9

### **FRM 25 & 25A**

- The FID can be applied to the determination of the mass concentration of the total molecular structure of the organic emissions under any of the following limited conditions

15 - 10

### **FRM 25 & 25A**

- Where only one compound is known to exist
- When the organic compounds consist of only hydrogen and carbon

15 - 11

### **FRM 25 & 25A**

- Where the relative percentages of the compounds are known or can be determined, and the FID responses to the compounds are known

15 - 12

**FRM 25 & 25A**

- Where a consistent mixture of the compounds exists before and after emission control and only the relative concentrations are to be assessed
- Where the FID can be calibrated against mass standards of the compounds emitted (solvent emissions, for example)

15 - 13

**Advantages: FRM 25**

- Measures only VOC (excludes Methane)
- Responds equally to all VOC

15 - 14

**Disadvantages: FRM 25**

- Potential positive bias that may vary according to source category
- Relatively poor precision

15 - 15

**Advantages: FRM 25A**

- Very good precision
- Real time analysis
- Relatively low detection limit

15 - 16

**Disadvantages: FRM 25A**

- Does not respond equally to all VOC
- Requires a separate measurement of Methane to convert THC to VOC

15 - 17

**Advantages: FRM 18**

- Good precision
- Low detection limits
- Can exclude methane

15 - 18

### **Disadvantages: FRM 18**

- Measures individual organic compounds - not total VOC
- Requires calibration standards for all measured compounds

15 - 19

### **General Guidance**

- Use FRM 25 for unknown mixtures with concentrations greater than 50 ppm
- Use FRM 25A for unknown mixtures with concentrations less than 50 ppm

15 - 20

### **General Guidance**

- Use any of the methods for known mixtures with the following conditions
  - FRM 25 should only be used for concentrations greater than 50 ppm

15 - 21

### **General Guidance**

- Use any of the methods for known mixtures with the following conditions
  - FRM 25A should be calibrated with the known mixture or the results mathematically corrected for varying response factors

15 - 22

### **General Guidance**

- Use any of the methods for known mixtures with the following conditions
  - FRM 18 must be calibrated for each of the compounds in the mixture

15 - 23

### **Summary**

- None of the existing methods for measuring VOCs are perfect
- Because their problems can be source specific, we may have to approve alternative methods for some sources
- We must continue to improve the existing methods

15 - 24

### Reporting VOCs

- Many state agencies require reporting “as VOCs;” or as “carbon, methane; or propane” or “make up your own!”
- One must know how the state wants data reported for VOC emissions
- Volatile organic compounds as defined in 40 CFR 51.100

15 - 25

### Reporting VOCs

- The reporting format of the data must be known prior to accepting test data
  - Mass emission rates - lb/hr as carbon, methane, or propane?
  - Mass emission rates - lb/hr “as VOC”

15 - 26

### Case Study Molecular Weight - FRMs 25 & 25A

- Emissions testing was performed and submitted in support of a permit application
- Gas Stream consisted of ~ 100 VOCs
- Total VOCs per FRM 25A = 2.5 lb/hr as carbon

15 - 27

### Case Study

- One speciated compound per a compound specific test was emitted at 5 lb/hr
- Outcome
  - Facility adjusted the reported VOC emission rate using a MW that was considered ‘average’ for the pollutant gas stream (avg MW of the VOCs)

15 - 28

### Case Study

- Using the MW of carbon for mass emission rate calculation
- Consider Propylene Glycol ( $\text{CH}_3\text{CH}(\text{OH})\text{CH}_2\text{OH}$ )
- Molecular Weight is 76.10
- Assume: Concentration = 100ppm
- Qsd of 100,000 dscfm

15 - 29

### Case Study

- lb/hr “as carbon” ( $\text{MW}=12$ ) = 18.7 lb/hr.
- lb/hr “as VOC” ( $\text{MW}=76.1/3$ ) = 39.57 lb/hr.
- An error in excess of 100% due only to MW

15 - 30



### Case Study

- Identification of a major concern with the reporting of VOCs when using FRMs 25 & 25A
- Propose using a molecular weight adjustment
- Every organic will weigh more than just carbon

15 - 31

### Other Errors Involving FRM 25 & 25A

- “Response factor” error associated with FRM 25A
- The flame ionization detector (FID) used in FRM 25A does not give a 1:1 response with all organics

15 - 32

### FRM 18 Reporting of VOCs

- FRM 18 measures specific VOCs
- Requires knowledge of the pollutant gas stream
- Can only measure VOCs for which the GC/specific detector has been calibrated

15 - 33

### FRM 18 Reporting

- Difficulties
  - Sources claim that they only need to measure “total VOCs” - not speciated
  - What to do with a “soup” of VOCs?

15 - 34

### Summary VOC Methods

- FRM 25 - Measures Total VOC (> 50 ppm)
- FRM 25A - Measures Total Hydrocarbons (THC) (10-100 ppm)
- FRM 18 - Measures Individual Organic Compounds (Sub-ppm)

15 - 35

### EPA’s Conditional Test Method (CTM) 035



15-36

### ◆ VOC Test Methods

- SCAQMD Former Draft Method 25.2 - removed from consideration
- SCAQMD Method 25.3 - for low concentrations only
- EPA's Conditional Test Method (CTM)-035

15 - 37

### Applicability

- ◆ EPA's CTM-035 for combustion exhausts < 50 ppm C
- ◆ Continue to use FRM on inlets or higher concentrations (> 50 ppm)
- ◆ SCAQMD M25.3 replaces former draft M25.2
- ◆ Has a provision for deleting trap when no elevated moisture present (ambient)


15 - 38

### EPA's CTM-035 Sampling

- ◆ Simple self contained sampler
  - No power, no heaters, no adjustments
  - Analysis is completed off-site
- ◆ Duplicate sampling
  - ◆ Probes are placed flush with port entrance

15 - 39

### ◆ Sampling Apparatus



15 - 40

### Duplicate Samplers



15 - 41

### Trap Assembly



15 - 42

### Condensate Trap




15 - 43

### Analysis

- ◆ Condensate by infrared total organic carbon analyzer
  - Lower detection limit 1 ppmC
- ◆ Canister by Method 25.1 modified for low concentration
  - GC/oxidation/reduction/FID
  - Lower detection limit 1 ppmC

15 - 44

### Example Chromatogram



15 - 45







**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 15: Overview and Comparison FRMs 18, 25, 25A and CTS 035**



15 - 49



15 - 50



**Method Development**

- ◆ Various improvements made
  - Trap volume, connector line recovery, trap purge for CO<sub>2</sub>, cleaning and handling
- ◆ EPA Method 301 validation needed however
- ◆ Recent test indicate 92% spike recovery, 20% COV (0.5 ppm)
- ◆ Deemed validated by EPA giving CTM status

15 - 54

### Implementation Issues

- ◆ In interim, distributing CTM-035 for comments
- ◆ Have been allowing use of draft method subject to protocol review
- ◆ Requires determination for MW/C ratio
  - Draft method contains guidelines for MW/C

15 - 55

### ◆ Conclusions

- Method is thought to have superior accuracy and precision than existing methods (i.e., FRM 25 or FRM 25A)
  - Next phase – comparison to Method 25A
- Well received by industry and source test firms
- Not accurate above 50 ppm C

15 - 56

### NCASI Impinger and Canister Method

- National Council for Air and Stream Improvement (NCASI)
  - IM/CAN/WP-99.02
  - “Impinger/Canister Source Sampling Method for HAPs at Wood Products Facilities
  - Publications@ncasi.org

15 - 57

### NCASI Impinger and Canister Method

- Sampling train consist of three chilled impingers/pump/canister
- Flow through impingers is ~ 400 cc/mL
- Single point sampling for 60 minutes

15 - 58

### NCASI Impinger and Canister Method

- Ketones/phenols-Water Impinger: GC/FID
  - Acetaldehyde
  - Acrolein
  - Methanol
  - Methyl Ethyl Ketone
  - Methyl Isobutyl Ketone
  - Propionaldehyde
  - Phenol

15 - 59

### NCASI Impinger and Canister Method

- Formaldehyde-Water Impinger: Acetylacetone Reagent
  - Measure absorption at 412 nm

15 - 60

**NCASI Impinger and Canister  
Method**

- Organic Analysis-Canister: Cryogenic trapping followed by GC/MSD EPA's Compendium Method TO-14
  - Acetaldehyde
  - Acetone
  - Acrolein
  - Methanol
  - Methyl Ethyl Ketone (2-Butanone)
  - Methyl Isobutyl Ketone
  - Propionaldehyde
  - Phenol

15 - 61

**NCASI Impinger and Canister  
Method**

- Terpene Analysis-Canister: Direct Injection GC/FID
  - Camphene
  - p-Mentha-1,5-Diene
  - 3-Carene
  - p-Cymene
  - Limonene
  - $\alpha$ -Pinene
  - $\beta$ -Pinee

15 - 62

**NCASI Impinger and Canister  
Method**

- Total Hydrocarbons-Canister: Direct Injection GC/FID
- Bacharach Gas Analyzer For CO/O<sub>2</sub>/CO<sub>2</sub>-Canister: Direct Analysis By Bacharach Gas Analyzer

[Method IM/CANWP-99.02 Impinger/Canister Source Sampling Method for Selected HAPs at Wood Products Facilities \(ncasi.org\)](http://ncasi.org)

15 - 63





**What is Landfill Gas(LFG)?**

- ◆ Landfill gas generated by the decomposition of organic municipal solid waste such as garbage, garden waste, and paper products

16 - 3

**At Near Steady-state Conditions LFG Is Typically Composed Of:**

- ◆ 45 - 58% methane ( $\text{CH}_4$ )
- ◆ 35 - 45% carbon dioxide ( $\text{CO}_2$ )
- ◆ <1 - 5% oxygen ( $\text{O}_2$ )
- ◆ <1 - 20% nitrogen ( $\text{N}_2$ )

16 - 4

**At Near Steady-state Conditions LFG Is Typically Composed Of:**

- ◆ <1 - 5% hydrogen ( $\text{H}_2$ )
- ◆ 1 - 5% water vapor
- ◆ <1 - 3% trace constituents

16 - 5

**LFG is typically composed of:**

- ◆ Small amounts of nonmethane organic compounds (NMOCs)
  - Benzene
  - Vinyl chloride
  - Chloroform
  - 1,1-dichloroethene
  - Carbon tetrachloride

16 - 6

### LFG is typically composed of:

- ◆ Nonorganic species
  - Hydrogen sulfide
  - Mercury
  - Particulate matter

16 - 7

### Landfill Gases

- ◆ Methane
  - By-product of anaerobic decomposition
  - Colorless, odorless, tasteless gas
  - Lighter than air, relatively insoluble in water
  - Highly explosive in concentrations of 5 to 15% in air

16 - 8

### Landfill Gases

- ◆ Carbon Dioxide (CO<sub>2</sub>)
  - By-product of both aerobic and anaerobic decomposition
  - Colorless, odorless gas
  - Heavier than air, noncombustible
  - Soluble in water and decreases water pH

16 - 9

### Landfill Gases

- ◆ Oxygen (O<sub>2</sub>) and Nitrogen (N<sub>2</sub>)
  - Not common constituents of LFG
  - Present as result of air intrusion (i.e., through cover, through recovery/control system)
  - Typically combined volumes of oxygen and nitrogen < 10% with same ratios in air

16 - 10

### Landfill Gases

- ◆ Hydrogen (H<sub>2</sub>)
  - Typically produced during aerobic decomposition and early stages of anaerobic decomposition
  - Should have only trace concentrations in a mature landfill

16 - 11

### Landfill Gases

- ◆ Water Vapor (H<sub>2</sub>O)
  - LFG typically saturated with water vapor
  - Water in landfill entrained in the gas

16 - 12

## Landfill Gases

- ◆ Trace Constituents
  - Usually originate from waste within the landfill, but some may be present as a result of natural decomposition processes (H<sub>2</sub>S)
  - Nonmethane organic compounds (NMOCs) usually < 1%

16 - 13

## Landfill Gases


- Over 150 different organic gases have been identified
- Contaminants of potential concern (COPCs) in LFG

16 - 14

## Landfill Gas Generation Stages

- ◆ Mainly methane and carbon dioxide produced by microorganisms within the landfill under anaerobic conditions

16 - 15




16 - 16

## Four Characteristic Phases of Gas Generation at Landfills

- ◆ Phase I: Aerobic
- ◆ Phase II: Anaerobic/ Acid Generation
- ◆ Phase III: Transition to Anaerobic
- ◆ Phase IV: Anaerobic
- ◆ Phase V: Transition to Stability

16 - 17

## Path of Least Resistance



16 - 18


## Depends Upon the Path of Least Resistance

- ◆ To the atmosphere through the landfill surface
- ◆ Migrate laterally into surrounding soils
- ◆ Enter groundwater and follow water path
- ◆ Through LFG extraction systems

16 - 19

## Federal Reference Method 2E Determination of Landfill Gas Production Flow Rate

16 - 20



16 - 21

## Applicability

- ◆ Applies to measurement of landfill gas (LFG) production flow rate from municipal solid waste (MSW) landfills
- ◆ Used to calculate the flow rate of nonmethane organic compounds (NMOC) from landfills
- ◆ Also applies to calculating a site-specific “k” value

16 - 22

## Principle

- ◆ Extraction wells are installed in a cluster of three, or at five locations dispersed throughout the landfill
- ◆ A blower is used to extract LFG from the landfill

16 - 23

## Principle

- ◆ LFG composition, landfill pressures near the extraction well, and volumetric flow rate are measured and landfill gas production flow rate determined

16 - 24

### Apparatus

- ◆ Well drilling rig
- ◆ Material
  - Gravel
  - Bentonite
  - Backfill material


16 - 25

### Apparatus

- ◆ Wellhead assembly
  - Control valve
  - Orifice meter/manometer
  - Blower
  - Sampling ports (Well head/outlet)

16 - 26

### Schematic of Above Ground Well Head Assembly



16 - 27

### Placement of Extraction Wells

- ◆ Single cluster of three (3) extraction wells in a test area (Waste known)
  - Near perimeter of site
  - Depth equal to or greater than the average depth of the landfill
  - Waste 2-10 years old

16 - 28

### Placement of Extraction Wells

- ◆ Five (5) wells spaced over the landfill (waste unknown)
  - Divide landfill into five (5) equal areas and place extraction well at centroid of each area

16 - 29

### Extraction Well Pipe Configuration


- ◆ PVC, HDPE, fiberglass, stainless steel or other materials of construction
- ◆ Minimum diameter of 0.075 meters

16 - 30

### Extraction Well Pipe Configuration

- ◆ Bottom two-thirds of the pipe perforated
  - Holes/slots 1.0 centimeter diameter
  - Spaced 90 degrees apart every 0.1 to 0.2 meters

16 - 31



16 - 32

### Extraction Well Pipe Placement

- ◆ Place in center of hole
- ◆ Backfill with gravel to 0.3 meters above perforation
- ◆ Add backfill material 1.2 meters thick
- ◆ Add layer of bentonite 1.0 meters thick
- ◆ Remainder cover material

16 - 33

### Pressure Probe

- ◆ Pressure probes are used in the check for infiltration of air into the landfill and radius of influence
  - Shallow pressure probes used for determination of infiltration of air into landfill
  - Deep pressure probes used to determine the radius of influence

16 - 34

### Pressure Probe Configuration

- ◆ PVC or stainless steel, 0.025 meter
- ◆ Bottom two-thirds of pipe perforated
  - Four 6-mm diameter holes
  - Placed 90 degrees apart
  - Every 0.15 meters




16 - 35

### Pressure Probe Placement

- ◆ Shallow pressure probes placed in close proximity to cluster well
- ◆ Deep pressure probes
  - Along three radial arms from the extraction wells
  - Approximately 120 degrees apart
  - Distances of 3, 15, 30, and 45 meters from extraction wells

16 - 36





**LFG Flow Rate Measurement**

- ◆ **Leak Check System:**  
 Measure nitrogen using FRM 3C at the well head and downstream of the flow measuring device. System is leak tight if difference is < 10,000 ppm

16 - 40

**LFG Flow Rate Measurement**

- ◆ **LFG Flow Rate:**  
 Measure LFG flow rate using orifice meter and manometer continuously during testing

16 - 41

**LFG Static Testing**

- ◆ **Purpose:** Determine the initial condition of the landfill
- ◆ **Procedure:** Close the control valve on the well. Measure the gauge pressure ( $P_g$ ) at each deep pressure probe and barometric pressure ( $P_{bar}$ ) every 8 hours for 3 days

16 - 42

### LFG Static Testing

- ◆ Calculate:  $P_i = P_{bar} + P_g$
- ◆ Average all 8 hours reading for each well to record  $P_{ia}$

16 - 43

### Well Temperature and Static Flow Rate

- ◆ Measure the LFG temperature at each well head
- ◆ Measure static flow rate using Type S pitot tube at each well head

16 - 44

### Short Term Testing

- ◆ The purpose of short term testing is to determine the maximum vacuum that can be applied to the wells without infiltration of air into the landfill
  - Use blower to extract LFG from single well (others capped) at a rate at least twice the static flow rate

16 - 45

### Short Term Testing

- Check for infiltration of air into the landfill by measuring the temperature of the LFG at the wellhead, the gauge pressures of the shallow pressure probes, and LFG nitrogen using FRM 3C
- ◆ LFG concentration of nitrogen is  $> 20\%$
- ◆ Any shallow probes have a negative gauge pressure

16 - 46

### Short Term Testing

- ◆ LFG temperature  $> 55^\circ\text{C}$
- ◆ Increase the blower vacuum by 4 mm Hg, wait 24 hours, and repeat infiltration test
- ◆ Continue increasing blower vacuum by 4 mm Hg until infiltration occurs

16 - 47

### Short Term Testing

- ◆ Then reduce blower vacuum until nitrogen  $< 20\%$ , shallow probes are positive, or LFG temperature  $< 55^\circ\text{C}$
- ◆ This is the maximum vacuum at which infiltration does not occur
- ◆ At this maximum vacuum, measure  $P_{bar}$  every 8 hours for 24 hours
- ◆ Record LFG flow rate:  $Q_s$

16 - 48

### Short Term Testing

- ◆ Deep probe gauge pressures for all probes every 8 - hours:  $P_f$
- ◆ Average 8 hour readings of deep probes:  $P$
- ◆ Compare initial average pressure ( $P_{ia}$ ) to final average pressure ( $P_{fa}$ )

16 - 49

### Short Term Testing

- ◆ Determine furthestmost point from the wellhead along each radial arm where  $P_{fa} < P_{ia}$

16 - 50

### Short Term Testing

- ◆ This is the distance of maximum radius of influence (ROI)
- ◆ Average ROIs to determine the average maximum radius of influence ( $R_{ma}$ )
- ◆ Calculate depth ( $D_{st}$ ) affected by the extraction well:
  - $D_{st} = WD + R_{ma}^2$

16 - 51

### Short Term Testing

- ◆ Calculate void volume (V)
  - $V = (0.40)(R_{ma}^2)(D_{st})$
- ◆ Calculate total void volumes ( $V_v$ )
  - Sum of all V

16 - 52

### Long Term Testing

- ◆ The purpose of long term testing is to determine the methane generation rate constant, k
  - Set blower vacuum to previously determined highest vacuum rate acceptable without infiltration
  - Every 8 hours, sample LFG, measure gauge pressure at shallow pressure probes, the blower vacuum, the LFG flow rate, and check for infiltration

16 - 53

### Long Term Testing

- Calculate  $V_t$ , the total volume of landfill gas extracted:

$$V_t = \sum_{i=1}^n (60)(Q_i)(T_{vi})$$

16 - 54

## Calculating NMOC mass emission rate

$$Q_t = 2kL'_o C_{NMOC} (3.595 \times 10^{-9}) \sum_{i=1}^n M_i e^{-[(k)(t_i)]}$$


Eq. 2E-14

16 - 55

## Federal Reference Method 3C

Determination of Carbon Dioxide, Methane, Nitrogen, and Oxygen from Stationary Sources  
(40 CFR 60, Appendix A)

16 - 56



16 - 57

## Applicability

- ◆ This method applies to the analysis of carbon dioxide (CO<sub>2</sub>), methane (CH<sub>4</sub>), nitrogen (N<sub>2</sub>), and oxygen (O<sub>2</sub>) in samples from municipal solid waste landfills and other sources when specified in an applicable subpart

16 - 58

## Principle

- ◆ A portion of the sample is injected into a gas chromatograph (GC) and the CO<sub>2</sub>, CH<sub>4</sub>, N<sub>2</sub>, and O<sub>2</sub> concentrations are determined by using a thermal conductivity detector (TCD) and integrator

16 - 59

## Apparatus

- ◆ Gas Chromatography equipped with separation column, sample loop, conditioning system, and thermal conductivity detector
- ◆ Recorder, tubing, regulators and adsorption tubes to remove any oxygen in the carrier gas

16 - 60

## GC System and Analytical Apparatus



16 - 61

## Calibration and Linearity Gases

- ◆ Standard cylinder gas mixtures for each compound of interest with at least three (3) concentration levels spanning the range of sample concentration

16 - 62

## Sample Collection

- ◆ Direct Injection
- ◆ Tedlar® Bag
- ◆ Whole Air Flask/Canister

16 - 63

## Whole Air Flask/canister at Extraction Well



16 - 64

## Analytical System Standardization

- ◆ Optimize GC system according to manufacturer's specifications
- ◆ Linearity Check and Calibration
  - Three calibration gases over the range of suspected sample concentration (This initial check may also serve as the initial instrument calibration)

16 - 65

## Analytical System Standardization

- Plot linear regression of concentration vs. area values to obtain relative response to each compound

16 - 66

## Analytical System Standardization

- ◆ Single Point Calibration Check
  - Use standard calibration gas which is within 20% of the sample component concentration

16 - 67

## Sample Analysis

- ◆ Purge sample loop with sample
- ◆ Analyze each sample in duplicate
  - Peak areas should agree within 5% of their average

16 - 68

## Method 3C Calculations

- ◆ Moisture content in the sample
  - $B_w = P_w/P_{bar}$
- ◆ Compound concentration
  - $C = A/R(1-B_w)$

16 - 69


## Concentration of Sample Components

$$C = [P_{tf}/T_{tf}]/[(P_t/T_t) - (P_{tf}/T_{tf})][(A)/R(1-B_w)]$$

16 - 70

## Federal Reference Method 25C

16 - 71



16 - 72



### Applicability

- ◆ This method is applicable to the sampling and measurement of nonmethane organic compounds (NMOC) as carbon in MSW landfill gases

16 - 73

### Principle

- ◆ In operation, a sample probe that has been perforated at one end is driven or augured to a depth of 1.0 meter below the bottom of the landfill cover
- ◆ A sample of the landfill gas is extracted with an evacuated cylinder

16 - 74

### Principle

- ◆ The NMOC content of the gas is determined by injecting a portion of the gas from the evacuated cylinder into a gas chromatographic column to separate the NMOC from CO, CO<sub>2</sub>, and CH<sub>4</sub>

16 - 75

### Principle

- ◆ The NMOC from the separation is oxidized to CO<sub>2</sub>, reduced to CH<sub>4</sub>, and measured by a flame ionization detector (FID)

16 - 76

### FRM 25C Sampling System

- ◆ Probe: Stainless steel with the bottom third perforated. Must be long enough to go a minimum of 1 meter below landfill cover
- ◆ Rotameter: With flow control valve (< 500 mL/min)
- ◆ Sampling valve: Stainless steel

16 - 77

### FRM 25C Sampling System

- ◆ Pressure gauge: U-tube mercury manometer
- ◆ Purge pump: Capable of purging probe
- ◆ Vacuum pump: Capable of evacuating to an absolute pressure of 10 mm Hg


16 - 78

### FRM 25C Sampling System

- ◆ Sampling tank: Stainless steel or aluminum cylinder with a minimum volume of 4 liters and equipped with a stainless steel sample tank valve


16 - 79

### Sampling Probe Purging System



16 - 80

### Sampling Train



16 - 81



16 - 82



### Tank Sampling Procedure

- ◆ Sample Tank Evacuation: Evacuate to 10 mm Hg absolute (field/laboratory), set aside for 60 minutes, check vacuum, no change; acceptable

16 - 84

## Tank Sampling Procedure

- ◆ Sampling
  - Evacuate/pressurize sampling tank three time with final vacuum of 325 mm Hg; set aside
  - Assemble sample probe, flow control valve, rotameter and purge pump

16 - 85

## Pilot Probe Sampling Procedure

- ◆ Sample Probe Installation
  - Pilot Probe Procedure:
    - Use post driver to 1 meter below landfill cover
    - Insert sample probe
    - Seal with bentonite
    - Cap

16 - 86

## Pitot Probe Sampling Procedure

- Purge at least 2 probe volumes at flow rate of 500 mL/min
- Replace purge pump with sample tank


16 - 87

## Pilot Probe Sampling Procedure

- Auger Procedure:
  - Drill hole to 1 meter below landfill cover
  - Place sample probe in hole
  - Backfill with pea gravel to level of 0.6 meters from the surface
  - Seal around probe with bentonite
  - Equilibrate for 24 hours before sampling

16 - 88


### Sample Probe in the Ground



16 - 89



16 - 90



- ### Sampling Procedure
- ◆ **Sampling**
    - Open the sampling valve and tank valve
    - Sample at a flow rate of 500 mL/min until sample tank gauge is zero
    - Disconnect from sampling system
    - Pressurize to 1,060 mm Hg with helium
- 16 - 93

- ### Sampling Procedure
- Record final pressure (may also be pressurized in the laboratory)
  - Landfill gas sample is acceptable if N<sub>2</sub> is < 20%
- 16 - 94

- ### Federal Reference Method 25C Analysis
- ◆ FRM 25C: Oxidation, reduction and measurement of NMOC
  - ◆ Initial NMOC analyzer performance test:
    - Oxidation catalyst efficiency check
    - Reduction catalyst efficiency check
    - Analyzer linearity check (not CO<sub>2</sub>)
- 16 - 95

- ### Federal Reference Method 25C Analysis
- ◆ NMO Analyzer daily calibration
  - ◆ NMO response factor
- 16 - 96

### NMOC Concentration

$$C_t = \frac{P_{tf}}{T_{tf}} \frac{P_t}{T_t} \frac{P_{ti}}{T_{ti}} \frac{1}{1 - B_w - C_{N2}} r \sum_{j=1}^r C_{tm(j)}$$

16 - 97



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17A: Federal Reference Method 18

### U.S. EPA APTI Compliance Test and Source Test Observation

Federal Reference  
Method 18  
General GC Methodology  
(Work Horse for VOCs Speciation Detection)

17A - 1

Direct Interface  
Direct Interface/Dilution  
Solid Adsorbent  
Tedlar Bags



17A - 2

Survey Canister Sampling



17A - 3

#### Applicability

- Provides concentration data on approximately 90% of total gaseous organic mass emitted from an industrial source
- Does not include techniques to identify and measure trace amounts of organic compounds (< 1 ppm), such as those found in building air and fugitive air emission sources

17A - 4

#### Applicability

- FRM 18 is a generic method which is wide open for quantifying speciated organic compounds
- FRM 18 is a “self-certifying” method.....”performance-base” method! Most all other VOC methods are “procedure-base!”
- “Regulatory science” vs. “measurement science!”

17A - 5

#### Applicability

- FRM 18 will not determine compounds that are
  - Polymeric (high molecular weight)
  - Analytes that can polymerize before analysis
  - Analytes that have very low vapor pressure at stack or instrument conditions (<  $10^{-3}$  mm Hg)

17A - 6



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17A: Federal Reference Method 18

---

### Principle

- Based on separating components of a gas mixture in a gas chromatographic column and measuring separated components with suitable detector (i.e., FID, ECD, PID, MS, IT etc.)
- Uses retention time (RT) as the identification technique compared to standards

17A - 7

### Overview Items

- FRM 18 requires analysis of an EPA audit cylinder prior to sample analysis
- FRM 18 strongly suggest/requires performing pre-survey to help identify analytes/column/detector [All tentatively identified compounds (TICs) with peaks > 5%]
- FRM 18 requires conducting a recovery study to meet 70-130 %

17A - 8

### Overview Items

- FRM 18 provides concentration (usually in terms of “ppm”) for speciated organics
- Mass emission rate can be provided as long as FRM 1 and 2 are incorporated into the monitoring program

17A - 9

### Overview Items

- FRM 18 identifies only those analytes for which sampling and analysis is specifically conducted
- FRM 18 can't be used if emissions are unknown
  - FRM 18 ( $\text{CH}_3\text{OH}$ , MW=32) 100 ppm x 32 = 3200
  - FRM 25 (C, MW=12) 100 ppm x 12 = 1200
  - Error: 62 %

17A - 10

### Overview Items

- FRM 18 requires calibration of analytical system with 3 standards which bracket the concentration of the analyte in the source
  - Commercial cylinders
  - Gas cylinder dilution (FRM 205)
  - Flash vaporization
- FRM 18 requires determination of response factor for each analyte

17A - 11

### Overview Items

- FRM 18, for tube sampling, requires determination of collection efficiency (CE). Tubes (800/200 mg) with no more than 10% of analyte concentration on back portion

17A - 12

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17A: Federal Reference Method 18

---

### Overview Items

- FRM 18 requires determination of recovery study for all methodologies
  - Direct interface: Mid-level gas at probe then analyzer/2 injections ( $\pm 10\%$ )
  - Bags: Of the 3 sample bags, choose one and spike all analytes into bag (40-60 % of avg. conc. of 3 bags). Recovery 70-130 %
  - Adsorbent tubes: Two sampling trains: Spiked/40-60 % of expect conc. and unspiked; three runs; 70-130 % recovery

17A - 13

### Overview Items

- FRM 18 pushes you to using direct injection, Tedlar bags or adsorbents as sampling options
- FRM 18 allows correction of emissions to "Recovery Study" results: Reported emissions = FRM 18 Conc./R
- For solid adsorbent, no more than 10% of analyte found on back tube

17A - 14

### Overview Items

- All tubing used in the sampling train must be Teflon...no Tygon tubing allowed
- Aluminized Mylar bags are recommended for low concentration bag sampling because of low permeation rate
- Canister sampling can only be used during survey, **NOT** for compliance application

17A - 15

### Method Criteria

- Range: 1 ppm to an upper limit of GC detector (saturation of detector limiting factor; upper limit can be extended by dilution)
- A lower range may be achievable by concentrating the sample, thus lowering the limit of detection below the 1
- Sensitivity: minimum detection limit or signal-to-noise ratio 3:1

17A - 16

### Method Criteria

- Precision: 5 to 10% relative standard deviation(RSD) of mean value (usually 5% with experience GC operator)
- Accuracy: Within 10% audit sample value
- Must conduct recovery study
  - 70-130 % recovery criteria

17A - 17

### Method Criteria

- Audit Samples are required
- As of July 2021, the requirement to obtain these audit samples is no longer in effect until such time as another independent accredited audit sample providers (AASP) has audit samples available for purchase.

17A - 18

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

---

Interferences

- Resolution interferences (may be eliminated by GC column selection and column physics)
- Contamination of analytical system (checked by periodic analysis of blanks)

17A - 19

Interferences

- Cross-contamination from analysis of high to low concentration (prevented by purging system between analysis)
- Water vapor (correction factor developed)

17A - 20

FRM 18 Overview

- To determine the concentration of discrete volatile organic compounds (VOCs) in the sample
- Generic GC method
- Pre-survey recommended/required
  - Confirms identity of target analytes and concentration > 5 % peak height
  - Qualitative by RT, quantitative by internal/external calibration technique

17A - 21

FRM 18 Overview

- For speciated VOCs
- Any combination of
  - Sampling techniques, GC Columns, and detectors can be used (Wide open method)
  - Source decides combination provide the recovery criteria are met (70-130%)
  - Recovery performed once per source

17A - 22

FRM 18 Sampling Methods

- Integrated bag
  - Glass sampling flask
  - Adsorbent tubes
    - Charcoal
    - Silica Gel
    - Florisil®
    - CarboTrap® 300
    - Tenax® TA
- (Must perform recovery study for each sampling approach)

17A - 23

FRM 18 Sampling Methods

- Liquid Trapping Media
  - Sulfuric acid for amines
  - Cadmium hydroxide for reduced sulfurs compounds
  - 2,4-Dinitrophenylhydrazine for aldehydes and ketones

17A - 24

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17A: Federal Reference Method 18

---

### FRM 18 Sampling Methods

- **Direct Interface:** Sample continuously pumped to gas chromatographic (GC) by heated line
  - Analysis conducted on discrete gas samples from sample loop ( ~ 1mL)
  - All compounds must be separated by one column/detector combination

17A - 25

### FRM 18 Sampling Methods

- **Dilution Interface:** Same as direct interface, but used with extremely high concentrations of target analytes

17A - 26

### Using FRM 18

- **Know The Characteristics of the Source (Pre-Survey)**
  - Specific analytes known
  - Chemical and physical properties of emissions known (i.e., BP, VP etc)
  - Matrix of source known (i.e., % H<sub>2</sub>O, stack temperature, part. loading etc.)
  - Perform survey with direct injection, Tedlar bags or canisters and identify all TICs with peaks > 5 %

17A - 27

### Using FRM 18

- **Select Sampling and Analytical Finish for Targeted Analytes**
  - State of PA flow chart
  - Determine analytical finish for TICs
  - For solid adsorbents, select through literature resin and tube design
    - Breakthrough volume, desorption efficiency, capacity of adsorbent, design of 800 mg/200 mg
- **Perform laboratory evaluation for analyte recovery (Not required by FRM 18)**

17A - 28

### Using FRM 18

- **Perform An Audit of EPA's Gas Cylinder for Target Analytes (This is a Performance Evaluation [PE] Audit)**
  - Analysis must agree within 10 % of certified gas values
  - Three analysis must agree within 10 % of each other
- **Calibrate all Sampling Components**
  - Dry gas meters, flow meters, thermocouples etc.

17A - 29

### Using FRM 18

- **Conduct Recovery Study (Once/source) For Selected Methodology**
  - **Direct Interface:** Mid-level gas at entrance of probe; Must meet 5 % recovery
  - **Tedlar Bag:** Spike 1 bag at 40-60 % of emission standard; Must meet 70-130 % recovery
  - **Tube Sampling:** Two sample trains, 3-runs, one train spiked (40-60% mass); Must meet 70-130 % recovery

17A - 30

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17A: Federal Reference Method 18

### Using FRM 18

- Sampling
  - Verify non-cyclonic flow at sampling location
  - If mass emission required, perform FRM 1 and 2
- Sample
  - Assemble sample train, Leak check, Purge probe, Sample at constant rate/single point, Take necessary data during sampling, Post leak check, Fill out COC, Chill samples if applicable

17A - 31

### Using FRM 18

- Calibration of Analytical System and Analysis
  - Calibrate system using minimum of 3 standards that bracket the concentration of analyte in source
  - Determine relative response factor for each target analyte
  - Must identify all TICs > 5 %
  - Determine collection efficiency of 1 tube by analyzing back section. No more than 10 % on back section
  - Correct data to recovery study value

17A - 32

### Sampling Flask/Canister

- Samples can be collected in pre-cleaned 250 mL double-ended sampling flask or canisters
  - Cleaning of flask: methylene chloride, soap solution, furnace (500 °C for 1 hour)
- Sampling performed by either:
  - Evacuated flask procedure
  - Purged flask procedure

17A - 33

### Evacuated Flask/Canister Sampling Procedure

- Flasked/canister cleaned
- Attach "T-connection" to inlet of flask/canister
- Attach 6 mm O.D. borosilicate sampling probe with 12 mm O.D. enlargement at end containing glass wool plug for particle control
- Probe placed > 1 meter from side wall of stack

17A - 34

### Evacuated Flask Sampling Procedure

- Use rubber suction bulb to purge probe
- Open stopcock to fill flask/canister
- Heated canister used by NCASI for quantifying methanol, xylenes, acetone, benzene and methyl ethyl ketone (MEK)
- SCAQMD Method 25.3 applicable also

17A - 35

### Purge Flask Sampling Procedure

- Attach end of flask to a rubber suction bulb
- Attach probe used in evacuated flask procedure to inlet of flask

17A - 36

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

Purge Flask  
Sampling Procedure

- Purge flask, then close stopcock near suction bulb
- Close stopcock near probe
- Tape stopcocks to prevent leakage

17A - 37

Flexible Bag  
Sampling Procedure

- Pre-survey samples collected in Tedlar® or aluminized Mylar flexible bags
- Flexible bag certification
  - Use new bag
  - Leak check all bags

17A - 38

Flexible Bag  
Sampling Procedure



- Check for contamination by filling with nitrogen
- Analyze 24 hours later with GC

17A - 39

Bag Sampling


- Assemble sampling train
- Leak check both the bag and container
- Place probe > 1 meter from inside wall
- Purge probe line
- Evacuate container containing flexible bag

17A - 40





**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**



**Bag Sampling**

- Sample three bags (proportional sampling to stack flow, single point sampling)
- Analyze bag in triplicate
- Spike one of the bags for recovery determination
- Store for hold time period
- Analyze in triplicate

17A - 46



**Recovery Study For Bag Sampling**

- Recovery must be 70-130%; Field values adjusted to recovery value
- Must analyze performance evaluation (PE) sample (EPA Audit Sample) prior to analysis of stack gas sample
- Audit analyses must agree with the audit concentrations within 10%

17A - 48

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

Bag Sampling with High Condensation Stacks

- Heat sampling box containing sample bag to stack temperature
- Maintain temperature of bag until analysis (Similar to heated canister approach)
- Add dropout impinger to collect condensate (must be analyzed for VOCs along with bag analysis)

17A - 49

Direct Interface Sampling and Analysis

- Apparatus: Sample probe (~ 6.4 mm), sample line, sample pump, sample valve, flow meters, and heated box
- Assemble equipment and leak check
- Heat sample probe, line, and sample box to 1 to 3°C above stack temperature

17A - 50

Direct Interface Sampling and Analysis

- Perform analysis of mid-level calibration gas through the sample line behind probe outlet.
- Response should be  $\pm 10\%$  of true value and two readings must be within  $\pm 5\%$

17A - 51

Direct Interface Sampling and Analysis

- Response to calibration gas analysis should be accurate to within 10 %
- Reconnect probe, analyze stack gas
- Analysis of stack gas must agree with the two analyses to within 5 %

17A - 52

Direct Interface/Dilution Sampling and Analysis

- Same apparatus as direct interface except a dilution system is added between heated sample line and the gas sampling valve
- Apparatus arranged so either a 10:1 or 100:1 dilution of source gas can be directed to the GC analyzer

17A - 53

Direct Interface/Dilution Sampling and Analysis

- Verify accuracy of dilution system by analyzing calibration gas with agreement within 10 % of expected value
- Analyze low concentration calibration gas into analyzer twice
- Analysis should be within 5 % of each other

17A - 54

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

---

Adsorbent Tube Procedure

- Samples are collected in adsorbent tube containing specific amounts of adsorbents packed as primary and secondary sections (Dual bed tubes)
  - 800/200 mg for charcoal tubes
  - 1040/260 mg for silica gel tubes

17A - 55

Adsorbent Tube Procedure

- Tube design left up to user and selection of resin as long as:
  - Breakthrough volume determined;
  - Desorption efficiency determined; and
  - Capacity of adsorbent determine under stack conditions (i.e., temperature, moisture etc.)

17A - 56

Adsorbent Tube Design

- Adsorbents such as Tenax<sup>®</sup> GC or XAD-2<sup>®</sup> can also be used
- Typical tube design is 90 mm X 6 mm
- Dual sampling trains
- Dual components of tubes (< 10% in back tube)
- Audit analysis of  $\pm 10\%$

17A - 57

Nature of Ideal Adsorbents

- Very high surface area
- Irregular shape
- Non-polar
- Non-reactive
- Granular

17A - 58

Nature of Ideal Adsorbents

- High capacity
- Inert
- Non-corrosive
- Readily activated
- Easy release

17A - 59

Advantages of Adsorbent Technology

- Small sample configuration
- First element in sampling train
- Large selection of adsorbents
- Better water management
- Large database

17A - 60

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

---

Typical Adsorbents

- Organic polymer adsorbent
- Inorganic adsorbent
- Carbon adsorbents

17A - 61

Classification of Adsorbents

- Weak (50 m<sup>2</sup>/g)
  - Tenax<sup>®</sup>, Carbopack C<sup>®</sup>, Anasorb<sup>®</sup>
- Medium (100-500 m<sup>2</sup>/g)
  - Carbopack B<sup>®</sup>, chromosorbs
- Strong (> 1000 m<sup>2</sup>/g)
  - Carbosieve S-III<sup>®</sup>, Carboxen<sup>®</sup>

17A - 62

Typical Organic  
Polymeric Adsorbents

- Tenax-GC<sup>®</sup> or Tenax-TA<sup>®</sup>
- Porapak Q<sup>®</sup>
- Carbon molecular sieve
- XAD<sup>®</sup> series

17A - 63

Weaknesses of  
Tenax<sup>®</sup> Adsorbent

- Poor desorption of highly polar compounds
- Possibly retains O<sub>2</sub> leading to sample oxidation
- Limited to specific range of VOCs

17A - 64

Weaknesses of  
Tenax<sup>®</sup> Adsorbent

- Possible background contamination
- Low breakthrough volume for many of the analytes of interest

17A - 65

Weaknesses of  
XAD<sup>®</sup> Series Adsorbent

- Thermal stability questionable
- Breakthrough extensive for < C7

17A - 66

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

Inorganic Adsorbents

- Silica gel
- Alumina
- Fluorisil
- Carbon molecular sieves

17A - 67

Weaknesses of  
Silica Gel Adsorbent

- Limited use in high moisture stacks
- Thermal breakdown of silica gel
- Solvent extraction means dilution of sample

17A - 68

Weaknesses of Carbon Molecular  
Sieve Adsorbent

- Holds onto very volatile compounds
- Solvent extraction means dilution
- Desorption efficiency decreases with analytes that have boiling points (BP) > 100°C

17A - 69

Carbon Adsorbent

- Activated carbon
- Carbon molecular sieve
- Carbonaceous polymeric adsorbents

17A - 70

Limitation of  
Carbon Base Adsorbents

- High surface area causes artifact formation
- High background contamination possible
- Very high affinity for water High catalytic activity

17A - 71

Limitation of  
Carbon Base Adsorbents

- Incomplete sample recovery during solvent extraction
- Impurities in solvents used during extraction
- Solvent extraction means dilution

17A - 72

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

Common Adsorbents Used in Air Pollution Studies

- Carbon
- Tenax-TA®
- Porapak Q®
- Polyurethane foam

17A - 73

Common Adsorbents Used in Air Pollution Studies

- Carbon molecular sieve
- XAD® Series
- Carbosieve S-III® /Carbotrap® /Carbotrap C® (Carbotrap 300®)

17A - 74

Adsorbent Selection-Capture Process (Analyte Boiling Point)

- Carbosieve S-III® for VOCs with boiling points between -15°C to 80°C
- Carbotrap® for VOCs with boiling points between 0°C to 100°C
- Carbotrap C® for VOCs with boiling points between 80°C to 250°C

17A - 75

Adsorbent Selection-Capture Process (Analyte Boiling Point)

- Tenax-TA® for VOCs with boiling points from 30°C to 200°C
- XAD-2® for VOCs with boiling points from 120°C to 350°C

17A - 76

Supelco Carbotrap® 300

Carbotrap C®	Carbonaceous material	Heavy Organics (> C <sub>12</sub> )
Carbotrap	Carbonaceous material	C <sub>5</sub> to C <sub>12</sub>
Carbosieve S-III®	Carbon molecular sieve	C <sub>2</sub> to C <sub>6</sub>

17A - 77

Adsorbent Recovery  
Two Process Recoveries

- Thermal Desorption
  - Entire sample analyzed
  - More readily automated
  - Only one analysis

17A - 78



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

**Adsorbent Recovery Solvent Extraction**

- Solvent Extraction
  - Able to adjust concentration
  - Replicate analysis
  - No thermal desorption breakthrough products
  - However, dilute sample


17A - 79

**Adsorbent Tube Sampling Train**

- Heated probe (~ 6 mm I.D.), in-stack or out-of-stack filter (heated), flexible tubing, leakless sample pump, rotameter, and adsorption tube
- All temperature and flow measuring devices must be calibrated


17A - 80

**Active Sampling System Utilizing Solid Adsorbents**




17A - 81

**Single Tube Design-Glass/Stainless Steel**



17A - 82

**Multi-bed Adsorbent Trap**



17A - 83




17A - 84

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**



17A - 85



17A - 86



17A - 87

### Adsorbent Tube Sampling

- Strengths
  - Sample compact and easy to use
  - Sample returned to laboratory for analysis
  - Good sample storage time

17A - 88

### Adsorbent Tube Sampling

- Weaknesses
  - Quantitative recovery poor
  - Breakthrough possible of interested analytes
  - Moisture may affect sample recovery


17A - 89

### Breakthrough Volume

- Breakthrough volume is when the analyte entering the adsorbent bed is also leaving the adsorbent bed at the same rate

17A - 90

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**



Published Breakthrough Volumes (at 20°C)

- Vinyl Chloride 0.6 L/g
- p-Dichlorobenzene 820 L/g
- Chlorobenzene 184 L/g
- Benzene 36 L/g
- Carbon Tetrachloride 27 L/g

17A - 92

Safe Sample Volume

- Safe sample volume is the published breakthrough volume (liters/gram of adsorbent) divided by 1.5 times the weight of the adsorbent used in the system

17A - 93

Published Safe Sample Volumes

- Vinyl Chloride <1.0 L/g
- p-Dichlorobenzene 290.0 L/g
- Chlorobenzene 74.0 L/g
- Benzene 14.0 L/g
- Carbon Tetrachloride 11.0 L/g

17A - 94

Adsorbent Tube Sampling

- Determine “breakthrough volume” in order to calculate sampling time and volume
- Perform recovery study of the analytes of interest during the actual field test
  - Two identical sampling trains collocated in stack

17A - 95

Adsorbent Tube Sampling

- Recovery study (Two sampling trains)
  - One train spikes (all compounds of interest) and the other unspiked train
  - Amount of analyte spiked should be 40-60% of mass expected to be collected by unspiked train
  - Field data adjusted with recovery value (R)

17A - 96

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17A: Federal Reference Method 18

---

### Adsorbent Tube Sampling

- Sample the stack gas with the collocated sampling trains for a total of 3 runs
- Determine the fraction of spiked compound recovered (R)
- Criteria of  $70 < R < 130\%$  must be met in order for sampling technique to be used for specific analyte
- $< 10\%$  in back half of adsorbent tube
- Audit analysis agrees within  $\pm 10\%$

17A - 97

### Direct Interface Sampling

- Strengths
  - Sampling provides for immediate analysis
  - Minimize loss or alteration to analytes during sampling
  - Method of choice for steady state processes when duct temperature is below  $100^{\circ}\text{C}$  and organics suitable for GC analysis

17A - 98

### Direct Interface Sampling

- Weaknesses
  - GC at site, can't integrate sample, non-steady state, poor recovery

17A - 99

### Tedlar® Bag Sampling

- Strengths
  - Sample collected over time and has same compounds and concentrations as stack emissions
  - Sample may be returned to laboratory for analysis
  - Multiple analysis

17A - 100

### Tedlar® Bag Sampling

- Weaknesses
  - Tedlar® bags awkward and bulky for shipment, stability of compounds, can't do polar

17A - 101

### Recovery Studies

- Direct Interface: Mid-level calibration point for 1 analysis ( $\pm 10\%$ ) repeated twice ( $\pm 5\%$ )
- Bags: After three analysis, choose bag, spike at 40-60% of avg. concentration (70-130 % recovery), field data adjusted to R value
- Solid Adsorbent: Two identical sampling trains, one spiked and one unspiked, 70-130 % recovery, field data adjusted to R value

17A - 102

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

Which Sampling  
Technique Should Be Used?

- Direct Interface: Excellent, provides real-time data if all analytes can be separated by one column/detector combination
- Dilution Interface: Same benefits as direct interface; excellent if high concentrations of target compounds are present in stack gas

17A - 103

Which Sampling  
Technique Should Be Used?

- Adsorbent Tube: Excellent if concentrations of target compounds are sub-ppm levels
- Bag Sampling: Everybody's favorite; cheap; excellent when more than one detector is needed; excellent for explosive environments

17A - 104

FRM 18  
Adsorbent Tube Sampling

- Any commercially available adsorbent is allowed
- May use water knockout impinger before adsorbent

17A - 105

FRM 18  
Adsorbent Tube Sampling

- Must perform dual sampling trains, one spiked and one unspiked
- Three dual-sampling trains constitutes a test

17A - 106

FRM 18  
Adsorbent Tube Sampling

- Desorption/analysis usually performed in lab
- May perform solvent or thermal desorption
- If solvent desorption, analyze each in triplicate

17A - 107

FRM 18  
Adsorbent Tube Sampling

- If thermal desorption, analyze each sample once
- Recovery of PE must be 70-130%

17A - 108

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

FRM 18  
Adsorbent Tube Sampling

- Method applicable to most sampling programs when
  - 10 or less compounds
  - compounds are known
  - fairly high vapor pressure at room temperature

17A - 109

FRM 18  
Adsorbent Tube Sampling

- ppb to ppm levels dependent on use of adsorbent or Tedlar® bag
- mass balance around system is required
- should not be used after combustion source unless compounds identifiable

17A - 110

FRM 18 Pre-survey Requirements

- A pre-survey shall be performed on each source to be tested to obtain all information necessary to design emission test
- Pre-survey optional if target compounds are known

17A - 111

FRM 18 Pre-survey Requirements

- Only place where canister sampling is allowed
- Typically grab sample, qualitative analysis, GC/MS for identification
- Canisters can be used during pre-survey

17A - 112

FRM 18 Pre-survey Requirements

- Obtain stack temperature and temperature range
- Obtain approximate particulate concentration
- Obtain static pressure and water vapor content

17A - 113

FRM 18 Pre-survey  
Sample Train Selection

- 250 mL double-ended glass sampling flask (specified cleaning procedures provided)
- Method 7 evacuated flask
- Tedlar® or aluminized Mylar flexible bag
- Adsorption tubes
- Specially-treated canisters

17A - 114



APTI #450/468 Compliance Test and Source Test Observation  
Lesson 17A: Federal Reference Method 18



FRM 18 Pre-survey  
Sample Analysis

- Select GC columns based upon manufacturer's recommendation
- Select GC conditions for good resolution by varying conditions after 1st injection

17A - 119

FRM 18 Pre-survey  
Sample Analysis

- Heat pre-survey sample to duct temperature
- Analyze pre-survey samples using retention time (RT) compared to calibration standards

17A - 120

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

---

Criteria for Pre-survey  
and Sample Analysis

- Prepare calibration standards by proper technique
- Determine optimum GC settings
- Obtain retention times with repeatability of  $\pm 0.5$  seconds

17A - 121

Criteria for Pre-survey  
and Sample Analysis

- Use smaller sample loop or dilution if necessary
- Identify all peaks  $> 5\%$  of the total area (i.e., tentatively identified compounds [TICs])

17A - 122

Preparation of  
Calibration Standards

- Liquid standard in desorbing solution
- Direct analysis of NIST reference gases or commercial certified gas mixtures

17A - 123

Preparation of  
Calibration Standards

- Gas dilution from high concentration of gas cylinder using calibrated rotameters
- Direct syringe-bag dilution for known quantity volatile liquid material

17A - 124

Preparation of  
Calibration Standards

- Indirect syringe-bag dilution for known quantity of less volatile liquid materials

17A - 125

FRM 18 Final Sampling  
and Analysis Procedure

- Consider safety and source conditions, select appropriate sampling and analysis procedures (use direct interface if source  $< 100^{\circ}\text{C}$  and organics suitable for detection)

17A - 126

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17A: Federal Reference Method 18

---

### FRM 18 Final Sampling and Analysis Procedure

- If source has high concentration (> 100 ppm), then select direct dilution interface technique

17A - 127

### FRM 18 Compliance Test Direct/Dilution Interface

- On-line, on-site GC
- Real-time analysis
- Triplicate injections, three concentrations of each target compound for generation of calibration curve

17A - 128

### FRM 18 Compliance Test Direct/Dilution Interface

- Calibration gas must be certified to 2% accuracy by manufacturer
- Method 205 allowed

17A - 129

### FRM 18 Compliance Test Direct/Dilution Interface

- Recovery study basically leak check, 70-130% recovery
- Five consecutive samples equals a run

17A - 130

### FRM 18 Compliance Test Direct/Dilution Interface

- Post-test calibration check
  - If > 5% difference, use both curves
  - If < 5% difference, use first curve generated

17A - 131

### FRM 18 Summary

- Source has great flexibility in choosing sampling/analytical methodology (as long as recovery criteria are met)
- Encourage direct/dilution interface: real-time data, less chance of sampling loss

17A - 132

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17A: Federal Reference Method 18**

---

---

FRM 18 Summary

- Any detector, including mass spectrometer, may be used
- Any adsorbent is allowed as long as recovery met
- Analyte recovery performed once per source
- Canisters are not allowed as a compliance test technique

17A - 133

FRM 18 Reporting Results

- Reported Results = (Measured concentration, ppm) / R
- R = Recovery =  $(m_v)(V_s)/S$ 
  - S = Theoretical mass

17A - 134

**U.S. EPA APTI  
Compliance Test and Source Test  
Observation  
FRM 25: TGNMOs as C**



17B - 1

**Family of Method 25s**

- FRM 25: Total VOCs
- FRM 25A: Instrumental FID
- FRM 25B: Instrumental NDIR
- FRM 25C: Landfill Gases
- FRM 25D: VOC Waste Sample
- FRM 25E: VOC Waste Sample

17B - 2

**Applicability**

- Method 25 applies to the measurement of volatile organic compounds (VOCs) as total gaseous nonmethane organics (TGNMO), condensable and non-condensable, as carbon in source emissions
- This method is not applicable for the determination of speciated VOCs or organic particulate matter

17B - 3

**Method 25**

- Applicability
  - Originally developed for determining the percent reduction of VOC emissions achieved by emission control devices for automobile and light-duty truck surface coating operations
- Concerns
  - Complex method
  - Use as last resort
  - Use FRM 18 first as survey tool

17B - 4

**FRM 25 Timeline**

- Original Proposed 10/05/79
- Promulgated 10/03/80
- Amendment 11/07/86
  - Added filter heating system
  - Redesigned condensate trap
  - Specified oxidation catalyst
  - Specified new separation column
- Corrections 04/07/88

17B - 5

**Method 25 Applicability**

- Concerns
  - Not applicable for measuring concentrations of VOCs or mass emissions of VOCs from sources whose concentrations are < 50 ppm
  - Possible bias when:
    - % CO<sub>2</sub> X % H<sub>2</sub>O > 100
  - As water freezes in the trap, CO<sub>2</sub> is trapped out prematurely. The CO<sub>2</sub>, when reduced to methane, is counted as VOCs in the analytical system

17B - 6

### Method 25 Applicability

- Concerns
  - Not applicable for measuring emissions from sources whose principal solvents are chlorinated hydrocarbons
  - Generally, for any situation where a simpler procedure is more accurate
  - High organic droplets in gas stream can cause high bias or data variability

17B - 7

### Method 25 Applicability

- Concerns
  - Source which has a complex flue gas flow
  - Moisture content of the exhaust gas is much higher than what is found in the audit sample
  - The presence of organic and inorganic particulates in concentrations larger than those found in the audit sample
  - Presence of droplets, tar, and wax aerosols

17B - 8

### Historical Method 25 Common Problems

- High gas sample moisture content and freezing of trap
- Probe exit and filter temperatures not within specifications
- Non-constant sample flow rate
- Use of Method 25 for measuring low levels of VOCs from source
- Measurement in ducts containing organic droplets

17B - 9



### Method 25 Principle

- A gas sample is withdrawn from the stack at a constant rate through a chilled condensate trap (dry ice temperature) by means of an evacuated sample tank (> 4 L)
- Condensate trap is 3/8 " stainless steel packed with glass wool
- TGNMO are determined by combining the analytical results obtained from independent analysis of the condensate trap and sample tank fraction

17B - 11

### Method 25 Applicability

- Applicable to all sources where VOC emissions are to be expressed as carbon (C)
  - To be used where there are too many solvents being emitted simultaneously
  - No speciation is required

17B - 12



### Method 25 Applicability

- After a combustion source where compound conversion takes place and identification is difficult
- A mass balance is not required (i.e., capture efficiency is not determined)

17B - 13

### Method 25 Interference

- Organic particulate matter will interfere with the analysis; therefore, a particulate filter may be required (i.e., in-stack or out-of-stack)

17B - 14

### Method 25 Advantages

- Gives constant results from source to source whether sample composition is known or not
- Sample train does require heated probe and filter, but is less complicated than FRM 5 hardware


17B - 15

### Method 25 Disadvantages

- Will not yield true mass emission rate
- No real time data (sample must be returned to laboratory for analysis)
- High moisture and CO<sub>2</sub> together can cause interference
  - ( $\%CO_2$ ) $\times$ ( $\%H_2O$ ) $>$ 100 gives potential high bias (EPA Guidelines)

17B - 16

### Method 25 Summary



17B - 17

### Method 25 Summary

- Inject portion of cylinder sample into GC to separate non-methane organics, oxidize NMO to CO<sub>2</sub>, reduce to methane, and measure with FID
- Combine results (condensable and non-condensable) and report as total gaseous nonmethane organics (TGNMO)

17B - 18




# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17B: Federal Reference Method 25

### Method 25 Apparatus



- Sampling System
  - Probe (260 °C)
  - Filter (250 °C ±5 °C)
  - Condensate trap (-78 °C) for condensables
  - Flow control system
  - Sample tank for non-condensables

17B - 19







APTI #450/468 Compliance Test and Source Test Observation  
Lesson 17B: Federal Reference Method 25





**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**



**Calibration of  
Sampling System**

- Sample tank volume (Measure to nearest 5g of water or 5 mL)
- Volume of sampling train from probe tip to sample tank valve (This volume maximum should be 100 mL)

17B - 36

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

---

**Calibration of  
Sampling System**

- Sample tank: to the nearest 5 g (if using deionized water) or to the nearest 5 mL
- Sample train volume: No limits (< 100 mL)
- Rotameter: Not calibrated
- Thermometers: Within 3°C of true value
- Barometer: Within 0.1 in. Hg of mercury-in-glass barometer

17B - 37

**Method 25  
Sampling Train Preparation**

- Leak check the tank (#1)
- Assemble the sampling train
- Leak check the entire sampling train

17B - 38

**Method 25  
Train Preparation**

- Evacuate sample tank to 10 mm Hg. Record on field test data sheet (FTDS). Set aside and recheck within 1 hour. Should be within 2 mm of previous reading
- Just before train assembly, measure tank vacuum

17B - 39

**Method 25  
Train Preparation**

- Assemble sampling system; immerse condensate trap in dry ice ~ 30 minutes before sampling
- Plug probe tip

17B - 40

**Method 25  
Train Preparation**

- Evacuate sampling system from probe tip to valve to 10 mm Hg
- Close purge valve, turn off pump, wait 10 minutes
- Record  $\Delta P$ . Vacuum should not change more than 2 mm to be acceptable

17B - 41

**Method 25  
Train Preparation**

- Calculate maximum allowable pressure change based on leak rate of 1% and compare to measured  $\Delta P$
- Record findings on FTDS

17B - 42

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

**Method 25 Sampling**

- Mark probe for point of average stack gas velocity (probe  $\leq$  36 in. as specified in FRM 25)
- Check dry ice level (Maintain as high level as possible)
- Calculate flow rate, record time, set flow rate, probe temp, and filter

17B - 43

**Method 25 Sampling**

- Attach trap to sampling train
- Position probe tip perpendicular to stack gas flow (Take plug off end)
- Purge sampling train, then adjust flow rate

17B - 44

**Method 25 Sampling**


- Record sample tank vacuum, flow meter settings, and temperatures at 5 - minute intervals on FTDS
- Adjust the flow rate as necessary to maintain a constant rate,  $\pm 10\%$  over duration
- Sampling rate between 60-100 mL/min (i.e., 3.6 to 6.0 L of total sample acquired)
- After sampling, record final readings

17B - 45

**Method 25 Sampling**

- Recover components, disconnect sample tank, record tank vacuum
- Disconnect condensate trap, seal both ends with brass fittings
- Record final readings on FTDS and chain-of-custody
- Pack trap in dry ice during storage and shipping

17B - 46



Simplified Schematic of NMO Analyzer  
17B - 47

**Method 25 Sample Analysis**

- Condensable organics in the trap are vaporized and oxidized to CO<sub>2</sub> and collected in a separate (#2) evacuated tank
- The CO<sub>2</sub> (which are the original condensable organics from sampling) in #2 tank is then injected into the NMO analyzer, reduced to methane, and detected with an FID

17B - 48



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17B: Federal Reference Method 25

### Method 25 Sample Analysis

- Non-Condensable Organics
  - The non-condensable sample in the original field sample tank (#1) is injected into the analyzer
  - Methane, CO, CO<sub>2</sub>, and NMOC are separated, and the NMOC fraction is then back-flushed, oxidized to CO<sub>2</sub>, reduced to methane and detected with an FID

17B - 49

### Method 25 Apparatus


- Analytical System
  - Oxidation system for recovery and conditioning of condensate trap contents
    - Heat source
    - Oxidation catalyst (chromia @ 650 °C)
    - Non-dispersive infrared analyzer (NDIR)
    - Intermediate evacuated canister (#2)

17B - 50

### Method 25 Apparatus




- NMO Analyzer
- GC with back-flush capability
- Oxidizing/reducing catalyst (Ni @ 400 °C)
- FID

17B - 51



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

---







### Initial Performance Check of Condensate Recovery and Conditioning Apparatus

- Carrier gas and auxiliary oxygen blank (< 5 ppm contaminants)
- Catalyst efficiency check with 1% methane ( $\pm 2\%$ )
- System performance check
  - Hexane, toluene, methanol ( $\pm 5\%$ )

17B - 63

### Daily Performance Tests

1

#### Condensable organic recovery system

- Leak test
- System background test
- Oxidation catalyst efficiency test

2

#### NMO analyzer daily calibration

- CO<sub>2</sub> response calibration (CO<sub>2</sub>/methane)
- NMO response calibration (Propane)

17B - 64

### Condensable Organic Fraction Recovery

- Recovery of condensable organics is accomplished in two stages
  - Condensate trap is purged of CO<sub>2</sub> (< 5ppm) while cooling the trap in dry ice and put into original field tank (#1)
  - Condensate organics are volatilized and converted catalytically to CO<sub>2</sub> which is collected in an intermediate collection vessel (ICV or #2) for analysis

17B - 65

### Condensable Organic Fraction Recovery

- Trap purge and sample tank pressurization
  - Obtain sample tank and condensate trap
  - Set zero air flow to 100 mL/min
  - Attach the sample tank (#1) to the condensate trap recovery system

17B - 66

### Condensable Organic Fraction Recovery

- Measure sample tank pressure
- Immerse the condensate trap in crushed dry ice
- Observe IR response to CO<sub>2</sub> to minimum level of < 5 ppm
- Pressurize sample tank (#1) to 1060 mm Hg absolute pressure and detach

17B - 67

### Condensable Organic Fraction Recovery

- Recovery of condensible organics
  - Attach an ICV (i.e., #2 tank) to the trap recovery system and evacuate to 10 mm Hg
  - Set auxiliary oxygen flow to 150 mL/min
  - Switch 4-port valve to collect position

17B - 68

### Condensable Organic Fraction Recovery

- Remove condensate trap from dry ice and allow to warm to room temperature
- Heat trap by placing it in a furnace at 200 °C

17B - 69

### Condensable Organic Fraction Recovery

- Recovery of condensable organics
  - After NDIR analyzer indicates a CO<sub>2</sub> concentration of < 10,000 ppm, begin heating the tubing that connects the condensate trap to the oxidation catalyst with a heat gun

17B - 70

### Condensable Organic Fraction Recovery




- Continue trap heating and purging until the CO<sub>2</sub> concentration is below 10 ppm
- Pressurize the ICV (i.e., #2) to approximately 1060 mm Hg

17B - 71



17B - 72

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**





**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

**Method 25 Apparatus**


- Method 25 NMO Analyzer Apparatus
  - GC with back-flush capability
  - Oxidizing catalyst (19 % chromia on alumina @ 650 °C)
  - Reducing catalyst (Ni @ 400 °C)
  - FID

17B - 79

**Method 25 Sample Analysis**

- Both Tanks (#1: Sample) and #2 (ICV)
  - Sample in both tanks (#1 and #2) are injected into the NMO analyzer
  - Methane, CO, CO<sub>2</sub>, and NMOC are separated, and the NMOC fraction is then back-flushed, oxidized to CO<sub>2</sub>, reduced to methane, and detected with an FID
  - Original tank (#1) only NMO quantified

17B - 80



17B - 81

**Method 25 Analysis**

- ICV (i.e., #2) Analysis
  - Attach the ICV (#2) to the 10-port gas sampling valve
  - Purge sample loop
  - When detector response returns to near baseline after CO<sub>2</sub> peak, back-flush and increase column oven temperature

17B - 82

**Method 25 Analysis**

- After detection of any NMOC, return column oven temperature to 85°C
- Record the CO<sub>2</sub> peak area and NMO peak area
- Repeat analysis two additional times

17B - 83

**Method 25 Analysis**

- Sample Tank (#1): Same as ICV (#2)
  - Inject triplicate samples from the sample tank and record the values obtained for nonmethane organics only
  - Perform three analyses and average the NMO values

17B - 84



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17B: Federal Reference Method 25

### Method 25 Calculations

- Sample volume
- Noncondensable organics
- Condensable organics
- Total gaseous nonmethane organics
- Percent recovery
- Relative standard deviation
- EPA provides audit sample

17B - 85



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

---

**Method 25 QC Checks**

**1. Oxidation Catalyst Efficiency Test**

1 % CH<sub>4</sub>

Oxid./Red. Cat. Unheated (R1)

Oxid Cat. Heated (R2)

Oxid. Cat. Eff. =  $R1 - R2/R1 \times 100$

17B - 91

**Method 25 QC Checks**

**2. Reduction Catalyst Efficiency Test**

1 % CH<sub>4</sub>

Oxid. Cat. Unheated + Red. Cat. Heated (R4)

Oxid./Red. Cat. Heated (R3)

Red. Cat. Eff. =  $R4/R3 \times 100$

17B - 92

**Method 25 QC Checks**

**3. NMO Response Linearity Test**

20, 200, 3000 ppm propane standard

Response Factor (RF) within 2.5 % over range, then linear response

17B - 93

**Method 25 QC Checks**

**4. CO<sub>2</sub> Response Linearity Test and Initial Calibration**

50, 500, 10,000 ppm CO<sub>2</sub> standard

Response Factor (RF) within 10 % over range, then linear response

17B - 94

**Method 25 QC Checks**

**5. NMO Analyzer Performance (ppmC)**

Std #1: 50 ppm CO, 50 ppm CH<sub>4</sub>, 2 % CO<sub>2</sub>, 20 ppm Propane

Std #2: 50 ppm Hexane

Std #3: 20 ppm Toluene

Std #4: 100 ppm Methanol

Criteria: ± 5%

17B - 95

**Method 25 QC Checks**

**6. Condensable Organic Recovery System Check**

Stage #1: Carrier Blank Check (< 5 ppm)

Stage #2: Oxidizing Catalyst

Stage #3: Known Organic Concentration

17B - 96

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

---

### Method 25 Daily QC Checks

1. Leak test of condensable recovery system (< 10 mm Hg for 10 minutes)
2. System background check (Syringe of gas < 10 ppm CO<sub>2</sub>)
3. Oxidation catalyst efficiency check
4. CO<sub>2</sub> analyzer response
5. NMO response check

17B - 97

### Method 25 Guide

- Make sure tanks, traps, and sample trains are clean (< 1 ppm)
- Analyze confirmation preferred
- Leak check sampling trains in the field, even though they are checked in the lab

17B - 98

### Method 25 QC Checks

#### EPA Audit Sample (2)

Between 50 % below standard and 100 % above standard ± 20% of known concentration

17B - 99

### Method 25 Guide

- Leak check cold (minimize heating/re-cooling system)
- Leak check before adding trap
- Leak check canisters before use in field
- Leak check with rotameter completely open

17B - 100

### Method 25 Guide

- Setup sampling train properly
- DO NOT over-tighten the filter or the swage fittings
- If there is a leak, go to last fitting disturbed
  - Use logical approach to find leak
  - Isolate specific areas in the sample train

17B - 101

### Method 25 Guide

- Get most accurate pre-test and post-test barometric pressures, tank vacuums, and temperature possible
- Used in sample volume

17B - 102

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

---

**Method 25 Guide**

- Use small pellets of dry ice around the trap to increase contact to trap organics
  - This will generate better results (esp. oxygenated organics)

17B - 103

**Method 25 Guide**

- Monitor both sample flow and tank vacuum with the rotameter and gauge on the unit
- Vacuum gauge is not accurate, but used as an indicator of proper sampling

17B - 104

**Method 25 Guide**

- Take care that the brass caps from the traps don't come into contact with pump oil, vacuum grease, or other contaminants
- Use tags to identify the tank/trap pairing, as well as noting the pairings on the sample data sheet

17B - 105

**Method 25 Guide**

- Seal both arms of the trap with the brass caps and pack the cooler with sufficient dry ice to ensure the temperature is maintained until receipt at the labs

17B - 106

**Method 25 Guide**

- Perform Method 25 gas audits prior to field sampling to minimize carryover of contaminants from a dirty sampling train (Audit through sample train)
- If sampling blanks are part of the program, a preferred method is to collect a clean air sample over a one-hour period using the project sampling train components (i.e., blank train)

17B - 107

**Method 25 Guide**

- If high concentrations are expected, then collect only 3.5 L sample
- If low concentrations are expected, then collect larger volume of gas (Increase trapped sample volume)

17B - 108

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

---

**Method 25 Guide**

- If very high moisture is expected, then add an ice water second trap in front of the cryogenic trap to prevent freezing water from plugging the sample flow

17B - 109

**Method 25 Guide**

- However, this increases analytical cost and may increase the positive bias from trapping CO<sub>2</sub>
- This approach does appear to limit sampling problems

17B - 110

**Observations**

- Obtain the most accurate pre-test and post-test barometric pressure, tank vacuums, and temperatures. This data determines the volume of gas sampled. Don't use gauge on control box for tank vacuum measurement...it isn't accurate enough and affects final volume sampled
- Do not over tighten swage-lock fittings as part of the sample train

17B - 111

**Observations**

- A pre-test leak check is required. Suggest set-up everything and leak check without the dry ice and condensate trap. This limits the number of components that might leak
- Method suggest purge the probe for 10 minutes at 60-100 cc/min. If the source has high moisture, then purge only for 5 minutes to minimize possible freezing of trap

17B - 112

**Observations**

- FRM 25 requires you to evacuate the sample tank to <10 mm Hg absolute. Need laboratory pump and may take several attempts and 5 minutes to reach that value
- Purchase dry ice in small pellets. Pack the condensate trap to top of weld and cover dry ice during sampling with aluminum foil

17B - 113

**Observations**

- Make sure that the sample canister and condensate trap are both labelled properly with the same sample run. The VOCs are determined from both components for that single sample run
- If sampling a high particulate source, then change the filter after each run to minimize potential biases in the analysis

17B - 114

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17B: Federal Reference Method 25**

---

---

**Observations**

- If you are sampling a source with high moisture (> 20%) and high CO<sub>2</sub> (>20%), then there is a real possibility that your trap will freeze at the very top of the trap.
  - Use hair dryer to unfreeze trap
  - Remove foil and let the sun melt the plug at the top of the trap
  - Add a dry water impinger in front of the condensate trap. However, must analyze content of that trap also

17B - 115



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17C: Federal Reference Method 25A**

---

---

**U.S. EPA APTI  
Compliance Test and Source  
Test Observation**

**Federal Reference  
Method 25A**

Determination of Total Gaseous  
Organic Concentration Using A Flame  
Ionization Detector (FID)

17C - 1

**Family of Method 25s**

- FRM 25: Total VOCs
- FRM 25A: Instrumental FID
- FRM 25B: Instrumental NDIR
- FRM 25C: Landfill Gases
- FRM 25D: VOC Waste Sample
- FRM 25E: VOC Waste Sample

17C - 2

**Method 25A Timeline**

- Proposed 12/17/80
- Promulgated 08/18/83

17C - 3

**FRM 25A**

- Originally developed to determine compliance with VOC emission standards for bulk gasoline terminals
- FRM 25A not recommended for high moisture (> 40 % by volume)
- High organic droplets in gas stream can cause high bias or data variability

17C - 4

**FRM 25A Uses**

- Incinerators
- Carbon Adsorption Units
- Coating and Printing Operations
- Web Offset Presses
- Method 25A measures total hydrocarbons (THCs) (i.e., non-compound specific)

17C - 5

**Applicability**

- This method is applicable to the measurement of total gaseous organic concentration of vapors consisting primarily of alkanes, alkenes, and/or arenes (aromatic hydrocarbons)
- Only measures C-H bond very well and analytes that can generate a response factor (RF)

17C - 6

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17C: Federal Reference Method 25A**

---

---

**Applicability**

- Results from the use of FRM 25A are expressed in terms of volume concentration of propane (or other appropriate organic calibration gas) or in terms of carbon

17C - 7

**Applicability**

- Results from FRM 25A are measured on a wet basis and the concentration must be adjusted for the percent moisture in the sample gas stream for the purpose of emission calculations

17C - 8

**Applicability**

- FRM 25A “...can only be used where an appropriate response factor for the stack gas can be determined”

17C - 9

**Instrument Response Factors (RF)**

- The instrument response factor for the compound of interest is determined by:
  - Response Factor (RF) = (Act. Conc.) / (Instru. Observ. Conc.)
  - Typical RF:
    - Benzene: 0.29
    - Chloroform: 9.28
  - M25A requires RF determination

17C - 10

**Agency Example RF Application**  
(Surface Coating Operation)

- Four analytes which you know % of solvent used in mixture
- Standard prepared with that same percent ratio in mixture in gas std.
- Response of analyzer in ppm as carbon
- Concentration of gas stream is determined by dividing by RF

17C - 11

**Applicability**

- The concentration is expressed in terms of propane (or other appropriate organic calibration gas) or in terms of carbon
- Measurement is made on a wet bases and emissions must be adjusted accordingly to dry bases
- Span value of the analyzer is usually 1.5 to 2.5 times the applicable emission limit

17C - 12

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17C: Federal Reference Method 25A**

---

---

**FRM 25A Items**

- Calibration for FRM 25A should be done using EPA Traceability Protocol gas standards, preferably propane
- The sample line should be heated ( $\geq 110^{\circ}\text{C}$ ) to prevent any condensation. Heating above 400 F is not required.

17C - 13

**FRM 25A Items**

- A system bias check is required and is performed by introducing the bias check standard directly into the FID and then through the entire sampling system, excluding the probe. Results must agree within 5 % to be acceptable

17C - 14

**FRM 25A Items**

- The bias check standard must be representative of the effluent (i.e., boiling point, solubility, chemical reactivity etc.). Propane may be used if effluent is unknown.

17C - 15

**FRM 25A Items**

- For the bias test, propane should be used at the following processes:
  - Incinerators, boilers, asphalt plants, cement plants and resource recovery facilities.
- For the bias test, propane should NOT be used at the following processes:
  - Bakeries (using yeast), ethylene oxide sterilizers, chemical manufacturing facilities (HON/SOCMI), surface coating operations, and graphic arts operations

17C - 16

**FRM 25A Items**

- Calibration error test must be performed within 2 hours of start of testing
  - Introduce zero and high-level standard, adjust
  - Introduce low and mid-level standard, no adjustment. Criteria of 5 %
- Perform response time test at same time as calibration error test for zero and high-level standard. Repeat 3 times and record. Typically, < 1 minute

17C - 17

**FRM 25A Items**

- Drift determination is determined each hour during the test
  - Introduce zero and mid-level gas standards
  - Criteria: < 3 %
- Location of sampling point can be a single point (> 1.5 meters from inside wall of stack) or raked probe (16.7, 50, 83.3 %)

17C - 18

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17C: Federal Reference Method 25A**

**Wet Bases to Dry Bases**

- Wet bases measurement emissions to dry bases measurement emissions:

$$C_{s(dry)} = \frac{C_{s(wet)}}{(1-Bws)}$$

$$C_{s(dry, STP)} = \frac{C_{s(wet)}}{(1-Bws)} \times \frac{(T_s)(P_{std})}{(T_{std})(P_s)}$$

17C - 19

**Principle**

- A gas sample is extracted from the source through a heated sample line and filter to a total hydrocarbon analyzer (THC) containing a flame ionization detector (FID)
- All sampling components leading to the analyzer shall be heated  $\geq 110^{\circ}\text{C}$  ( $220^{\circ}\text{F}$ )
- The flame ionization detector block shall be heated  $>120^{\circ}\text{C}$  ( $250^{\circ}\text{F}$ ).

17C - 20

**Principle**

- Sampling is performed on a continuous, real-time basis with results proportional to the carbon content of the sample stream passing through the detector on a wet bases
- FID is linear from 0-10,000 ppm (If higher concentrations, then use dilution system)
- Method 25A is good up to about 40 % moisture in the stack gas


17C - 21

**FID Theory**

- Basic Theory:
  - Sample is introduced into an ionization chamber and burned
  - Process separates free ions
  - Free ions are attracted to a collecting electrode
  - Collection of the ions results in an increased current which is proportional to the concentration of the compound
  - By-products are  $\text{H}_2\text{O}$  and  $\text{CO}_2$


17C - 22

**Diagram of FID**



17C - 23


**Flame Ionization Detection**



- Advantages
  - Wide dynamic and linear range (0-10,000 ppm)
  - Highly sensitive to hydrocarbon vapors
  - Very stable and repeatable
  - Unaffected by ambient levels of  $\text{CO}$ ,  $\text{CO}_2$  and water vapor

17C - 24

## Flame Ionization Detection



### Disadvantages

- Requires oxygen > 16% to operate
- Total hydrocarbon detector - not specific

17C - 25

## Principle

- FRM 25A results are measured on a wet basis and the concentration must be adjusted for the percent moisture in the sample gas stream for purposes of emission calculations

17C - 26

## Principle

- In general alkanes, alkenes, and aromatics are the most appropriate compound groups for FRM 25A sampling and analysis
- May also be used on C, H & O compounds. Ethanol gives ~ 60% signal to that of propane, but can still be used for ethanol

17C - 27

## FRM 25A Limitations

- Sensitivity greatest for the alkane, alkene, and aromatic organic compounds
- FRM 25A can only be used in situations where an appropriate response factor for the stack gas constituents can be determined

17C - 28

## FRM 25A Limitations

- Gas streams with high moisture (> 40%) can affect response of the FID
- Limitations of the FID. FID response is different for different analytes
- Large quantities of methane present gives questionable results
- Sample gas needs O<sub>2</sub> (> 16 %) for combustion in the FID

17C - 29

## FRM 25A Sampling System

- Sample Probe: A heated (> 250°F) stainless steel, three-hole rake type probe. Holes should be 4 mm diameter or smaller and located at 16.7, 50, and 83.3% of the equivalent stack diameter
- Alternatively, a single opening probe may be used so that a gas sample is collected from the centrally located 10% area of the stack cross-section

17C - 30

### Options for Sampling Point

- Single point in centroid of stack
- Single point at average velocity of stack gas
- Rake probe (i.e., 16.7%, 50%, and 83.3% of the equivalent stack diameter)
  - Therefore, FRM 2 needed to determine cyclonic flow and velocity of stack gas

17C - 31

### FRM 25A Sampling System

- Sample Line: Heated (> 250°F) stainless steel or Teflon® tubing
- All components must be heated > 250°F so moisture and organics don't drop out of the gas stream
  - Check unions for cold spots
  - Check for unheated transfer line
  - Check for sudden spiking at steady state conditions
  - Check for unheated filter

17C - 32

### Sampling System

- Calibration Valve Assembly: A heated (> 250°F) three-way valve at exit of probe assembly to direct the zero and calibration gases to the analyzer
- Particulate Filter: An in-stack or an out-of-stack heated (> 250°F) glass fiber filter assembly
- Pump: A heated (> 250°F) leak-free diaphragm type

17C - 33

### Sampling System

- Organic Concentration Analyzer: A heated (> 250°F) total hydrocarbon analyzer (THC) with a flame ionization detector (FID)
- Recorder: A strip-chart, digital recorder, or computer for recording measurement data

17C - 34

### FRM 25A Gases

- Fuel: 40% H<sub>2</sub>/60% He or 40% H<sub>2</sub>/60% N<sub>2</sub>
- Zero Air: High purity air with less than 0.1 ppmv of organic material (propane or carbon equivalent)
  - Most systems use 100% H<sub>2</sub> as the fuel which makes for a hotter flame

17C - 35

### Gases

- Calibration Gases (i.e., propane in air/N<sub>2</sub>)
  - Low-level calibration gas: An organic calibration gas with a concentration equivalent to 25 to 35% of the applicable span value
  - Mid-level calibration gas: An organic calibration gas with a concentration equivalent to 45 to 55% of the applicable span value

17C - 36



### Gases

- High-level calibration gas: An organic calibration gas with a concentration equivalent to 80 to 90% of the applicable span value

(Note: Use hydrocarbon/air standards; Propane/N<sub>2</sub> may yield inaccurate results!)

17C - 37

### Steps to Perform An Analysis

- Analysis of PE sample not mandatory, but suggested, due to calibration gases are NIST traceable!
- Leak Check System not mandatory but suggested!
- Calibration Error Test (With Propane):  $\pm$  5% of calibration gas value

17C - 38

### Steps to Perform An Analysis

- Response Time Test: 1-2 minutes; traditionally < 1 min; No specifications in FRM 25A
- Calibration Drift (Zero/Mid-span Gas)Test (No adjustments allowed to analyzer):  $\pm$  3% of span value

17C - 39

### Pre-test Requirements

- Sampling Site: Located as required by the specific regulations (i.e., exhaust stack, inlet line etc.)
- Method 1

17C - 40

### Pre-test Requirements

- Assemble the sampling system following manufacturer's specification
- Prepare sample interface from stack to extraction system
- Make system operable

17C - 41

### Pre-test Requirements

- All delivery pressures of the gases to the THC/FID system must be maintained at the same value used during calibration and sampling

17C - 42

### First Step To Perform An Analysis

- Leak Test of System: Perform both positive and negative leak check of sampling and analytical system
  - 1. Vacuum: Attach manometer to probe inlet, pull 2 in. of Hg vacuum; no leak for 1 minute
  - 2. Pressure: After pump, apply pressure and use soapy water to determine leaks at all joints/connections

17C - 43

### Pre-test Requirements

- After leak test of system, place probe at centroid of stack, pipe, or duct and is sealed tightly

17C - 44

### Remember Sampling Point Options!

- Single point in centroid of stack
- Single point at average velocity of stack gas
- Rake probe (i.e., 16.7%, 50%, and 83.3% of the equivalent stack diameter
  
- FRM 2 needed to determine cyclonic flow and velocity of stack gas

17C - 45

### Calibration of M25A

- Calibration of THC/FID Analytical System: Generate a series of high, mid, and low range calibration gases of known concentrations spanning the linear range of the FID and introduce at the calibration valve assembly to the THC/FID
  - The analytical range must be chosen so that the source THC limit is 10 to 100% of the range
  - Calibration must be done on-site to determine RFs

17C - 46

### Second Step To Perform An Analysis

- Calibration Error Test (Response to True Value):  
Perform a calibration error test (within 2 hours of the start of the test) by introducing the zero and high-level calibration gases to the analyzer

17C - 47

### Pre-test Calibration Error

- Calibration
  - The calibration gases are usually propane in air, propane in nitrogen, or methane in air or nitrogen
  - Perform three injections each of the calibration gases
  - Calibration gases must be NIST traceable; Therefore, no method does not require a PE sample

17C - 48

### Pre-test Calibration Error

- Calibration
  - Generate calibration curve from the three injections performed in the calibration of the analytical system
  - Develop a "calibration factor" for each level of the injected calibration gases (the calibration factor should fall between 0.95 and 1.05 to be acceptable)

17C - 49

### Pre-test Calibration Error

- Inject zero and high level (80-90 % of span value) at the calibration valve
- Adjust the analyzer output to the appropriate levels
- Introduce the mid and low-level calibration gases
- Make no adjustments to the analyzer
- If system is linear, differences should be < 5%

17C - 50

### Pre-test Calibration Error

- If can't meet < 5% of the calibration gas concentration value, then system must be replaced or repaired
- No adjustments can be made to the system after the calibration error test and before the calibration drift test
  - If adjustments are required, perform the calibration drift test prior to the adjustments and repeat the calibration drift test after the adjustments

17C - 51

### Third Step To Perform An Analysis

- Response Time Test: Response time test is used to document response of gases by the THC/FID analytical system
  - Introduce zero gas at the calibration valve assembly
  - When the system output has stabilized, switch quickly to the high-level calibration gas

17C - 52

### Pre-test Requirements

- Record the time from the concentration change to the measurement system (no limit specified, just determine)
- Repeat the test three times
  - Just record results
- Response time should be < 1 minute, but can be 1-2 minutes
  - FRM 25A does not specify limit

17C - 53

### Fourth Step To Perform An Analysis: Sampling

- Purge the sample system for a period of time longer than the response time of the system
- Mark the start time on the data recorder after purging. Remember, all delivery pressures of the gases to the THC/FID system must be maintained at the same value used during calibration and sampling
- Begin sampling!!!

17C - 54

### Fifth Step To Perform An Analysis: Post-test

- Calibration Drift Determination: Immediately following completion of the test period (and hourly during the test), perform a calibration drift test
  - Reintroduce the zero and mid-level calibration gases, one at a time, to the measurement system at the calibration valve

17C - 55

### Post-Test Procedures

- Make no adjustments to the instrument, just record response
- If drift exceeds 3% (span value) for either gases, invalidate the test results preceding the check
  - If you fail drift test during run, then void sample to that point from the last acceptable drift test, recalibrate, and then continue!

17C - 56

### Organic Concentration Calculations

- Calculated as ppm<sub>v</sub> as carbon

$$C_c = K C_{\text{meas}}$$

Where:

- K = 1 for methane
- K = 2 for ethane
- K = 3 for propane
- K = 4 for butane
- K = Appropriate response factor for other organic calibration gases

17C - 57

### Agency Bias Check

- Agency bias check is not required by FRM 25A
- Bias check procedure:
  - Introduce bias gas standard at back of analyzer
  - Introduce bias gas standard through entire sampling system
  - If results agree within 5% of bias gas standard concentration, then PASS!

17C - 58

### Agency Bias Check

- Bias gas standard must be representative of the effluent as a whole with regard to BP, water solubility, and chemical reactivity
- Propane may not be used for the following facilities:
  - Bakeries, ethylene oxide sterilizers, chemical manufacturing facilities, surface coating operations and graphic arts operation

17C - 59

### Method 25A Notes

- The use of Method 25A usually must be justified to regulatory agencies instead of using Method 25. Key points would be:
  - Expected concentration < 50 ppm
  - VOCs known to consist of C and H
  - (CO<sub>2</sub>)(H<sub>2</sub>O) > 100 %
- Set-up instrument in environmentally controlled room to minimize instrument drift

17C - 60

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17C: Federal Reference Method 25A**

---

---

**Method 25A Notes (Contd)**

- To minimize condensation of VOCs in the analytical system, keep at least 10 °F hotter than rest of system
- Protocol 1 standard should be used for calibration, but other standards allowed if manufacturer certified accurate is 2 %
- Void test run if using expired standards....but!

17C - 61

**Method 25A Notes (Contd)**

- The entire sampling system (probe, heated sample lines, valves and manifolds) must be maintained at stack temperature or 250 °F (May go hotter/Web Offset Presses..350 °F)
  - Actual temperature of each component may want to be recorded every 15 minutes and included in final test report

17C - 62

**Method 25A Notes (Contd)**

- Agency may require a system bias check conducted with a certified standard that has properties (boiling point, water solubility, and reactivity) similar to the effluent as a whole. *Propane is not normally acceptable by regulatory agencies!*
  - Concentration of the system bias check standard must be similar to the concentration of the stack

17C - 63

**Method 25A Notes (Contd)**

- The analyzer temperature and pressure must be the same during sampling as it was during calibration
- Pollutant concentration must be measured on a wet basis and reported on a dry bases
- Any run in which the average VOC concentration exceeds the span must be voided

17C - 64

**Method 25A Notes (Contd)**

- For Destruction Efficiency (DE) Testing:
  - The same sampling method should be used; The outlet test location determines the method (i.e., concentration, % H<sub>2</sub>O etc.)
  - The results (lbs/hour) at both the inlet and outlet must be on the same bases (as propane or as VOCs)

17C - 65

**Method 25A Notes (Contd)**

- The actual emissions should be determined if at a VOC coating source:

$$\text{Emission Rate} = \{(\text{Coating Usage}) \times (\text{Coating Usage}) \times (1 - \text{DE}) \times (\text{CE})\} + \{(\text{Coating Usage}) \times (\text{VOC Content}) \times (1 - \text{CE})\}$$

17C - 66

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17D: Weakness - Strengths of FRM 18, 25, 25A

### U.S. EPA APTI Compliance Test and Source Test Observation

Weakness/Strengths FRMs 18, 25, & 25A



17D - 1

### Lecture Objectives



17D - 2

### Background

- FRM 25 - measures total VOC
- FRM 25A - measures total hydrocarbons (THC)
- FRM 18 - measures individual organic compounds

17D - 3

### Background

- Generally, "stack testing" is performed using FRM 25A or FRM 18
- FRM 25/25A were created in order to determine the removal efficiency of a control device

17D - 4

### Background

- Typically, once a method is promulgated (and sometimes before it is) the method will be used for a variety of purposes including functions that it was not designed to perform
- FRM 25 and FRM 25A are not applicable to mass emission rate

17D - 5

### Background

- FRM 25
  - Samples are time integrated
  - Analysis is completed off site
- FRM 25A
  - Sampling is continuous
  - Analysis is done on site

17D - 6



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17D: Weakness - Strengths of FRM 18, 25, 25A**

---

---

Background

- FRM 18
  - Samples can be time integrated or semi-continuous
  - Analysis can be on site or off site

17D - 7

Background

- FRM 25
  - All compounds are converted to methane before measuring with an FID
- FRM 25A
  - All compounds are measured directly, as a whole, with an FID

17D - 8

Background

- FRM 18
  - Each compound is separated and measured individually with an FID

17D - 9

FRM 25 & 25A

- The FID can be applied to the determination of the mass concentration of the total molecular structure of the organic emissions under any of the following limited conditions

17D - 10

FRM 25 & 25A

- Where only one compound is known to exist
- When the organic compounds consist of only hydrogen and carbon

17D - 11

FRM 25 & 25A

- Where the relative percentages of the compounds are known or can be determined, and the FID responses to the compounds are known

17D - 12

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17D: Weakness - Strengths of FRM 18, 25, 25A

### FRM 25 & 25A

- Where a consistent mixture of the compounds exists before and after emission control and only the relative concentrations are to be assessed
- Where the FID can be calibrated against mass standards of the compounds emitted (solvent emissions, for example)

17D - 13


### Advantages: FRM 25

- Measures only VOC (excludes Methane)
- Responds equally to all VOC

17D - 14

### Disadvantages: FRM 25

- Potential positive bias that may vary according to source category
- Relatively poor precision



17D - 15

### Advantages: FRM 25A

- Very good precision
- Real time analysis
- Relatively low detection limit

17D - 16

### Disadvantages: FRM 25A

- Does not respond equally to all VOC
- Requires a separate measurement of Methane to convert THC to VOC

17D - 17

### Advantages: FRM 18

- Good precision
- Low detection limits
- Can exclude methane

17D - 18

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17D: Weakness - Strengths of FRM 18, 25, 25A

---

### Disadvantages: FRM 18

- Measures individual organic compounds - not total VOC
- Requires calibration standards for all measured compounds

17D - 19

### General Guidance

USEPA Guidance Document 033

([www3.epa.gov/ttn/emc/guidlnd/gd-033.pdf](http://www3.epa.gov/ttn/emc/guidlnd/gd-033.pdf))

- Use FRM 25 for unknown mixtures with concentrations greater than 50 ppm
- Use FRM 25A for unknown mixtures with concentrations less than 50 ppm

17D - 20

### General Guidance

- Use any of the methods for known mixtures with the following conditions
  - FRM 25 should only be used for concentrations greater than 50 ppm

17D - 21

### General Guidance

- Use any of the methods for known mixtures with the following conditions
  - FRM 25A should be calibrated with the known mixture or the results mathematically corrected for varying response factors

17D - 22

### General Guidance

- Use any of the methods for known mixtures with the following conditions
  - FRM 18 must be calibrated for each of the compounds in the mixture

17D - 23

### Summary

- None of the existing methods for measuring VOCs are perfect
- Because their problems can be source specific, we may have to approve alternative methods for some sources
- We must continue to improve the existing methods

17D - 24

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 17D: Weakness - Strengths of FRM 18, 25, 25A**

---

---

**Reporting VOCs**

- Many state agencies require reporting “as VOCs;” or as “carbon, methane; or propane” or “make up your own!”
- One must know how the state wants data reported for VOC emissions
- Volatile organic compounds as defined in 40 CFR 51.100

17D - 25

**Reporting VOCs**

- The reporting format of the data must be known prior to accepting test data
  - Mass emission rates - lb/hr as carbon, methane, or propane?
  - Mass emission rates - lb/hr “as VOC”

17D - 26

**Case Study Molecular Weight - FRMs 25 & 25A**

- Emissions testing was performed and submitted in support of a permit application
- Gas Stream consisted of ~ 100 VOCs
- Total VOCs per FRM 25A = 2.5 lb/hr as carbon

17D - 27

**Case Study**

- One speciated compound per a compound specific test was emitted at 5 lb/hr
- Outcome
  - Facility adjusted the reported VOC emission rate using a MW that was considered ‘average’ for the pollutant gas stream (avg MW of the VOCs)

17D - 28

**Case Study**

- Using the MW of carbon for mass emission rate calculation
- Consider Propylene Glycol ( $\text{CH}_3\text{CH}(\text{OH})\text{CH}_2\text{OH}$ )
- Molecular Weight is 76.10
- Assume: Concentration = 100ppm
- Qsd of 100,000 dscfm

17D - 29

**Case Study**

- lb/hr “as carbon” (MW=12) = 18.7 lb/hr.
- lb/hr “as VOC” (MW=76.1/3) = 39.57 lb/hr.
- An error in excess of 100% due only to MW

17D - 30

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 17D: Weakness - Strengths of FRM 18, 25, 25A

---

### Case Study

- Identification of a major concern with the reporting of VOCs when using FRMs 25 & 25A
- Propose using a molecular weight adjustment
- Every organic will weigh more than just carbon

17D - 31

### Other Errors Involving FRM 25 & 25A

- “Response factor” error associated with FRM 25A
- The flame ionization detector (FID) used in FRM 25A does not give a 1:1 response with all organics

17D - 32

### FRM 18 Reporting of VOCs

- FRM 18 measures specific VOCs
- Requires knowledge of the pollutant gas stream
- Can only measure VOCs for which the GC/specific detector has been calibrated

17D - 33

### FRM 18 Reporting

- Difficulties
  - Sources claim that they only need to measure “total VOCs” - not speciated
  - What to do with a “soup” of VOCs?

17D - 34

### Summary VOC Methods

- FRM 25
  - Measures Total VOC (> 50 ppm)
- FRM 25A
  - Measures Total Hydrocarbons (THC) (10-100 ppm)
- FRM 18
  - Measures Individual Organic Compounds (Sub-ppm)

17D - 35

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 18: Lesson 18 FRM 204. PTE-TTE, Enclosures, Capture Efficiency-

### Calculations

#### U.S. EPA APTI Compliance Test and Source Test Observation

#### FRM 204 PTE/TTE Enclosures, Capture Efficiency /Calculations

18 - 1

#### USEPA Method 204

- Procedure used to determine whether a permanent or temporary enclosure meets the criteria for a total enclosure.
- An enclosure is evaluated against a set of criteria. If the criteria are met and if all the exhaust gases from the enclosure are ducted to a control device, then the volatile organic compounds (VOC) capture efficiency (CE) is assumed to be 100 percent, and CE need not be measured.

18 - 2

#### Natural Draft Opening (NDO)

- Natural Draft Opening (NDO). Any permanent opening in the enclosure that remains open during operation of the facility and is not connected to a duct in which a fan is installed.

*Equivalent diameter*

$$ED = \sqrt{\frac{4 \cdot A}{\pi}} \quad (\text{Circle or square/rectangle})$$

or

$$ED = \frac{2LW}{(L+W)} \quad (\text{square/rectangle})$$

18 - 3

#### Permanent Total Enclosure (PTE)

- Permanently installed enclosure that completely surrounds a source of emissions such that all VOC emissions are captured and contained for discharge to a control device.

18 - 4

#### Criteria for Permanent Total Enclosure

1. Any NDO shall be at least four equivalent opening diameters from each VOC emitting point unless otherwise specified by the Administrator.
2. The total area of all NDO's shall not exceed 5 percent of the surface area of the enclosure's four walls, floor, and ceiling.
3. The average facial velocity ( $F_v$ ) of air through all NDO's shall be at least 3,600 m/hr (200 fpm). The direction of air flow through all NDO's shall be into the enclosure.
4. All access doors and windows whose areas are not included in section 5.3 and are not included in the calculation in section
5. shall be closed during routine operation of the process
6. All VOC emissions must be captured and contained for discharge through a control device

18 - 5

#### Permanent Total Enclosure



18 - 6



### Temporary Total Enclosure (TTE)

- Temporarily installed enclosure that completely surrounds a source of emissions such that all VOC emissions that are not directed through the control device (*i.e.*, uncaptured) are captured by the enclosure and contained for discharge through ducts that allow for the accurate measurement of the uncaptured VOC emissions.

18 - 7

### Criteria for Temporary Total Enclosure

1. Any NDO shall be at least four equivalent opening diameters from each VOC emitting point unless otherwise specified by the Administrator.
2. Any exhaust point from the enclosure shall be at least four equivalent duct or hood diameters from each NDO.
3. The total area of all NDO's shall not exceed 5 percent of the surface area of the enclosure's four walls, floor, and ceiling.
4. The average facial velocity (FV) of air through all NDO's shall be at least 3,600 m/hr (200 fpm). The direction of air flow through all NDO's shall be into the enclosure.
5. All access doors and windows whose areas are not included in section 5.3 and are not included in the calculation in section
6. shall be closed during routine operation of the process

18 - 8

### Temporary Total Enclosure



18 - 9

### Building Enclosure (BE)

- Building Enclosure (BE). An existing building that is used as a TTE.

18 - 10

### Alternative Capture Efficiency

- [Guidance Document 035](#)
- Must be included in SIP
- Liquid to gas mass balance without an enclosure
- Statistical analysis is required for alternatives
  - DQO or LCL

18 - 11

### Data Quality Objective (DQO)

- The purpose of the DQO is to allow sources to use alternative CE test procedures while ensuring reasonable precision consistent with pertinent requirements of the Clean Air Act. The DQO requires that the width of the 2-sided 95 percent confidence interval of the mean measured value be less than or equal to 10 percent of the mean measured value (see Figure 1). This ensures that 95 percent of the time, when the DQO is met, the actual CE value will be +5 percent of the mean measured value (assuming that the test protocol is unbiased).

18 - 12

Calculations

Lower Confidence Limit (LCL)

- The LCL approach compares the 80 percent (2-sided) LCL for the mean measured CE value to the applicable CE regulatory requirement. The LCL approach requires that either the LCL be greater than or equal to the applicable CE regulatory requirement or that the DQO is met. A

18 - 13

Lower Confidence Limit (LCL)

- The purpose of the LCL approach is to provide sources, who may be performing much better than their applicable regulatory requirement, a screening option by which they can demonstrate compliance. The approach uses less precise methods and avoids additional test runs which might otherwise be needed to meet the DQO while still being assured of correctly demonstrating compliance.

18 - 14

Lower Confidence Limit (LCL)  
(cont.)

- It is designed to reduce "false positive" or so called "Type II errors" which may erroneously indicate compliance where more variable test methods are employed. Because it encourages CE performance greater than that required in exchange for reduced compliance demonstration burden, the sources that successfully use the LCL approach could produce emission reductions beyond allowable emissions. Thus, it could provide additional benefits to the environment as well.

18 - 15

Method 204

Criteria for and Verification of a PTE or TTE

- [Method 204](#)

([https://www.epa.gov/sites/production/files/2019-06/documents/method\\_204\\_0.pdf](https://www.epa.gov/sites/production/files/2019-06/documents/method_204_0.pdf))

18 - 16

Quality Control - TTE

- The success of this method lies in designing the TTE to simulate the conditions that exist without the TTE (i.e., the effect of the TTE on the normal flow patterns around the affected facility or the amount of uncaptured VOC emissions should be minimal).
- The TTE must enclose the application stations, coating reservoirs, and all areas from the application station to the oven. The oven does not have to be enclosed if it is under negative pressure. The NDO's of the temporary enclosure and an exhaust fan must be properly sized and placed.

18 - 17

TTE - Baseline VOC Measurement

- Monitor the VOC concentration of the captured gas steam in the duct before the capture device without the TTE. To minimize the effect of temporal variation on the captured emissions, the baseline measurement should be made over as long a time period as practical. However, the process conditions must be the same for the measurement in section 7.5 as they are for this baseline measurement. This may require short measuring times for this quality control check before and after the construction of the TTE.

18 - 18

Calculations

Measure VOC inside TTE

- After the TTE is constructed, monitor the VOC concentration inside the TTE. This concentration should not continue to increase and must not exceed the safe level according to Occupational Safety and Health Administration requirements for permissible exposure limits. An increase in VOC concentration indicates poor TTE design.

18 - 19

TTE VOC Measurement

- Monitor the VOC concentration of the captured gas stream in the duct before the capture device with the TTE. To limit the effect of the TTE on the process, the VOC concentration with and without the TTE must be within 10 percent. If the measurements do not agree, adjust the ventilation rate from the TTE until they agree within 10 percent.

18 - 20

Enclosure Criteria Determination

1. Determine the equivalent diameters of the NDO's and determine the distances from each VOC emitting point to all NDO's. Determine the equivalent diameter of each exhaust duct or hood and its distance to all NDO's. Calculate the distances in terms of equivalent diameters. The number of equivalent diameters shall be at least four.

18 - 21

Enclosure Criteria Determination

2. Measure the total surface area ( $A_T$ ) of the enclosure and the total area ( $A_N$ ) of all NDO's in the enclosure. Calculate the NDO to enclosure area ratio (NEAR) as follows:

$$NEAR = \frac{A_N}{A_T}$$

- The NEAR must be  $\leq 0.05$ .

18 - 22

Enclosure Criteria Determination

3. Measure the volumetric flow rate, corrected to standard conditions, of each gas stream exiting the enclosure through an exhaust duct or hood using EPA Method 2.

- The FV shall be at least 3,600 m/hr (200 fpm). Alternatively, measure the pressure differential across the enclosure. A pressure drop of 0.013 mm Hg (0.007 in. H<sub>2</sub>O) corresponds to an FV of 3,600 m/hr (200 fpm).

18 - 23

Volumetric Flow Rate

- Measure the volumetric flow rate, corrected to standard conditions, of each gas stream exiting the enclosure through an exhaust duct or hood using EPA Method 2.

$$FV = \frac{Q_o - QI}{A_N}$$

18 - 24

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 18: Lesson 18 FRM 204. PTE-TTE, Enclosures, Capture Efficiency-

### Calculations

#### Volumetric Flow Rate (cont.)

- $Q_o$  = the sum of the volumetric flow from all gas streams exiting the enclosure through an exhaust duct or hood
- $Q_i$  = the sum of the volumetric flow from all gas streams into the enclosure through a forced makeup air duct; zero, if there is no forced makeup air into the enclosure

18 - 25

#### Enclosure Criteria Determination

4. Verify that the direction of air flow through all NDO's is inward. If FV is less than 9,000 m/hr (500 fpm), the continuous inward flow of air shall be verified using streamers, smoke tubes, or tracer gases. Monitor the direction of air flow for at least 1 hour, with checks made no more than 10 minutes apart.

18 - 26

#### Capture Efficiency

Protocol	Enclosure Verification	Liquid Input (L)	Captured emissions (G)	Fugitive Emissions (F or $F_b$ )	Capture Efficiency Formula
PTE	RM 204	N/A	N/A	N/A	Assumed 100%
TTE Gas/Gas	RM 204	N/A	RM 204B or C	RM 204D	$G/(G+F)$
TTE Liquid/Gas	RM 204	RM 204A or F	N/A	RM 204D	$(L-F)/L$
BE Gas/Gas	RM 204	N/A	RM 204B or C	RM 204E	$G/(G-F_b)$
BE Liquid/Gas	RM 204	RM 204 A or F	N/A	RM 204E	$(L-F_b)/L$

18 - 27

#### Method 204A – Volatile Organic Compounds Content in Liquid Input Stream

- [Method 204A](#)

([https://www.epa.gov/sites/production/files/2017-08/documents/method\\_204a.pdf](https://www.epa.gov/sites/production/files/2017-08/documents/method_204a.pdf))

18 - 28

#### Method 204B – Volatile Organic Compounds in Captured Stream

- [Method 204B](#)

([https://www.epa.gov/sites/production/files/2017-08/documents/method\\_204b.pdf](https://www.epa.gov/sites/production/files/2017-08/documents/method_204b.pdf))

18 - 29

#### Method 204C – Volatile Organic Compounds Emissions in Capture Stream (Dilution Technique)

- [Method 204C](#)

([https://www.epa.gov/sites/production/files/2017-08/documents/method\\_204c.pdf](https://www.epa.gov/sites/production/files/2017-08/documents/method_204c.pdf))

18 - 30

## APTI #450/468 Compliance Test and Source Test Observation

### Lesson 18: Lesson 18 FRM 204. PTE-TTE, Enclosures, Capture Efficiency-

#### Calculations

---

Method 204D – Volatile Organic Compounds Emissions in Uncaptured Stream from TTE

- [Method 204D](#)

([https://www.epa.gov/sites/production/files/2017-08/documents/method\\_204d.pdf](https://www.epa.gov/sites/production/files/2017-08/documents/method_204d.pdf))

18 - 31

Method 204E – Volatile Organic Compounds Emissions in Uncaptured Stream from BE

- [Method 204E](#)

([https://www.epa.gov/sites/production/files/2017-08/documents/method\\_204e.pdf](https://www.epa.gov/sites/production/files/2017-08/documents/method_204e.pdf))

18 - 32

Method 204F – Volatile Organic Compounds Content in Liquid Input Stream (Distillation Approach)

- [Method 204F](#)

([https://www.epa.gov/sites/production/files/2017-08/documents/method\\_204f.pdf](https://www.epa.gov/sites/production/files/2017-08/documents/method_204f.pdf))

18 - 33

## Compliance Test and Source Test Observation

### Stack Testing Special Topics:



19 - 1

## Compliance Test and Source Test Observation

### Stack Testing Special Topics:

- **High Moisture**
- High Pressure Stacks
- High Temperature Stacks
- Low Flow Rate

19 - 2

## Typical Sources With High Moisture Content In Stack

- Lime Hydrators
- Evaporators
- Coke Oven Quench Towers
- Ammonia Nitrate Prilling Facilities
- Steam Generators
- Processes with wet scrubbers
- Other


19 - 3

## The Problem

- High moisture in stack gas causes pitot tube to plug, thus poor  $\Delta p$  readings (i.e., velocity measurements)
- Problems with maintaining isokinetic sampling rate (i.e.,  $\Delta H = k\Delta p$ )
- Water droplets on filter increasing pressure drop and effecting isokinetics
- Dilution of impinger solutions thus effecting collection efficiency of analytes
- Condensation in pitot tube sample lines

19 - 4

## Water Vapor and Testing




19 - 5

## High Moisture Potato Chip Fryer







19 - 8

**The Problem: FRM 5  
 Isokinetic Rate Equation**

$$\Delta H = \left\{ 846.72 D_n^4 \Delta H_{@C_p}^2 (1 - B_{ws})^2 \frac{M_d T_m P_s}{M_s T_s P_m} \right\} \Delta P$$

19 - 9

**High Moisture Error**

- With low moisture (i.e., <15 %), the error is rather small
- However, with high moisture (i.e., > 15 %), the error becomes small
- Typically, for every 1 % error in moisture determination reflects a 1 % error in isokinetics


19 - 10

**Sampling Problems With High  
 Moisture Stacks**

- Erroneous readings due to low flow rate through orifice due to large volume of moisture drop-out in impingers
- Inaccurate control of sampling rate due to small volume of gas passing through control valves
- Non-isokinetic sampling due to fluctuations in moisture content of stack gas

19 - 11

**What Approaches Can Be Taken To  
 Sample Under High Moisture  
 Situations?**




19 - 12



### General Solution #1 (Placement of Orifice Meter In Stack)

- Place orifice meter before impingers instead at end of sampling system
  - Total sample volume passes through orifice meter
  - Moisture content measurement unnecessary
  - Isokinetics not affected by moisture


19 - 14



### General Solution #2 (Placement of Orifice Meter In Heated Filter Box)

- ◆ Orifice meter is located in heated sample box behind filter
  - Prevention of condensation at orifice
  - Protected from particulate fouling


19 - 16



### General Solution #3 (In-situ Orifice with Changeable Orifice Plates)

- Orifice meter is located in the stack with changeable orifice plates (i.e., In-situ)
- Filter located before silica gel impinger
- Probe heated to prevent condensation
- Developed for use at ammonium nitrate facilities

19 - 18



**General Solution #4  
 (Consultant's Approach)**

- ◆ Orifice meter is located in the heated filter compartment of FRM 5 sampling train
- ◆ Filter located before silica gel impinger
- ◆ Probe heated to prevent condensation and pitot tube lines cleaned by pressurized air
- ◆ Developed for use at ammonium nitrate facilities

19 - 20

**General Solution #5**

- Use FRM 5 Sampling Train Except:
  - Install cyclone and drop-out impinger in sample train to catch larger volume of water
  - Use larger 1<sup>st</sup> impinger and change periodically during test (Must leak check during each change!)
  - Install drop-out traps in pitot tube lines or blow-back lines periodically during sampling

19 - 21

**All of The Solutions Involve Removing  $B_{ws}$  From The Isokinetic Rate Equation**

$$H = \left\{ 846.72 D_n^4 \Delta H @ C_p^2 \frac{M_d T_m P_s}{M_s T_s P_m} \right\} \Delta P$$

19 - 22

**Problems Common To All Three Approaches**

- Entrained water droplets
- Condensation in manometer and pitot tube lines
- Improper condensation in impingers

19 - 23

**General Solutions**

- Use of larger knock-out impinger after heated filter compartment
- Use of condenser to aid in knocking out moisture coupled with larger impinger in sampling train
- Changing impingers frequently during testing (must leak check each time)

19 - 24

## Compliance Test and Source Test Observation

### *Stack Testing Special Topics:*

- High Moisture
- **High Pressure Stacks**
- High Temperature Stacks
- Low Flow Rate

19 - 25

## Stack Testing At High Pressure Sources

### Three Problem Areas With Stack Testing At High Pressure Stacks (> 5 “)

- Port Leakage
- Pressure Measurement Difficulties
- Sample Losses

19 - 27

### Port Leakage

- Locations with **NEGATIVE STATIC PRESSURE**
    - Ambient air ( $O_2 = 20.9\%$ ) will be sucked into the duct
  - Locations with **POSITIVE STATIC PRESSURE**
    - Flue gas will be blown out of port into the immediate test area
- ( As the magnitude of the static pressure increases, the effects become significant )

19 - 28

### Minimizing Port Leakage

- Install gate valves or globe valves on ports for use during sample train insertion and removal
- Use port adapters with compression fittings around probe to seal off port during sampling

19 - 29



19 - 30

### Pressure Measurement Difficulties

- During probe insertion/removal:
  - Pitot tube lines can be blown off the manometer from the force of the static pressure
  - Gauge oil in manometer can be pushed or pulled into the fluid reservoirs from the force of the static pressure
  - In extreme cases, the fluid can be pulled into pitot lines

19 - 31

### Overcoming Pressure Measurement Difficulties

- Use compression fittings to attach pitot lines to manometer
- Install a series of shut-off valves to the pressure lines
- Measure static pressure with a magnahelic gauge

19 - 32

### Sample Losses Can Occur

- During probe insertion/removal:
  - Filter can become unseated from the filter holder and sucked forward, along with any sample collected on the filter
  - Impinger contents can become sucked forward through the impinger train

19 - 33

### Sample Losses Can Occur

- During sampling:
  - Probe (and all attached components of the sample train) can be inadvertently displaced by positive or negative pressure
  - Impinger train can burst from extreme positive pressure

19 - 34

### Preventing Sample Losses

- Locations with **NEGATIVE STATIC PRESSURE**:
  - Engage the pump and allow a small amount of gas to flow through the sample train while putting the sample train into the port
- Locations with **POSITIVE STATIC PRESSURE**:
  - Engage the pump and allow a small amount of gas to flow through the sample train while taking the sample train out of the port

19 - 35

### Preventing Sample Losses

- Use port adapters with compression fittings around probe to support sample train and keep it fixed in place
- Reduce positive pressure on impinger train
  - Insert a valve at the inlet of the impinger train to reduce gas flow
  - Use a coiled condenser at the inlet of the impingers train to rapidly cool the gas stream

19 - 36




## Compliance Test and Source Test Observation

### *Stack Testing Special Topics:*

- High Moisture
- High Pressure Stacks
- **High Temperature Stacks**
- Low Flow Rate

19 - 37



19 - 38

## Typical Sources With High Temperature In Stack

- Gas Turbines
- Municipal Incinerators
- Glass Furnaces
- Flares
- Kilns
- Other Sources

19 - 39




19 - 41



19 - 42







**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 19: Stack Testing Special Topics**



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 19: Stack Testing Special Topics



### The Problem

- High stack temperatures causes problems with obtaining proper leak check of sampling system and safety problems
- Problems with achieving airtight seal between nozzle and probe liner
- Breakage of glass probe liner due to different coefficients of thermal expansion between probe liner and stainless steel jacket

19 - 53

### Stack Temperatures


- Traditional FRM 5 good to about 700 °F
- Municipal incinerators and gas turbines usually emit effluents well in excess of 750 °F, and up to 2000 °F

19 - 54

### Maximum Temperature of Various Materials

- Teflon: < 350 °F
- Glass: < 900 °F
- Stainless Steel: < 1210 °F
- Quartz: < 1650 °F
- Inconel: < 1800 °F


19 - 55



19 - 56

### Sampling Problems

- Teflon ferrules and Viton-O rings must not be used at temperatures exceeding their softening point (i.e., seal between nozzle and probe liner etc.)
- The organic material in the glue on the tape used to wrap the heating wire on the probe can burn off and bias the test
- The probe should be free of tape since there is no reason to heat the probe.<sup>19 - 57</sup>



19 - 58

### Sampling Problems

- Metal probes, at high temperatures, become catalyst (reactive surfaces) for substances in the stack gas (i.e., oxidation of metals, SO<sub>2</sub> to SO<sub>3</sub>, etc.)
- High effluent gas temperature could cause softening of the nozzle, probe and pitot tube
- Difficulty of maintaining filter box temperature at 248 °F

19 - 59

### Solution #1 (Construction of High Temperature Probes)

- Devise a cooling system allowing use of standard construction materials (i.e., Glass, Teflon, Stainless Steel)
  - Ambient Air
  - Water
  - Steam (Very dangerous)

19 - 60



**Solution #2  
(Construction of High  
Temperature Probes)**

- Construct probes of materials which can withstand high temperatures
  - Inconel
  - Special Alloys
  - Quartz

19 - 61

**Use of Probe Cooling  
Techniques  
( Advantages)**

- Durability of probe
- Unrestricted probe length
- Cooling of gases ensures that filter temperature can be maintained within limits
- Sensing lines (i.e., pitot tube) can be included within cooling jackets

19 - 62

**Use of Probe Cooling  
Techniques  
( Disadvantages)**

- Requires structural support equipment at sampling site
- Vapor pockets may form which may rupture jacket
- Condensation in probe may give problems with maintaining isokinetic sampling rate
- Cooling nozzle/pitot tube gives variable effects on stack gas flow

19 - 63

**Use of Quartz Probe  
( Advantages)**

- Stack gas effluents will not react probe material during sampling
- Absence of bulky cooling system
- No condensation in probe
- No heat expansion and distortion of probe and nozzle
- Gases not cooled below 248 °F

19 - 64

**Use of Quartz Probe  
( Disadvantages)**

- Very brittle/may crack during adding probe nozzle
- Traditionally, fixed nozzle sizes
- Probe lengths greater than 5 ft are impractical
- If using quartz probe without probe liner, then can't attach pitot tube and thermocouple wires

19 - 65

**Miscellaneous Sampling  
Problems**

- ◆ Sagging of probe and pitot tubes in gas effluent
- ◆ Heat radiation from process affects temperature measurements (may have to shield stack gas components)
- ◆ General safety consideration for handling hot probe and working close to stack liner


19 - 66

## Compliance Test and Source Test Observation

### *Stack Testing Special Topics:*

- High Moisture
- High Pressure Stacks
- High Temperature Stacks
- **Low Flow Rate**

19 - 67



19 - 68

## Velocity Measurement

- Used in determination of nozzle size
- Used in obtaining K-factor for setting isokinetic rate conditions during testing
- Used in determining pollutant mass rate

19 - 69

## Federal Reference Method 2 Average Velocity Over Cross-Section

$$\bar{v}_s = K_p C_p (\sqrt{\Delta p})_{avg} \sqrt{\frac{T_{s(avg)}}{M_s P_s}}$$

19 - 70

## Average Stack Gas Dry Volumetric Flow Rate

$$Q_{std} = 3600 \left(1 - B_{ws(avg)}\right) v_{s(avg)} A \frac{T_{std}}{T_{s(avg)}} \frac{P_s}{P_{std}}$$

19 - 71

## The Problem


- Pressure differential devices insensitive below 17 ft/second
- Unreliable pitot tube accuracy below 7 ft/second

19 - 72

### The Problem

- FRM 5 typical incline manometer has incline range of 0-1 “ H<sub>2</sub>O with 0.01 “ divisions, and vertical range of 1-10 “ H<sub>2</sub>O with 0.10 “ divisions
- FRM 5 designed to monitor flows around 1.84 “ H<sub>2</sub>O, not in the 0-0.5 “ H<sub>2</sub>O range

19 - 73



19 - 74

### Federal Reference Method 2 Guidelines

- A differential pressure gauge other greater sensitivity shall be used:
  - The arithmetic average of all  $\Delta p$  readings at the traverse points < 0.05 “ H<sub>2</sub>O
  - For traverse of 12 or more points, more than 10 % of the individual  $\Delta p$  readings < 0.05 “ H<sub>2</sub>O
  - For traverse of < 12 points, more than one  $\Delta p$  reading < 0.05 “ H<sub>2</sub>O

19 - 75

### Federal Reference Method 2 Guidelines

- As an alternative to criteria (1) through (3) above, the following equation may be used to determine the necessity of using a more sensitive differential pressure gauge. If T is greater than 1.05, the velocity head data are unacceptable and a more sensitive differential pressure gauge must be used.

19 - 76

### Determination of Sensitivity of Pressure Gauge

$$T = \frac{\sum_{i=1}^n \sqrt{\Delta p_i + K}}{\sum_{i=1}^n \sqrt{\Delta p_i}}$$


19 - 77

### Using Magnehelic Gauges Etc.

- If differential pressure gauges other than inclined manometers are used (e.g., magnehelic gauges), their calibration must be checked after each test series.
- To check the calibration of a differential pressure gauge, compare  $\Delta p$  readings of the gauge with those of a gauge-oil manometer at a minimum of three points, approximately representing the range of  $\Delta p$  values in the stack.

19 - 78





### Alternative Approaches for Low Velocity Measurements

- The use of techniques other than Type-S pitot tubes
- Modification of the source to effect a sufficiently high velocity for using the Type-S pitot tube
- Measure velocity at a different location and use data to calculate velocity at sampling site
- Compute flow and velocity using process parameters

19 - 80

### Techniques For Measurement of Low Flows

- Standard pitot tube with portable inclined manometer (0-0.25 " H<sub>2</sub>O with 0.005 " H<sub>2</sub>O scale divisions) or digital manometer
- Standard pitot tube with dual scale portable inclined manometer with 0-1.0 " H<sub>2</sub>O with 0.01 " H<sub>2</sub>O scale divisions and 0-10 " H<sub>2</sub>O with 0.10 " H<sub>2</sub>O scale divisions

19 - 81

### Techniques For Measurement of Low Flows

- Rotating vane anemometer with digital readout (0-100 ft/sec with 1 ft/sec accuracy)
- Thermal anemometer with digital readout (0-100 ft/sec with 1 ft/sec accuracy)

19 - 82

### Other Low Flow Techniques

- Venturi Meters
- Orifice Meters
- Mass Flow Meters

19 - 83

### Compliance Test and Source Test Observation

#### *Stack Testing Special Topics:*

- High Moisture
- High Pressure Stacks
- High Temperature Stacks
- Low Flow Rate

19 - 84

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20A: Reciprocating Internal Combustion Engines (RICE)**

---

Compliance Test and Source  
Test Observation

Reciprocating Internal  
Combustion Engines (RICE)  
Sampling and Overview of  
CEMS for Engines and Gas  
Turbine Testing

20A - 1

Stationary Engines - Video



20A - 2

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

Compliance Test and Source Test  
Observation  
*FRMs 6C, 7E, 3A and 20 Instrumental*



20B - 1



20B - 2

Applicability

- "...controlled and uncontrolled emissions from sources specified in the regulations..."
- Fossil fuel-fired boilers
- Municipal waste combustors

20B - 3

Principle

- "...sample continuously extracted and conveyed to an instrumental analyzer..."

20B - 4

How the Method Works

- Inject calibration gases directly to analyzers
- Inject calibration gases through sampling system
- Conduct a sampling run and record data

20B - 5

How the Method Works

- Inject calibration gases through sampling system again
- Use average values from sampling system calibrations to correct the sample data
- **YOU CORRECT EMISSION DATA!**

20B - 6

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

---

Eight Major Points

1. Calibration Error (Both Analyzer):  
Zero, mid, high ( 2%)
2. Zero/Calibration Drift (Both Analyzer):  
Proceeding/Following Each Run:  
< 3% of span or Reject
3. Sampling System Bias Check/Recovery Check  
(Both Analyzers): Zero, Mid/High Range at Probe  
and Analyzer (5% of span)

20B - 7

Eight Major Points (cont.)

4. Interference Check (SO<sub>2</sub> Analyzer): Use Modified  
Method 6 (3 Runs 1 L/min) vs. Analyzer at Vent  
(7%)
5. Converter Check (NO<sub>x</sub> Analyzer): Introduce CO @  
500 ppm, SO<sub>2</sub>@200 ppm, CO<sub>2</sub>@10% and  
O<sub>2</sub>@20.9%; < 2% of span response, pass

20B - 8

Eight Major Points (cont.)

6. Calibration Error (Both Analyzer): Zero, mid, high ( 2%)
7. Zero/Calibration Drift (Both Analyzer):  
Proceeding/Following Each Run): < 3% of span or  
Reject
8. Sampling System Bias Check/Recovery Check(Both  
Analyzers): Zero, Mid/High Range at Probe and  
Analyzer (5% of span)

20B - 9

Interesting Points

- Perform Calibration Curve: High (80-100% span),  
Mid (40-60% span), Zero (<0.25% span)
- Calibration Gas Certification: Protocol 1 or Method  
6 (3 Runs/1 L/min), 5%

20B - 10

Interesting Points

- Span of instrument: Emission standard at 30% of  
span
- Calibration gases can be SO<sub>2</sub>/N<sub>2</sub>, SO<sub>2</sub>/Air, SO<sub>2</sub>/CO<sub>2</sub>, or  
SO<sub>2</sub>/CO<sub>2</sub>/O<sub>2</sub>
- Emission data corrected with determined bias  
number
- No EPA Method 6 audit vial required due to  
"Interference Check"

20B - 11

Interesting Points

- Sampling system bias test done before and after  
test, then average, and apply value to emission data  
to correct
- Zero/Calibration Drift (Both Analyzer):  
Proceeding/Following Each Run): < 3% of span; May  
not reject if pass bias check!

20B - 12

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**



20B - 13




20B - 14

**Method 6C**  
**Typical Analytical Methods**

- Ultraviolet Absorption (UV)
  - Nondispersive Infrared (NDIR)
  - Fluorescence
  - FTIR
- Analyzer must meet the performance requirements of this method.

20B - 15



20B - 16









20B - 17








20B - 18











# APTI #450/468 Compliance Test and Source Test Observation


## Lesson 20B: Federal Reference Method 6C-7E-3A and 20



20B - 31




20B - 32



20B - 33



20B - 34




### MODEL 43C- SO<sub>2</sub> ANALYZER

- Microprocessor control
- SO<sub>2</sub> Specific
- Reflective U.V. filtering
- Hermetically sealed U.V. lamp
- No consumables

**Thermo Environmental Instruments Inc.**  
Model 43C Analyzer


20B - 36

### MODEL 43C-SO<sub>2</sub> Analyzer



$$I_a = I_0[1 - e^{-a \times (\text{SO}_2)}]$$

$$I_f = I_0 a \times (\text{SO}_2) \text{ or } K(\text{SO}_2)$$



20B - 37

### Thermo Model 43C SO<sub>2</sub> Analyzer

#### Pulsed Fluorescence SO<sub>2</sub> Analyzer

#### Advanced Technology

The Model 43C integrates the proven pulsed fluorescence design of Thermo Environmental Instruments Inc. Model 43 series with an enhanced electronics package and user interface. The outcome is a sensitive, ultra stable SO<sub>2</sub> analyzer offering network operators and research scientists unlimited troubleshooting, diagnostics and data communications capability.

Thermo Environmental Instruments design engineers have introduced a user interface which literally guides one through operation of the Model 43C. This is accomplished via a 4 line by 20 character Vacuum Fluorescent Display and simple layout of easy-to-use function keys. The end result is a combination of self explanatory display messages and intuitive function entries.

User software facilities include field programmable measurement ranges and SO<sub>2</sub> concentration value storage by date and time.




#### MODEL 43C SPECIFICATIONS


Ranges	0-50, 100, 200, 500, 1000 ppb and 0-1, 2, 5, 10, 20, 50, 100 ppm
Zero/Noise	1.0 ppb RMS (10 second averaging time) 0.5 ppb RMS (60 second averaging time) 2.5 ppb RMS (300 second averaging time)
Lower Detectable Limit	21.0 ppb RMS (10 second averaging time) 1.0 ppb RMS (60 second averaging time) 5 ppb RMS (300 second averaging time)

Analyze • Detect • Measure • Control™  
 Thermo ELECTRON CORPORATION


15




20B - 39



20B - 40



20B - 41



20B - 42



### HOW IS NO MEASURED?

Chemiluminescence Technique

$$\text{NO} + \text{O}_3 \longrightarrow \text{NO}_2^* + \text{O}_2$$

$$\text{NO}_2^* \longrightarrow \text{NO}_2 + h\nu$$

Intensity of emitted light is proportional to NO concentration

20B - 43

### Chemiluminescent

Reduction of NO<sub>2</sub> to NO

$$3 \text{NO}_2 + \text{Mo} \longrightarrow 3 \text{NO} + \text{MoO}_3$$

A molybdenum catalyst, heated to ~325°C, is used to Convert NO<sub>2</sub> to NO

20B - 44




### Measurement Principle

CHEMILUMINESCENCE



$$\text{NO} + \text{O}_3 \longrightarrow \text{NO}_2^* + \text{O}_2$$

$$\text{NO}_2^* \longrightarrow \text{NO}_2 + h\nu$$

20B - 45



APTI #450/468 Compliance Test and Source Test Observation  
 Lesson 20B: Federal Reference Method 6C-7E-3A and 20



20B - 50



Analytical Range

- "...To the extent practicable, the measured emissions should be between 20 to 100 percent of the selected calibration span. ..."
- "No valid run average concentration may exceed the calibration span."

20B - 53

Performance Specifications

- **Analyzer Calibration Error**, for non-dilution systems, means the difference between the manufacturer certified concentration of a calibration gas and the measured concentration of the same gas when it is introduced into the analyzer in direct calibration mode.
- **Analyzer calibration error**
  - Less than ± 2% of span for zero, mid, and high-range gases

20B - 54

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

---

---

Performance Specifications

- *System Bias* means the difference between a calibration gas measured in direct calibration mode and in system calibration mode. System bias is determined before and after each run at the low- and mid- or high-concentration levels. For dilution-type systems, pre- and post-run system calibration error is measured rather than system bias.

20B - 55

Performance Specifications

- *System Calibration Error* applies to dilution-type systems and means the difference between the measured concentration of low-, mid-, or high-level calibration gas and the certified concentration for each gas when introduced in system calibration mode. For dilution-type systems, a 3-point system calibration error test is conducted in lieu of the analyzer calibration error test, and 2-point system calibration error tests are conducted in lieu of system bias tests.

20B - 56

Performance Specifications

- Sampling system bias
  - Less than  $\pm 5\%$  of span for zero and mid or high-range gases
- *Drift* means the difference between the pre- and post-run system bias (or system calibration error) checks at a specific calibration gas concentration level (*i.e.* low-, mid- or high-).
- Zero drift and calibration drift
  - Less than  $\pm 3\%$  of span over the period of the run

20B - 57

Calibration Gases

- High-range = Equal to the calibration span
- Mid-range = 40-60% of span
- Zero gas =  $< 0.25\%$  of span

20B - 58

Calibration Gases

- Protocol 1
- Traceability protocol (G1, G2)
- Valid certificate required Uncertainty  $\leq 2.0\%$  of tag value

20B - 59

Measurement System Performance Test Procedures

- Measurement system preparation
  - Acquire equipment/calibration gases
  - Set-up the components
  - Warm up the analyzers
  - Adjust flow rates

20B - 60



Recommended Sampling System Design  
Criteria

- Remove particulate
- Remove moisture or otherwise lower the dew point of the sample
- Minimize sample loss through leaks, absorption, and reaction

20B - 61

Recommended Sampling System Design  
Criteria

- Allow for introduction of calibration gas through as many components as possible

20B - 62

Recommended  
Particulate Removal

- In-stack filter at probe tip or probe outlet
- Filter after moisture removal system to catch condensable particulate
- Final filter at analyzer inlet

20B - 63

Sample Handling

- Maintain the sample above the dew point temperature except in the condensers
- Use only non-reactive wetted surfaces (i.e., glass, Teflon, and stainless steel)

20B - 64

Moisture Removal  
Condensers

- Use ice bath, refrigerated, or thermoelectrically cooled impingers or coils
- Design condenser to minimize contact area between sample and condensate

20B - 65

Moisture Removal  
Condensers

- Continuously remove condensate from traps to further reduce contact with sample and limit absorption of SO<sub>2</sub> and NO<sub>2</sub>

20B - 66

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

---

Other Methods of Lowering Sample Dew Point

- Semi-permeable membrane dryers (Perma-Pure®)
- Dilution probes

20B - 67

Injecting Calibration Gases Into the Sampling system

- One of the most common problem areas
- Calibration gases should be introduced under flow conditions that are as close as possible to the sampling conditions
- Testers hate to waste calibration gas

20B - 68

Three Suggested Ways to Introduce Calibration Gases

- Straight Tee
- Closed Loop
- Closed Loop with Vent

20B - 69

Calibration Gas Introduction - Straight Tee

- No 3-way valve required
- Will not pressurize sampling system if probe filter is clean
- Uses analyzer zero readings to establish adequate calibration gas flow

20B - 70

Calibration Gas Introduction - Closed Loop

- Uses 3-way valve to isolate sampling system from probe
- Sample flow meter is used to match calibration gas and sample gas flows
- Pressurizing the sampling system can disguise leaks

20B - 71

Calibration Gas Introduction - Closed Loop with Vent

- Uses 3-way valve to isolate sampling system from probe
- Vent with rotameter ensures that calibration gas is introduced under vacuum

20B - 72

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

---

---

Leak Check

- Not required by the method due to bias test procedure
- Should be conducted from probe tip to analyzers before and after each test

20B - 73

Analyzer Calibration Error

- Less than  $\pm 2\%$  of span for zero, mid and high-range gases
- Demonstrates accuracy and linearity

20B - 74

Sampling System Bias Check

- Less than  $\pm 5\%$  of span for zero and mid or high-range gases
- Check integrity of system; cannot adjust monitor calibration after calibration error (CE) test

20B - 75

Emission Testing

- Unless otherwise specified in an applicable regulation or by the Administrator, when this method is used to determine compliance with an emission standard, conduct a stratification test as described in method 7E, section 8.1.2 to determine the sampling traverse points to be used. For performance testing of continuous emission monitoring systems, follow the sampling site selection and traverse point layout procedures described in the appropriate performance specification or applicable regulation (e.g., Performance Specification 2 in appendix B to this part).

20B - 76

Emission Testing

- Perform a stratification test at each test site to determine the appropriate number of sample traverse points. If testing for multiple pollutants or diluents at the same site, a stratification test using only one pollutant or diluent satisfies this requirement.

20B - 77

Sampling Procedures

- Conduct sampling system bias checks before and after each run
- Make no calibration adjustments prior to recording bias results after a run
- Sample run duration plus twice the sampling system response time

20B - 78

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

---

---

If System Exceeds Bias Specifications

- Run is invalid
- Fix system (maybe just re-calibrate analyzer)
- Repeat analyzer calibration error and sampling system bias checks before proceeding

20B - 79

If System Meets Bias Specification

- Use average of bias results before and after the run to correct the measured effluent gas concentration

20B - 80

Data Recording

- Strip chart or computer data acquisition system with resolution of at least 0.5% of instrument span
- Commonly done with PC-based data acquisition systems

20B - 81

Emission Calculations

- Data corrected for errors observed in calibration error bias checks

20B - 82

Interference Check

- *Interference Check* means the test to detect analyzer responses to compounds other than the compound of interest, usually a gas present in the measured gas stream, that is not adequately accounted for in the calibration procedure and may cause measurement bias.

20B - 83

Interference Check

- The total interference response (i.e., the sum of the interference responses of all tested gaseous components) must not be greater than 2.50 percent of the calibration span for the analyzer tested. In summing the interferences, use the larger of the absolute values obtained for the interferent tested with and without the pollutant present. The results are also acceptable if the sum of the responses does not exceed 0.5 ppmv for a calibration span of 5 to 10 ppmv, or 0.2 ppmv for a calibration span <5 ppmv.

20B - 84

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

---

---

Known SO<sub>2</sub>  
Analyzer Interferences

- Some earlier model NDIR SO<sub>2</sub> analyzers demonstrated a high bias due to residual moisture in the sample (after condenser)
- Some earlier model UV analyzers demonstrated a high bias when NO<sub>2</sub> concentrations were high relative to the SO<sub>2</sub> concentrations

20B - 85

Known SO<sub>2</sub>  
Analyzer Interferences

- Fluorescence analyzers suffer from quenching effects from CO<sub>2</sub> and O<sub>2</sub>

20B - 86

Sampling in the  
Presence of Ammonia

- Ammonia reacts with SO<sub>2</sub> in the condenser causing a low bias
- Amount of bias depends on the relative concentrations of SO<sub>2</sub> and ammonia

20B - 87

Sampling in the  
Presence of Ammonia

- Some success reported using dilution sampling systems
- Used modified Method 6 or modified Method 8 instead of Method 6C to ensure good results

20B - 88

Dilution Probes for Method 6C/7E/3A

- *Dilution-Type Systems—Special Considerations.* When a dilution-type measurement system is used, there are three important considerations that must be taken into account to ensure the quality of the emissions data. First, the critical orifice size and dilution ratio must be selected properly so that the sample dew point will be below the sample line and analyzer temperatures.

20B - 89

Dilution Probes for Method 6C/7E/3A

- Second, a high-quality, accurate probe controller must be used to maintain the dilution ratio during the test. The probe controller should be capable of monitoring the dilution air pressure, eductor vacuum, and sample flow rates. Third, differences between the molecular weight of calibration gas mixtures and the stack gas molecular weight must be addressed because these can affect the dilution ratio and introduce measurement bias.

20B - 90

**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

---

---

Calibration Gas - Dilution Systems

- USEPA Method 205
- Not approved for acid rain (40 CFR 75) testing

20B - 91

Method 7E - NO<sub>x</sub>

- ? No field interference check (use Method 20 laboratory interference test)
- NO<sub>2</sub> to NO converter efficiency test (same as Method 20)

20B - 92

Method 7E - Ammonia (NH<sub>3</sub>) Interference Problems

- Use low temperature (molybdenum or activated carbon) NO<sub>2</sub> to NO converter to prevent conversion of NH<sub>3</sub> to NO
- Molybdenum converters lose efficiency quickly and need to be regenerated often

20B - 93

Method 7E - High NO<sub>2</sub>/NO Ratio in Sample

- NO<sub>2</sub> is readily absorbed by the sampling system, causing low bias
- Most NO<sub>x</sub> calibration gases contain little NO<sub>2</sub>

20B - 94

Method 7E - High NO<sub>2</sub>/NO Ratio in Sample

- NO<sub>2</sub> to NO converter efficiency becomes much more important
- Tester should perform NO/NO<sub>2</sub> balance adjustment

20B - 95

Method 3A - O<sub>2</sub> and CO<sub>2</sub>

- Any analytical technique
- Less rigorous sampling system material specification
- Option to substitute low-range check for zero gas for O<sub>2</sub> analyzers
- Laboratory interference check same as Method 20

20B - 96



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 20B: Federal Reference Method 6C-7E-3A and 20**

Method 20

**• Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions From Stationary Gas Turbines**

Method 20 contains the details you must follow when using an instrumental analyzer to determine concentrations of nitrogen oxides, oxygen, carbon dioxide, and sulfur dioxide in the emissions from stationary gas turbines.

20B - 97

Method 20

- The use of Method 20 may be required by specific New Source Performance Standards, Clean Air Marketing rules, and State Implementation Plans and permits where measuring SO<sub>2</sub>, NO<sub>x</sub>, CO<sub>2</sub>, and/or O<sub>2</sub> concentrations in stationary gas turbines emissions are required. Other regulations may also require its use.

20B - 98

Method 20

- In this method, NO<sub>x</sub>, O<sub>2</sub> (or CO<sub>2</sub>), and SO<sub>x</sub> are measured using the following methods found in appendix A to this part:
- (a) Method 1—Sample and Velocity Traverses for Stationary Sources.
- (b) Method 3A—Determination of Oxygen and Carbon Dioxide Emissions From Stationary Sources (Instrumental Analyzer Procedure).
- (c) Method 6C—Determination of Sulfur Dioxide Emissions From Stationary Sources (Instrumental Analyzer Procedure).

20B - 99

Method 20

- (d) Method 7E—Determination of Nitrogen Oxides Emissions From Stationary Sources (Instrumental Analyzer Procedure).
- (e) Method 19—Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates.

20B - 100

Method 20

- You must follow the procedures of Section 8.4 of the appropriate methods listed in Section 2.0.
- A test run must have a duration of at least 21 minutes.

20B - 101



20B - 102

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 21: RATA - CGA

### U.S. EPA APTI Compliance Test and Source Test Observation

### RATA / CGA

21 - 1

### Quality Assurance Activities

- Relative Accuracy Test Audit Procedures
- Cylinder Gas Audit and Linearity Check
- Opacity Calibration Error Assessment


21 - 2

### Relative Accuracy Test Audit (RATA)

- Requirements found in:
  - Part 60
    - New Source Performance Standards
    - Industry/Process Specific
  - Part 75
    - Acid Rain Program
    - Electric Generating Units

21 - 3

### Relative Accuracy Test Audit (RATA)



Verification of CEMS  
performance by a  
third-Party testing  
company using  
USEPA Methods

21 - 4

### Types of RATAs

- Gaseous
  - NO<sub>x</sub>
  - CO
  - SO<sub>2</sub>
  - Diluent (O<sub>2</sub> or CO<sub>2</sub>)
  - Other
- Flow Rate
- Particulate
- Mercury

21 - 5

### RATA General Concepts

- Compare CEMS to Reference Method
- Reference Method is the "Correct" data
  - Can be wet or instrumental version of the method
  - Typically, instrumental is preferred (real time data)
- Typical RATA is 12 runs, must use 9 to determine accuracy
- RATA Frequency – Varies on Rule

21 - 6

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 21: RATA - CGA

### RATA General Concepts (cont.)

- RM tests should be on same basis as CEM system
  - Wet to wet, or dry to dry
- For gaseous pollutants: 21-minute runs
- For flow rate: as long as it takes to do a traverse
- Match up RM and CEM times (critical)

21 - 7

### Required Reference Method QC

- Stratification test
- NOx converter efficiency
- Protocol calibration gases
- Linearity checks of analyzers
- Bias/drift checks
- Leak checks

21 - 8

### Part 60 RATA

#### “Out of Control”

- NOx/SO<sub>2</sub>: > 20% RM mean, or >10% standard (whichever is less restrictive)
- O<sub>2</sub>/CO<sub>2</sub>: >20% RM mean, or 1% O<sub>2</sub>/CO<sub>2</sub>
- CO: >10% RM mean, or >5% standard
- “Out of Control” lasts until pass next RATA

21 - 9

### Part 75 RATA

#### “Out of Control”

RATA	Semiannual	Annual
SO <sub>2</sub> or NO <sub>x</sub>	7.5% < RM ≤ 10% or ±15 ppm	RM ≤ 7.5% or ±12 ppm
SO <sub>2</sub> /diluent	7.5% < RM ≤ 10% or ±0.030 lb/mmBtu	RM ≤ 7.5% or ±0.025 lb/mmBtu
NO <sub>x</sub> /diluent	7.5% < RM ≤ 10% or ±0.020 lb/mmBtu	RM ≤ 7.5% or ±0.015 lb/mmBtu
CO <sub>2</sub> /O <sub>2</sub>	7.5% < RM ≤ 10% or ±1.0% CO <sub>2</sub> /O <sub>2</sub>	RM ≤ 7.5% or ±0.7% CO <sub>2</sub> /O <sub>2</sub>
Moisture	7.5% < RM ≤ 10% or ±1.5% H <sub>2</sub> O	RM ≤ 7.5% or ±0.10% H <sub>2</sub> O
Flow	7.5% < RM ≤ 10% or ±2.0% fps	RM ≤ 7.5% or ±1.5 fps

21 - 10

### Part 60 Requirements

- Unit load
  - 50% of capacity, or
  - Normal” load
- Repeat every four calendar quarters
  - i.e.: annually

21 - 11

### Part 75 Requirements

- Unit load
  - Test at “normal” load
  - Defined at Part 75, Appendix A, 6.5.2.1
- Frequency
  - Every 2 operating quarters (semi-annual), except:
  - Can go to annual if RA ≤ 7.5%
  - Fall back into semi-annual if RA > 7.5%

21 - 12

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 21: RATA - CGA

### Cylinder Gas Audit (CGA)

- Challenge the CEMS three times at each audit point using a protocol gas, and use the average of the three responses in determining accuracy
- Each CEMS must be audited at least once each calendar quarter. Successive quarterly audits shall occur no closer than 2 months.

21 - 13

### CGA (cont.)

CGA - may be conducted in three of four calendar quarters, but in no more than three quarters in succession

1. Challenge the CEMS (both pollutant and diluent portions of the CEMS, if applicable) with an audit gas of known concentration at two points

21 - 14

### CGA (cont.)

2. Operate each monitor in its normal sampling mode, i.e., pass the audit gas through all filters, scrubbers, conditioners, and other monitor components used during normal sampling, and as much of the sampling probe as is practical.

21 - 15

### CGA (cont.)

3. Use Certified Reference Materials (CRM's) audit gases that have been certified by comparison to National Institute of Standards and Technology (NIST) or EPA Traceability Protocol Materials (ETPM's) following the most recent edition of EPA's Traceability Protocol No. 1. As an alternative to CRM's or ETPM gases, Method 205 (See Citation 3) may be used.

21 - 16

### CGA (cont.)

- The difference between the actual concentration of the audit gas and the concentration indicated by the monitor is used to assess the accuracy of the CEMS

21 - 17

### Cylinder Gas Audit (CGA) Part 60

CGA Calibration Gas Requirements

Audit Point	Pollutant Analyzers % of Span	CO <sub>2</sub> % by volume (actual conc.)	O <sub>2</sub> % by volume (actual conc.)
1	20 to 30	5 to 8	4 to 6
2	50 to 60	10 to 14	8 to 12

21 - 18

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 21: RATA - CGA

### CGA vs Linearity

- Part 60 CGA
  - 2 gases: low (20-30% of span) and mid (50-60% of span)
  - Criteria < 15% or ≤5 ppm difference
  - Performed in 3 quarters per year with RATA performed in 4<sup>th</sup> quarter
- Part 75 Linearity
  - 3 gases: low (20-30% of span), mid (50-60% of span), and high (80-100% of span)
  - Criteria < 5% or ≤5 ppm difference
  - Performed in every QA operating quarter

21 - 19

### CGA: Out-of-Control Period

- An out-of-control period occurs when the CGA at any of the two concentrations (four for dual range) exceeds the applicable specifications (>15% error or 5 ppm difference). The out-of-control period begins with the hour of the failed CGA and ends with the hour of a satisfactory CGA following the corrective action.
- During the time the CEMS is out-of-control the CEMS data may not be used in calculating emission compliance nor be counted toward meeting minimum data availability.

21 - 20

### Linearity Check – Part 75

- Cal gas requirements are based on % of span per the following:

Low	20 – 30% of span value
Mid	50 – 60% of span value
High	80 – 100% of span value
- Calibration gases **MUST** be EPA Protocol certified
- Out-of-control occurs if any of the three audit level runs exceeds 5% or alternately 5 ppm difference for NO<sub>x</sub>/SO<sub>2</sub> or 0.5% difference for CO<sub>2</sub>/O<sub>2</sub>
- Exemptions, grace periods, and extensions exist for linearity

21 - 21

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 22: FRM 205 (Gas Dilution System)

### U.S. EPA APTI Compliance Test and Source Test Observation

### Method 205 Gas Dilution System

22 - 1

### Background

- Originated as Conditional Test Method 007 (CTM-007)
  - Assures Regional, State, and Local Authorities the gas dilution systems in use were producing accurate calibration gas at a fixed site.
  - Allow testers the advantage of avoiding costs and burden associated with purchasing transporting multiple gas cylinders over long distances.
- Promulgated as a Reference Method on May 30, 1994, as Method 205
  - Allows dilution system for most instrumental test method that requires multi-level cylinder gases.
  - Allows use of dilution systems when conducting performance specifications according to 40 CFR Part 60, Appendix F (CGAs), with Administrator Approval.
    - Administrative Approval for this has been delegated to Regions and in many instances down to the state level.


22 - 2

### Equipment Criteria

- Gas Dilution System
  - Multiple vendors, however, the market appears to be dominated by a single provider
    - Internal mass flow controllers (MFC) used to set dilution ratio
    - Dilution Ratio can be set by other equipment (e.g., critical orifice, capillary tubes, etc...)
  - Must produce a calibration gas within  $\pm 2$  percent of the predicted value
  - Must be recalibrated once per calendar year using a NIST-traceable primary flow standards with an uncertainty  $\leq 0.25$  percent.
    - Must be labeled with the calibration date and expiration date
    - **NO** set requirement to report the calibration documentation...
- High and Mid-Level Calibration Gas
  - Protocol Gas is recommended
  - Mid Level gas **SHALL** be within 10% of one of the dilution levels.

22 - 3

### Mass Flow Controller and Meters



22 - 4

### Gas Dilution System Calibration

- No set calibration procedure for the systems
  - Critical Orifices/Capillary Tubes are fixed
  - Mass Flow Meters and Controllers should be calibrated at multiple flow rates
- Requirement to use a primary standard with an uncertainty of 0.25 % should restrict most testers from performing this measurement in-house.
  - Primary Standards of the quality are Cost Prohibitive (20-50K initial cost)
  - A number of metrology labs/vendors capable of maintaining these calibrations.
  - Appropriate alternative to using a primary standard that has proven uncertainty below  $\leq 0.25$  % is a Laminar Flow Element (i.e., Molbloc). Not currently included in the method, but any future revisions would include transfer standards.



22 - 5

### Method 205 (Requirements)

- Field Evaluation (Mandatory)
  - Must be performed at the **Test Site**, prior to testing.
  - Prepare two different dilutions within the range of each dilution device.
    - Calculate a predicted value based on the dilution set-point(s) and high-level concentration
  - Challenge the Dilution System
    - At each set-point three times, by introducing gas to the analyzer through the dilution system
      - Precision Check –  $<2\%$  of the average response
      - Accuracy Check –  $<2\%$  of the predicted value
    - Introduce a mid-level gas (protocol gas and within 10% of a dilution level) directly to the analyzer
      - Accuracy Check –  $<2\%$  of the certified concentration

22 - 6



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 22: FRM 205 (Gas Dilution System)

### Method 205 (Requirements)

- Lab Evaluation (Optional)
  - Applies to reactive compounds (i.e., non-propane THCs, TRS compounds)
  - Must be conducted on an annual basis for each reactive compound
  - Same Procedures as the Field Evaluation

22 - 7

### Example – NO<sub>x</sub>/O<sub>2</sub> rata

#### Field Calibration - Oxygen Analyzer

- Instrument (Span for Testing) – O<sub>2</sub> - 21.0% **NO<sub>x</sub> – 12.2 ppmv**
- High Calibration Gas – O<sub>2</sub> @ 21.0%, **NO @ 99.2 ppmv** – Protocol Gas
- Mid-Level Calibration Gas – 20.9%, **NO @ N/A** – Protocol Gas
- Predicted Dilution Levels @ 2.1% and 21.0%
- Average Dilution Response of 2.2% and 20.6%
- Mid-Level Calibration Response – 20.9%

Acceptable

22 - 8

### Example A – NO<sub>x</sub>/O<sub>2</sub> RATA

#### Field Calibration - Oxygen Analyzer

- ✓ Instrument (Span for Testing) – O<sub>2</sub> - 21.0% **NO<sub>x</sub> – 12.2 ppmv**
- ✓ High Calibration Gas – O<sub>2</sub> @ 21.0%, **NO @ 99.2 ppmv** – Protocol Gas
- ✓ Mid-Level Calibration Gas – 20.9%, **NO @ N/A** – Protocol Gas
- ✓ Predicted Dilution Levels @ 2.1% and 21.0%
- ✓ Average Dilution Response of 2.2% and 20.6%
- ✓ Mid-Level Calibration Response – 20.9%

Good - incorporated the dilution range for all analyzers

Bad – Mid level Verification check performed at the "0" dilution point.

Hmmm.... Was there a leak in the calibration system?

22 - 9

### Example B – THC, CO, AND O<sub>2</sub> Compliance Test

#### Field Calibration – Carbon Monoxide Analyzer

- Instrument (Span for Testing)
  - CO – 100 ppmv, THC – 10 ppmv, O<sub>2</sub> - 15.0%
- High Calibration Gas – Certified ± 5 %
  - CO @ 10,000 ppmv, Propane @ 500 ppmv, O<sub>2</sub> @ 20.9
- Mid-Level Calibration Gas – Protocol Gas
  - CO @ 990 ppmv, THC @ N/A, O<sub>2</sub> @ N/A, –
- Predicted Dilution Levels @ 1,000 ppmv and 5,000 ppmv
- Average Dilution Response of 1000 ppmv and 5000 ppmv
- Mid-Level Calibration Response – 1000 ppmv

Acceptable?

22 - 10

### Example B – THC, CO, AND O<sub>2</sub> Compliance Test

#### Field Calibration – Carbon Monoxide Analyzer

- ✓ Instrument (Span for Testing) – CO – 100 ppmv, **THC 10 ppmv, O<sub>2</sub> - 15.0%**
- ✓ High Calibration Gas – CO @ 10,000 ppmv, **Propane @ 500 ppmv, O<sub>2</sub> @ 20.9** – Certified ± 5 %
- ✓ Mid-Level Calibration Gas – CO @ 990 ppmv, **THC @ N/A, O<sub>2</sub> @ N/A, –** Protocol Gas
- ✓ Predicted Dilution Levels @ 1,000 ppmv and 5,000 ppmv
- ✓ Average Dilution Response of 1000 ppmv and 5000 ppmv
- ✓ Mid-Level Calibration Response – 1000 ppmv

Good – Met The Method Criteria

Bad – Did Not Bracket the Dilution Range (10:1 vs 200:1)

Should of – Used a more appropriate high-level calibration gas

Could of – Additional mid-level verification for high dilution ratio

Hmmm.... That data looks really good

22 - 11

### Cylinder Gas Audits (CGAs)

- Can I use a Dilution System for Cylinder Gas Audit ?
  - Section 1.1 permits the use for CGA under Part 60
  - Broadly Applicable Alternative 25 (ALT-025) permitted the use under Part 63 as well. (September 3, 1999)
- You still must conduct the field evaluation at each site.
  - Multiple Gases Requirement (High and Mid) still required
  - Field evaluation takes a significant amount time.
- Diminishing Returns
  - Field Evaluation test should take twice as long as a normal CGA
- Protocol Gas for Criteria Pollutants are widely available and relatively inexpensive with a long shelf life
  - 10 Year Certificate
  - Gas Cost – less than \$250/ Demurrage (2 cents/day) = 10 year cost \$323
- Compelling Applications
  - When cylinder gases are very expensive
    - Reactive Compounds
    - Low-Level Standards
  - When cylinder gases are not widely available
  - For some reason, if the tester cannot predict the exact concentration needed



22 - 12

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 22: FRM 205 (Gas Dilution System)

---

### Method 205 Concerns

- Indeterminate Method Criteria
  - Calibration of the Dilution System
  - No record keeping
  - Maximum/Minimum Dilution Ratio Undefined, manufacture suggestion
- Technology
  - Open to any device that meets criteria
  - Multiple (Blended) Gas Calibration is undefined
  - Data Reporting/Recording/Logging

22 - 13

### Acid Rain Program (Part 75) Applications

- Method 205 is only permitted with Administrator Approval
- Part 75 is a “Cap and Trade” System
  - Tighter Protocol Gas Requirements (PGVP)
  - Quarterly Audits have a tighter criteria than CGAs
  - Quality Protocol Gases are widely available.

22 - 14

### Future Revisions to Method 205


- No immediate plans for major revisions to Method 205
  - Minor revision to incorporate the use of NIST transfer standards to calibrate the dilution devices.
- Future Revisions
  - Report/Record Requirements
  - Limit CGAs of criteria pollutants
  - Requirement to bracket dilution ranges
  - Defined System Calibration Requirements
  - PS 12 or 18 Applicability
  - Formatting Change – EMMC Format

22 - 15

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 23: FRM 320 FTIR

### U.S. EPA APTI Compliance Test and Source Test Observation *FRM 320 and 321 FTIR*



23 - 1

### Introduction to FTIR Operation

- Absorption peaks in an infrared absorption spectrum arise from molecular vibrations
- Absorbed energy causes molecular motions which create a net change in the dipole moment

23 - 2


### Introduction to FTIR Operation

- Fourier-transform infrared spectroscopy is a vibrational spectroscopic technique, meaning it takes advantage of asymmetric molecular stretching, vibration, and rotation of chemical bonds as they are exposed to designated wavelengths of light.
- Fourier transform is to transform the signal from the time domain to its representation in the frequency domain

23 - 3

### FTIR Theory and Instrumentation

#### Typical Fourier Transform Spectrometer



- Light enters the spectrometer and is split by the beam splitter. The figure above shows what is referred to as the Michelson interferometer

23 - 4


### FTIR Theory and Instrumentation

- Light originates from a He-Ne laser
- Half of the light is reflected 90 degrees, while the other half passes through the beam splitter and hits the moving mirror
- The split beams are recombined, after having traveled different distances, they exhibit an interference pattern with each other
- As they pass through the sample, the detector collects the interfering signals and returns a plot of response v. mirror displacement known as an interferogram

23 - 5

### FTIR Theory and Instrumentation

- The heart of the system is the interferometer in which the light from the source is divided into two beams.
- Beams pass through the sample cell and then recombine resulting in a signal.
- All information required to identify and quantify the gases in the sample is present in the interferogram.
- Interferogram signal is converted to a frequency spectrum by a mathematical technique called Fourier Transformation.



23 - 6

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 23: FRM 320 FTIR

---

### FRM 320

- Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy
  - 1.0 Introduction
  - 2.0 Summary of Method
  - 3.0 Definitions
  - 4.0 Interferences
  - 5.0 Safety
  - 6.0 Equipment and Supplies

23 - 7

### FRM 320 (cont'd)

- Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy
  - 7.0 Reagents and Standards
  - 8.0 Sampling and Analytical Procedure
  - 9.0 Quality Control
  - 10.0 Calibration and Standardization
  - 11.0 Data Analysis and Calculations
  - 12.0 Method Performance

23 - 8

### FRM 320 (cont'd)

- Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy
  - 13.0 Method Validation Procedure
  - 14.0 Pollution Prevention
  - 15.0 Waste Management
  - 16.0 References
  - Addendum to Test Method 320
    - Protocol for the Use of Extractive FTIR for the Analyses of Gaseous Emissions from Stationary Sources

23 - 9

### FRM 320 (cont'd)

- Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy
  - Addendum A to Test Method 320
    - Protocol for the Use of Extractive FTIR for the Analyses of Gaseous Emissions from Stationary Sources
  - Addendum B to Test Method 320
    - Identifying Spectral Interferants
  - Addendum C to Test Method 320
    - Estimating Noise Levels

23 - 10

### FRM 320 (cont'd)

- Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy
  - Addendum D to Test Method 320
    - Estimating Minimum Concentration Measurement Uncertainties
  - Addendum E to Test Method 320
    - Determining Fractional Reproducibility Uncertainties
  - Addendum F to Test Method 320
    - Determining Fractional Calibration Uncertainties
  - Addendum G to Test Method 320
    - Measuring Noise Levels

23 - 11

### FRM 320 (cont'd)

- Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy
  - Addendum H to Test Method 320
    - Determining Sample Absorption Pathlength and Fractional Analytical Uncertainty
  - Addendum I to Test Method 320
    - Determining Fractional Model Uncertainties

23 - 12

### FRM 320 Sampling Types

- Screening
- Emission Test
- Validation

23 - 13

### FRM 320 (cont'd)

- Measurement of Vapor Phase Organic and Inorganic Emissions by Extractive Fourier Transform Infrared (FTIR) Spectroscopy
  - System involves typical CEM probe and pump to extract the sample to the FTIR analytical bench
  - An IR spectra of the sample is digitized from the FTIR gas cell
  - "Reference spectra" prepared in the laboratory of the standard samples of interest compared to the digitized FTIR spectra of the sample
  - Self-validation method in utilizing a QA analyte spike of the extracted sample at the probe

23 - 14

### FRM 320

- "...This method applies to the analysis of vapor phase organic or inorganic compounds which absorb energy in the mid-infrared spectral region, about 400 to 4000  $\text{cm}^{-1}$  (2.5 to 25  $\mu\text{m}$ ). This method is used to determine compound-specific concentrations in a multi-component vapor phase sample, which is contained in a closed-path cell. Spectra of samples are collected using double beam infrared absorption spectroscopy. A computer program is used to analyze spectra and report compound concentrations."

23 - 15



23 - 16

### Infrared Spectroscopy

- Infrared light (IR) waves at discrete frequencies to molecular bond motions
- Vibrational and pure rotational motions
- When the frequencies match, energy is absorbed by that bond and resulting excitation increases molecular bond energy state (non-ionizing)

23 - 17







### Infrared Spectroscopy

- The energy absorbed by the bond at discrete frequencies is proportional to the number of molecules
- FTIR spectrum is a plot of decreased energy at discrete frequencies corresponding to the absorption bands of the compounds in the sample. High resolution 0.5  $\text{cm}^{-1}$




23 - 18



**APTI #450/468 Compliance Test and Source Test Observation**  
**Lesson 23: FRM 320 FTIR**







### Beer-Lambert Law

$$I = I_0 e^{-\alpha c l}$$

- $I$  = intensity of radiation through the sample
- $I_0$  = intensity of radiation with  $c = 0$  or  $\alpha = 0$
- $\alpha$  = absorption coefficient
- $c$  = gas concentration
- $l$  = pathlength of radiation through the gas


23 - 29

### From Beer-Lambert Law:

$$A = \log I / I_0 = \alpha c l$$

Direct Relationship


23 - 30



### Infrared Band Centers Of Some Common Gases


Gas	Band Center (μm)	Wave Number (cm <sup>-1</sup> )
NO	5.0-5.5	1800-2000
NO <sub>2</sub>	5.5-20	500-1800
SO <sub>2</sub>	8-14	700-1250
H <sub>2</sub> O	3.1, 5-5.5, 7.1-10	1000-1400 1800-3200
CO <sub>2</sub>	2.7, 5.2, 8-12	850-3700
NH <sub>3</sub>	10.5	950

23 - 32









- ### Operation of the FTIR Spectrometer
- IR energy enters the spectrometer
  - A beam splitter reflects back 50 percent and transmits 50 percent of the incoming infrared radiation
  - The two beams are then reflected back to the beam splitter by a moving mirror and a stationary mirror
  - Depending on the position of the moving mirror, these two beams recombine with a specific path difference between them
- 23 - 34

- ### Operation of the FTIR Spectrometer
- This produces the interferogram
  - The interferogram is generated by the interferometer modulating the infrared beam as the moving mirror is translated
  - The modulated frequencies depend on the wavelength of the incident radiation and the velocity of the moving mirror
  - The interferogram is produced after absorption by the sample and is detected by the detector
- 23 - 35



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 23: FRM 320 FTIR





# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 23: FRM 320 FTIR



23 - 43

### Components of FRM 320


- Sample probe: Glass, stainless steel or other appropriate material of sufficient length and physical integrity to sustain heating.
- Particulate filter: A glass wool plug inserted at the probe tip and a filter to remove particulate matter.
- Heat trace sample line: Heated sufficiently to prevent condensation.

23 - 44


### Components of FRM 320

- Gas Distribution Manifold: A heated manifold allowing the operator to control flows of gas standards and samples directly to the FTIR system or through sample conditioning system. May use heated flow meters, heated valves etc.
- Calibration/Analyte Spike Assembly: A three-way valve assembly to introduce analyte or surrogate spikes into the sampling system at the outlet of the probe upstream of the out-stack filter and the FTIR analytical system.
- FTIR Analytical Bench

23 - 45



### FRM 320 Extractive FTIR Sampling System



23 - 47

### Sampling and Analysis Procedures

- Set-up Sampling System
- Pre-test Preparation and Evaluation
  - Select required detection limit ( $DL_i$ ) and maximum permissible Analytical Uncertainty ( $AU_i$ ) for each analyte. Estimate maximum expected concentration of each analyte.
  - List potential interferences
  - Determine Fractional Reproducibility Uncertainty ( $FRU_i$ )

23 - 48

### Sampling and Analysis Procedures

- Pre-test Preparation and Evaluation (Cont'd)
  - Calculate Minimum Analyte Uncertainty (MAU)
  - Prepare computer program and input reference spectra for all analytes
- Leak-Check Sampling System
  - From probe to pump
  - FTIR cell
- Determine Linearity of Detector


23 - 49

### Sampling and Analysis Procedures

- Perform Background Spectrum with dry nitrogen in FTIR cell
  - Also have in data base spectra of major interferences
- Pre-test Calibrations
  - Fill FTIR cell with Calibration Transfer Standard (CTS). CTS should be certified  $\pm 2\%$  by manufacturer. Record spectra
  - QA Spike to probe to FTIR analytical bench using certified standard (70-130 % recovery)
- Begin Sampling

23 - 50

### FRM 320 FTIR Sampling/Spiking Configuration



23 - 51

### Sampling and Analysis Procedures

- Post-test QA
  - Verify instrument parameters
  - Perform post-test CTS spectra ( $\pm 5\%$ )

23 - 52

### FRM 320 QA Activities

- Analytical Spike (Section 9)-Three spiked samples, analyte concentration in the spike sample compared to expected spike concentration to verify that the sampling/analytical system is working properly
- QA Spike Procedure (Section 8.6.2)- QA Spike to probe to verify that sampling/analytical system is working.
- Response Time Determination (Section 9.2.2)-
- Validation Procedure (Section 13)-

23 - 53


### FRM 320 QA Activities

- Method Validation Procedure (Section 13)- Similar to QA Spike procedure in that one acquires two un-spiked samples, then introduces QA Spike gas into continuous flow of sample gas. Collect spectra of two sample gases.
  - Use FRM 301 to calculate bias as:
 
$$B = S_m - CS$$
 Where:
    - B = Bias at spike level
    - $S_m$  = Mean concentration of the analyte spiked samples
    - CS = Expected concentration of the spiked samples

23 - 54




# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 23: FRM 320 FTIR



- ### FRM 320 QA Activities
- Method Validation Procedure (Section 13)-
    - Use Method 301 to evaluate statistical significance of the bias.
    - If bias is significant ( $0.7 \leq CF \leq 1.3$ ), then develop a correction factor (CF) is calculated and emission results are multiplied by the CF for final analyte concentration.
    - If  $CF \geq \pm 30$  percent, then the test method is considered to be “not valid.”
- 23 - 56

- ### FRM 320 Interferences
- Analytical Interferences (Background and Sampling)
    - Background interference occurs when unexpected change in background spectra from dirt on lenses, changes in detector sensitivity, changes in infrared source etc. This requires a new background to be generated.
    - Spectral interferences from mostly water and CO<sub>2</sub> which causes interferences with measurement analyte wavelength.
- 23 - 57






# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 23: FRM 320 FTIR

### GASMET CEMS APPLICATIONS


Gasmets CEMS and reference measurements:



23 - 61

### U.S. EPA APTI Compliance Test and Source Test Observation

#### FRM 320 and 321 FTIR



23 - 62

# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 24: Safety on the Stack


### Source Sampling Observation Safety



24 - 1

### SES Safety Guidelines Handbok

[SAFETY GUIDELINES HANDBOOK | Source Evaluation Society \(SES\) \(sesnews.org\)](#)



**Source Evaluation Society (SES)**  
P. O. Box 12124 Research Triangle Park, NC 27709-2124

**Primary links**

- Contact Us
- What's New
- General Information
- SES OSTI /QSTO Program
- SSSAAP Conference
- Stack Testing Companies
- Join SES
- SES Members Only
- SES Safety Guidelines Handbook
- Links

**Navigation**

- Feed aggregator

**Home**

**SAFETY GUIDELINES HANDBOOK**  
Submitted by admin on Fri, 03/06/2009 - 14:15


The SES Safety Manual is available for download at the following links:

**Check Lists**

- 2ndEd appendices.pdf
- 2ndEd SafetyHandbook.pdf
- APP H - NIOSH Pocket Guide to Chemical Hazards.pdf
- SAFE PLAN OF ACTION.pdf

24 - 2

### Safety on the Stack



24 - 3



24 - 4



24 - 5



24 - 6

# APTI #450/468 Compliance Test and Source Test Observation


## Lesson 24: Safety on the Stack

---



2

24 - 7



24 - 8



24 - 9



24 - 10



24 - 11




24 - 12



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 24: Safety on the Stack

---



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 24: Safety on the Stack

---



24 - 19



24 - 20



24 - 21



24 - 22



24 - 23



24 - 24



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 24: Safety on the Stack

---









# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 24: Safety on the Stack

---



# APTI #450/468 Compliance Test and Source Test Observation

## Lesson 24: Safety on the Stack

---



**U.S. EPA APTI**  
**Compliance Test and Source Test**  
**Observation**  
**FRM 23/SW-846 Method 0023A,**  
*Dioxin/Furans*



25 - 1



25 - 2

**Applicability**

- This method is applicable to the determination of polychlorinated dibenzo-p-dioxins (PCDDs) and polychlorinated dibenzofurans (PCDFs) from stationary sources utilizing FRM 23 and SW-846, Method 0023A

25 - 3

**Applicability**

- Simultaneous sampling and analysis for polychlorinated biphenyls (PCBs), polynuclear aromatic hydrocarbons (PAHs), semi-volatile organic compounds (SVOCs), and polybrominated diphenyl ethers (PBDE) can also be performed along with PCDDs and PCDFs

25 - 4

**Applicability**






- SW-846, Method 0023A is used to determine destruction removal efficiency (DRE) of PCDDs and PCDFs at 99.9999% (six 9's) from incinerators
- General detection limits are 0.010  $\text{pg}/\text{m}^3$
- FRM 23 is used to quantify PCDD's and PCDF's from stationary sources

25 - 5

**What Are Dioxins?**


- Dioxins are a family of 210 different molecules with one or two basic structures
  - The dioxin structure with two oxygen atoms
  - The furan structure with one oxygen atom

25 - 6



### Chlorine Distribution in Aroclors

	1016	1221	1232	1242	1248	1254	1260
CI-1	90.0%	99.4%	31.5%	0.6%			
CI-2	24.3%	0.6%	28.2%	19.5%	0.7%		
CI-3	47.1%		21.5%	39.1%	22.0%		
CI-4	27.3%		18.7%	36.7%	61.3%	16.0%	0.3%
CI-5	0.4%		0.4%	4.2%	16.3%	59.9%	12.2%
CI-6						23.8%	50.3%
CI-7						0.4%	31.4%
CI-8							5.9%
CI-9							
CI-10							12



### Differences Between Molecules

- The differences between the molecules lie in the number and attachment positions of chlorine atoms

**Examples**  
 2,3,7,8 - TCDF  
 2,3,7,8 - TCDD  
 1,2,3,7,8 - PeCDD

25 - 14

### Chlorinated Dioxins and Furans

- 7-2,3,7,8-substituted chlorinated dioxins
- 75 total chlorinated dibenzo-p-dioxins
- 10-2,3,7,8-substituted chlorinated furans
- 135 total chlorinated dibenzofurans

25 - 15

### Levels of Chlorination

- 4 level chlorination: Tetra
- 5 level chlorination: Penta
- 6 level chlorination: Hexa
- 7 level chlorination: Hepta
- 8 level chlorination: Octa

25 - 16

### TEF Values

Analyte	TEF Value
■ 2,3,7,8 - TCDD	1.0
■ 2,3,4,7,8 - PeCDD	0.5
■ 2,3,4,6,7,8 - HxCDD	0.1
■ 1,2,3,4,6,7,8 - HpCDD	0.01
■ 1,2,3,4,6,7,8,9 - OCDD	0.001

25 - 17

### Congeners

- Molecules with different chemical formulas and the same basic structure are referred to as *congeners*
- Generally, the most common one is octachlorodibenzo-p-dioxin (OCDD), with chlorine in all eight available positions

25 - 18



### Aroclor PCBs

- Aroclor PCBs were manufactured by simply chlorinating biphenyl to specific weight percentage of chlorine

25 - 19

### Aroclor PCBs

- Aroclor mixtures are characterized by a four digit number - ie., Aroclor 1242
  - 12 represents the parent compound, biphenyl
  - 42 represents weight percentage of chlorine in the mixture

25 - 20

### Aroclors

- Each Aroclor mixture consists of biphenyl molecules chlorinated to levels from 1 through 10
- Each level of chlorination produces a chromatographic pattern unique to that PCB
- Many Aroclors have similar peaks, but differ in their ratio

25 - 21

### Aroclors

- Quantification of multi-component mixtures requires area summation of all components and comparison to the summed area from the corresponding Aroclor standard
- To remove interfering peaks, sample clean-up with Florisil is required

25 - 22

### Interferences

- If not using high resolution GC/MS, then interferences from polychlorinated biphenyls and polychlorinated diphenyl ethers could effect low resolution techniques

25 - 23

### Interferences

- Very high amounts of other organic compounds in the matrix will interfere with the analysis
- Contamination in solvents, reagents, glassware, and other sampling processing hardware (all glassware must be cleaned thoroughly before use)

25 - 24



**FRM 23 and SW-846  
 Method 0023A**

**Design Requirements**

- Gas flow measurement system (EPA Methods 2-4)
- Modified Method 5 sampling train, retaining heated filter
  - Sample time of 6.25 hours
- Addition of condenser and XAD-2 resin trap (~65 grams)

25 - 25

**FRM 23 and SW-846 Method  
 0023A Sampling Train**

- Probe with nozzle
- Pitot tube/temperature sensor array
- Heated filter assembly (Teflon®)
- Condenser/XAD-2 resin trap assembly


25 - 26

**FRM 23 and SW-846  
 Method 0023A  
 Sampling Train**

- Condensing impingers
- Silica gel
- Pump/dry gas meter/orifice assembly

25 - 27

**FRM 23/Method 0023A  
 Sampling Train**



25 - 28

**XAD-2 Resin Trap**


- XAD-2 is a cross-linked styrene-divinylbenzene - Organic Polymeric Adsorbent
- Amberlite XAD-2 physical characteristics
  - Mesh Size: 20-60
  - Bulk Density: 1.08 g/mL
  - Surface Area: 300 m<sup>2</sup>/g
  - Temp. Max: 190°C

25 - 29

**Weaknesses of  
 XAD-2 Resin**

- Thermal stability questionable, therefore must solvent extract
- Compounds below C7 breakthrough extensive during sampling
- Produces sulfur compounds as artifacts




25 - 30



### Percent Phase Distribution of Dioxins in Sampling Train

Phase	TCDD	PeCDD	HxCDD	HpCDD	OCDD
Vapor	55	26	4	2	1
Particle	45	74	96	98	99

25 - 32



### Filter Certification of Cleanliness

- Glass fiber filter without organic binder
- Soxhlet extracted with toluene for 16 hours
- No analytes observed above the detection limits of 0.010 pg/m<sup>3</sup>

25 - 37

### XAD-2 Certification of Cleanliness

- Rinse twice with reagent water
- Place resin in thimble with methylene chloride, Soxhlet extract with water for 8 hours, repeat with methanol for 22 hours
- Repeat with methylene chloride, then with toluene, then nitrogen drying

25 - 38

### XAD-2 Certification of Cleanliness

- Resin blank should have no analytes above method detection limits for targeted species
- Spike resin bed with isotopically labeled PCDD/PCDF standards prior to field sampling (surrogate spikes)

25 - 39

### XAD-2 Certification of Cleanliness

- Wrap cartridge in hexane-rinsed aluminum foil

25 - 40

### FRM 23/Method 0023A Typical Field Surrogates (i.e., Surrogate Standards)

- Added to clean cartridge prior to field deployment
  - <sup>37</sup>C<sub>4</sub>-2,3,7,8-TCDD
  - <sup>13</sup>C<sub>12</sub>-2,3,4,7,8-PeCDF
  - <sup>13</sup>C<sub>12</sub>-1,2,3,4,7,8-HxCDD
  - <sup>13</sup>C<sub>12</sub>-1,2,3,6,7,8-HxCDF
  - <sup>13</sup>C<sub>12</sub>-1,2,3,4,7,8,9-HpCDF

25 - 41

### FRM 23/Method 0023A Glassware Preparation

- Soak all glassware in hot soapy water
- Rinse with tap water
- Rinse with DI water

25 - 42

### FRM 23/Method 0023A Glassware Preparation

- Bake at 400°C for 2 hours
- Rinse (3 times) with methylene chloride
- Rinse (3 times) with toluene
- Cap glassware with cleaned aluminum foil

25 - 43

### FRM 23/Method 0023A Glassware Preparation

- Mark glassware with color-coded stickers
- Rinse glassware immediately before use with acetone and methylene chloride

25 - 44

### FRM 23/Method 0023A Operational Requirements

(See Field Observation Checklist)

- Multi-point integrated sampling
- Isokinetic sampling rate (average sampling rate should be within 0.5 to 0.75 cfm)
- Collect calculated sample volume based upon analyte detection limits

25 - 45

### FRM 23/Method 0023A Operational Requirements

- Probe/filter at 120°C (248°F)
- Sorbent resin trap inlet < 20°C (68°F)
- Leak-free system

25 - 46

### Calculation of Sample Duration

- Minimum sample time =  
Analytical Detection Limit / [(Sample Rate) X (Desired Gas Concentration Detection Limit)]

25 - 47

### Example Calculation

- Assumptions
  - Average sampling rate 0.5 cfm
  - Analytical detection limit 0.5 ng
  - Desired gas concentration 0.1 ng/m<sup>3</sup>

25 - 48

### Example Calculation

- Minimum sample time =  
 $0.5 \text{ ng} / [(0.85 \text{ m}^3/\text{hr}) \times (0.1 \text{ ng}/\text{m}^3)] =$   
5.88 hours minimum sample time
- Minimum sample time should be greater than or equal to the calculated total sample time (minimum 2 minutes per sampling point)

25 - 49

### FRM 23/Method 0023A Record Keeping Requirements

- Calibration of
  - Temperature sensors
  - Metering pump
  - Pitot tubes

25 - 50

### FRM 23/Method 0023A Record Keeping Requirements

- Periodic sampling information
  - Gas flow measurements
  - Sampling train parameters
- Sample recovery and laboratory data

25 - 51

### Preliminary Field Determination

(See Field Inspection Checklist)

- Select sampling site according to FRM 1
- Select nozzle size and establish isokinetic sample train operation
- Select probe liner and proper length

25 - 52

### Preliminary Field Determination

- Determine total length of sampling based upon method detection limits
- Establish sampling time per point based upon calculation

25 - 53

### Preparation of Sample Train

- Obtain certified clean isotopically spiked (i.e., field surrogates) sorbent trap from sample custodian, log trap number into field data sheet
- Obtain clean quartz fiber filter from sample custodian

25 - 54

### Preparation of Sample Train

- Charge impingers with appropriate solutions (first impinger empty, second and third impingers filled with 100 mL water, fourth impinger contains 200-300 g silica gel)
- If analyzing for SVOCs, then use HPLC-grade water in impingers

25 - 55

### Preparation of Sample Train


- Place labeled/pre-weighted filter in filter holder
- Install selected nozzle and mark probe

25 - 56

### Preparation of Sample Train

- Assemble sample train (no silicone grease upstream of organic module)
- Place crushed ice around impingers

25 - 57



25 - 58

### Preparation of Sample Train

- Turn on filter/probe heating systems
- Turn on sorbent and condenser coil coolant recirculating pumps (must maintain resin bed at  $< 20^{\circ}\text{C}$ )

25 - 59

### Preparation of Sample Train

- Leak check system at 15 in. Hg vacuum; rate not to exceed 4% of average sampling rate ( $< 0.02$  cfm)

25 - 60



### Preparation of Sample Train

- Clean stack access port
- Insert probe to first sampling point and record initial train information on field test data sheet
- Block off openings around probe to prevent dilution of sample gas

25 - 61

### Sample Train Operation

- Begin sampling when all temperatures are at required settings:
  - Probe/Filter:  $120 \pm 14^{\circ}\text{C}$
  - Sorbent Bed:  $< 20^{\circ}\text{C}$
  - Exit Silica Gel Impinger:  $< 20^{\circ}\text{C}$

25 - 62

### Sample Train Operation

- Sample at each traverse point, maintaining isokinetic sampling rate to within 10% of true isokinetic

25 - 63

### Sample Train Operation

- Record sample train operating parameters-sampling time
  - Sample train vacuum
  - Differential pressures: pitot tube, orifice
  - Dry gas meter (DGM) volume
  - Temperatures: DGM, filter, stack, sorbent, exit last impinger
  - Maintain isokinetics ( $\Delta H = K\Delta p$ )

25 - 64

### Sample Train Operation

- If the pressure drop across filter or adsorbent is  $> 15$  in. Hg, then one must change components
  - Must leak check system prior to change and after change of train component
- If exceeds leak rate limit, run is voided

25 - 65

### Sample Train Recovery

- Turn off coarse adjust valve, remove probe from stack, turn off pump
- Leak check to specifications
- Calculate percent Isokinetics to determine whether the run is valid

25 - 66

**Sample Train Recovery  
by FRM 23/Method 0023A**

- Filter (Container #1: FRM 23/Method 0023A)
  - Recover in pre-clean aluminum foil or container
- Front Half Rinse (Container #2/Method 0023A) and Back Half Rinse (FRM 23)
  - Nozzle, probe liner, filter housing: 3X acetone, then methylene chloride (FRM 23/Method 0023A)
  - 2X with toluene (SW-846, Method 0023A)

25 - 67

**Sample Train Recovery  
by FRM 23/Method 0023A**

- XAD-2 sorbent trap (Container #3/Method 0023A). No container for FRM 23 sorbent trap
  - Weigh for moisture/cap ends (FRM 23)
  - Wrap in original aluminum foil
  - Ship to lab under blue ice (< 4°C)
- Back half rinse (Container #4/Method 0023A)
  - Back half filter holder, connecting lines, condenser with 3X acetone, 2X methylene chloride, 2X toluene

25 - 68

**Sample Train Recovery  
by FRM 23/Method 0023A**

- Impingers - measure/weigh entrained water and note any color in first three impingers (if analyzing for SVOCs, retain)
- Silica Gel - note color, weigh

25 - 69

**Criteria for  
On-site Invalidation**


- Minimum sample volume not met (may not have enough analyte for MDL)
- XAD-2 temperature exceeds 68°F (loss of sample from resin due to no adsorption)

25 - 70

**Criteria for  
On-site Invalidation**

- Use of wrong recovery solvents (may not collect analyte)
- Pre-test leak check >0.02 cfm (4% of average of sampling rate)
- Calculated percent isokinetics outside 90-110%

25 - 71



### HRGC/HRMS Analysis

- HRGC/HRMS initial tuning
- 5-point initial calibration curve
- Continuing calibration checks

25 - 73

### HRGC/HRMS Analysis

- Soxhlet extraction spiked
- Quantitation by internal standards
- PE sample analyzed

25 - 74

### Ions Monitored by HRGC/HRMS

- 2,3,7,8-TCDD
  - 258.9300
  - 319.8965
  - 321.8936
  - 331.9368

25 - 75

### Ions Monitored by HRGC/HRMS

- 1,2,3,4,7,8-HxCDD
  - 326.8521
  - 389.8156
  - 391.8127

25 - 76

### Ions Monitored by HRGC/HRMS

- OCDD
  - 394.7742
  - 457.7377
  - 459.7347

25 - 77

### Analysis For FRM 23

- Analysis by FRM 23 combines filter and XAD-2 resin as one analysis
- Analysis by SW-846, Method 0023A performed in two fractions
  - Fraction #1: Filter (with surrogate spiking) and front half rinses (Containers 1 and 2)
  - Fraction #2: Sorbent trap and back half rinses (Containers 3 and 4)

25 - 78

### Method 0023A Laboratory Surrogates

- ◆ **Added to filter prior to extraction**
  - $^{37}\text{C}_4$ -2,3,7,8-TCDD
  - $^{13}\text{C}_{12}$ -2,3,4,7,8-PeCDF
  - $^{13}\text{C}_{12}$ -1,2,3,4,7,8-HxCDD
  - $^{13}\text{C}_{12}$ -1,2,3,6,7,8-HxCDF
  - $^{13}\text{C}_{12}$ -1,2,3,4,7,8,9-HpCDF

79

### Analysis

- This allows filter surrogate recoveries/XAD-2 surrogate standard recoveries determined

25 - 80

### Analysis

- Surrogate standards are added to the filter/front half fraction immediately prior to extraction whereas the field surrogate standards have already been added to XAD-2 resin prior to field deployment

25 - 81

### Analysis by FRM 23

- **Container #1 (filter)**
  - Extract extraction thimble/  
1 g of silica gel and glass wool  
with for 3 hrs toluene
  - Add filter and XAD-2 resin in the  
extraction thimble containing the 1 g  
silica gel

25 - 82

### FRM 23 Analysis

- **Container #2 (Acetone and Methylene Chloride Rinses)**  
Concentrate to 1-2 mL and added to filter/XAD-2 resin in the extraction thimble
- Add 100  $\mu\text{L}$  of internal standard solution
- **Container #3 (Toluene Rinse)**  
Concentrate and analyze separately.

25 - 83

### Both Method Analysis

- Soxhlet extraction in toluene/16 hours
- Concentrate to 100  $\mu\text{L}$ ,  
redissolve in 5 mL of hexane
- Cleanup with alumina/carbon columns
- Add recovery standards
- Analyze by HRGC/HRMS

25 - 84

### Both Method Analysis

- Samples must be extracted within 30 days and analyzed within 45 days
- Extracted samples spiked with Recovery Standards (40 µL)

25 - 85

### Both Method Analysis

- Extracted samples divided into two portions
  - Portion #1: archived for future analysis
  - Portion #2: solvent exchanged to hexane, then subject to 3 column chromatographic cleanup by Method 8290

25 - 86

### Both Method Analysis

- GC/MS analysis by Method 8290
  - HRGC/HRMS initial tuning
  - 5-point initial calibration
  - Continuing calibration checks
  - Recovery standard solutions
  - Quantitation by internal standards

25 - 87

### Calculation

$$C_i(\mu\text{g}/\text{m}^3) = (\text{Total mass of analyte collected, } \mu\text{g}) / (\text{Std. volume of gas sampled, } \text{m}^3)$$

25 - 88

### Both Method Acceptance Criteria

- All PCDD/PCDF surrogate recoveries should be within 70% to 130%
- If all isomer recoveries are greater than 130% or less than 70%, repeat sample run

25 - 89

### Both Method Acceptance Criteria

- Must perform field, method, reagent, and proof blanks
- Must pre-clean filter and sorbent cartridge

25 - 90

### Both Method Key Points

- XAD-2 and filter must be certified clean and good for 4 weeks
- Adsorbent temperature during sampling can not exceed 68°F
- Pre- and component change leak check required and must meet < 0.02 cfm or invalidate sample run

25 - 91

### Both Method Key Points

- Filter spiked with surrogates prior to extraction (Method 0023A)
- XAD-2 adsorbent trap spiked with surrogates prior to field deployment

25 - 92

### Both Method Key Points

- Surrogate, internal and recovery standards used with HRGC/HRMS analysis
- Shipment of samples to laboratory under blue ice (< 4°C)
- No grease used in front of sorbent trap

25 - 93

### Both Method Key Points

- Extensive cleaning of glassware prior to use
- Must calculate sample volume needed to meet method detection limits
- Can't use stainless steel nozzles

25 - 94

### Both Method Key Points

- Extraction and analysis performed in two fractions so filter and XAD-2 surrogate recoveries can be determined separately (Method 0023A only)
- Sampling is isokinetic
- Sample must be extracted in 30 days and analyzed within 45 days

25 - 95

### PCB Congeners

PCB Isom Group	Cong. #	Chlorine Sub.
Monochlorobiphenyl	1	2
Trichlorobiphenyl	29	2,4,5
Pentachlorobiphenyl	87	2,2',3,4,5'
Octachlorobiphenyl	200	2,2',3,3',4,5',6,6'



### **LONG-TERM DIOXIN & FURAN SAMPLING SYSTEMS**

- **AMESA (German Instrument)**
  - Adsorption Method for Sampling of D/F
- **DMS (Austria Instrument)**
  - Dioxin Monitoring System

25 - 97

### **Applications Dioxin/Furan Emissions**

- **Municipal Incinerators**
- **Hazardous Waste Incinerators**
- **Hospital Waste Incinerators**
- **Sewage Sludge Incinerators**
- **Other Combustion Sources**

25 - 98

### **SAMPLING PRINCIPLES AMESA & DMS**

- **Auto-isokinetic Sampling**
- **Titanium Probe & Nozzle**
  - Heated application
  - Air or water cooled application
- **Sampling Periods**
  - 4 hrs to 4 weeks
  - Usually 2 weeks per XAD module

25 - 99

### **AMESA SAMPLING EQUIPMENT & PROTOCOL**

- **Titanium Probe Positioned at Average Velocity Sampling Point**
- **Electronic System Leak-Check Valve**
- **Collects D/F in XAD-2 Module**
- **Collects & Measures Stack Moisture**
- **Monitors & Records Temperatures**

25 - 100

### **DMS SAMPLING EQUIPMENT & PROTOCOL**

- **Two Titanium Probes Positioned at Average Velocity Sampling Points**
- **Electronic System Leak-Check Valve**
- **Collects D/F on Filter & PUF Cartridges**
- **Does Not Measure Stack Moisture**
- **Monitors & Records Temperatures**

25 - 101

### **DMS SAMPLING EQUIPMENT & PROTOCOL**

- **Dual Titanium Probes Positioned at Average Velocity Sampling Points.**
- **Probes Switch Every 30 Minutes**
- **Uses the "Null Nozzle" Concept**
- **Stack Sample is Diluted & Cooled**
- **Electronic System Leak-Check Valve**
- **Collects D/F on Polyurethane Foam (PUF)**
- **Does Not Collect Stack Moisture**

25 - 102

### DMS SAMPLING PROTOCOL

- Null Nozzle Sampling Approach
  - Design assumes by adjusting the nozzle sample flow to produce a “null condition” for the manometer pressures, isokinetic sampling can be achieved.
  - Reliability of null sampling nozzles is a function of design and use.
  - Isokinetic sampling conditions are not always guaranteed.

25 - 103

### DMS SAMPLING PROTOCOL

- Dilution Sampling Method
  - Stack gas is sampled isokinetically
  - Mixed with dried, cleaned, D/F-free compressed air
  - Purpose of dilution air is to cool and dilute the stack gas to a dew point where little or no condensate is realized
  - Dry gas mixture passes through a filter and two PUFs for D/F collection

25 - 104

### DMS SAMPLING PROTOCOL

- Polyurethane Foam (PUFs)
  - Two PUFs in series collect D/F
  - PUFs are cleaned and vacuum dried prior to use
  - Glass fiber filter and two PUFs are installed in field module
  - 100 ul of a recovery standard surrogate is applied to glass fiber filter surface
  - Module is assembled by laboratory

25 - 105

### AMESA & DMS SAMPLING EQUIPMENT

- Measures Stack Gas Velocity, Temperature, & Pressure
- Optional System Can Measure O<sub>2</sub> & CO<sub>2</sub>
- Sampling Range – 0.0001 to 10 ng/m<sup>3</sup>
- Condensate Can Be Collected & Analyzed For AMESA

25 - 106

### AMESA & DMS SAMPLING PROTOCOL

- Isokinetic Sampling Procedures
- Duplicates M23 Sampling Rates
- Collects Approx. 0.85 m<sup>3</sup>/hour (0.85 m<sup>3</sup> X 24 hrs = 20 m<sup>3</sup>/day )
- Volume For a Two Week Period – >280 m<sup>3</sup>

25 - 107

### AMESA & DMS SAMPLE MULTIPLE ANALYSES

- From a 280 m<sup>3</sup> XAD Sample Extract:
  - Dioxins/Furans
  - Polynuclear Aromatic Hydrocarbons (PAHs)
  - Polychlorinated Biphenyls (PCBs)
  - CAA Semivolatile HAPs
  - Other Organic Target Compounds

25 - 108

### **AMESA SUMMARY**

- Conducts Isokinetic Sampling
- Sampling Probe/Nozzle
  - Titanium materials
  - Single average-point sampling
  - Usually not heated (can be modified)
  - Probe sample fraction usually not recovered (20% factor added to XAD catch)
- No Fiber Glass Filter (can be added)
- Collects Stack Gas Moisture

25 - 109

### **DMS SUMMARY**

- Conducts Isokinetic Sampling
- Null Sampling Probe/Nozzle (2)
  - Titanium materials
  - Two average-point sampling locations
  - Usually not heated (can be modified)
  - Probe sample fraction usually not recovered (20% factor added to XAD catch)

25 - 110

### **DMS SUMMARY**

- Stack Gas Dilution
- Fiber Glass Filter & PUFs
- No Stack Gas Moisture

25 - 111

### **AMESA & DMS SUMMARY**

- Can Measure D/F 52 Weeks/Year
- Estimated Cost (less analysis)
  - Purchase price - ~\$100,000 US
  - Lease Price (12 months) - \$4000/month
- AMESA – 55 Units in Operation
- DMS – 5 Units in Operation

25 - 112

### **AMESA & DMS CONCLUSIONS**

- Allows for Long-Term D/F Measurements – up to 4 weeks
- Annual D/F Method 23 Estimates for Plants Have Increased 15 to 25% When Measured by AMESA & DMS
  - Increases attributed to: 1) daily plant operation variations and 2) that very few of the D/F are “non detects” as seen in Method 23 analyses.

25 - 113

### **AMESA & DMS AS ALTER. TEST METHODS**


- Must Meet M 301 Acceptance Criteria as Compared With EPA Method 23
- Procedures Could be Approved
  - As alternative compliance test method
    - At specific industry category
    - Facility by Facility approval (each emission point must be evaluated)

25 - 114

### AmbStack Dioxin Sampling

- Two part sample train/1 person
  - Unheated probe and pre-cleaned PUF/XAD-2 module
  - Metering console contain flow control, pump and volume meter
- Analysis by bioassay based on the Chemically Activated Luciferase Expression (CALUX) Assay

25 - 115



116

### AmbStack Dioxin Sampling

- System operated non-isokinetically and at a constant rate (~ 2L/min) at a single point (average velocity) in the stack. Sampling typically 3 hours
- Assay uses genetically engineered cells with the Luciferase gene under control of a dioxin-responsive promoter

25 - 117



### AmbStack Dioxin Sampling

- If dioxin/furans are present, the dioxin-responsive promoter emits light and recorded
- Dioxin TEQ is proportional to the amount of light emitted in response to a sample

25 - 118



APTI #450/468 Compliance Test and Source Test Observation  
Lesson 25: FRM 23 & SW-846 Method 0023A Dioxins and Furans





U.S. EPA APTI  
Compliance Test and Source  
Test Observation

FRM 30 Mercury



26-1

Acceptable Reference Methods

- Originally, the Ontario Hydro method (ASTM D6784-02) and EPA Method 29 were the only acceptable reference methods.
- August 22, 2007, EPA released a direct and final rule that allowed two other reference methods.
  - EPA Method 30A – Instrumental reference method (IRM)
  - EPA Method 30B – Sorbent trap method
- Both methods were promulgated November 2007.

26-2

Federal Register / Vol. 81, No. 168 / Tuesday,  
August 30, 2016 / Rules and Regulations

- **Z. Method 30A of Appendix A–8 of Part 60**  
In Method 30A, the heading of section 8.1 is changed from “Sample Point Selection” to “Selection of Sampling Sites and Sampling Points.”
- **AA. Method 30B of Appendix A–8 of Part 60**  
In Method 30B, the heading of section 8.1 is changed from “Sample Point Selection” to “Selection of Sampling Sites and Sampling Points.” In section 8.3.3.8, the reference to ASTM WK223 is changed to ASTM D6911–15, and the last two sentences in this section (inadvertently omitted in the proposed rule) are re-inserted.

26-3

EPA Method 30A

- **Determination of Total Vapor-Phase Mercury Emissions from stationary Sources Using an instrumental analyzer**
  - Sample point selection
  - Analytical procedures
  - Sampling procedures
  - QA/QC

26-4

EPA Method 30A - Sample point selection

- Use twelve sampling points located according Table 1-1 or Table 1-2 of Method 1 in appendix A-1
- Alternatively, conduct a stratification test as described in section 8.1.3 to determine the number and location of the sampling points

26-5

EPA Method 30A - Analytical procedures

- Real-time
- Performance-based
- Consistent w/ SO<sub>2</sub> & NO<sub>x</sub> instrumental methods
- Key elements
  - Calibration error/linearity
  - System integrity/conversion efficiency
  - System response time
  - Interference test
  - Dynamic spiking (gaseous method of standard additions)

26-6



EPA Method 30A - Hg Gas Standards



26-7

EPA Method 30A - Hg Gas Standard Traceability

Method Requires "NIST Traceable" Hg gas standards


- NIST Traceability is defined by EPA Documented in EPA-600/R-97/121 "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards"
- Traceable to a measured concentration, not theoretical

26-8

EPA Method 30A - Sampling procedures

- Two-point system integrity test
- Drift Check
- System equilibrates Two times system response prior to testing
- Traverse points
- Moisture correction

26-9



26-10

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Calibration Gases	Traceability protocol	Validation of concentration required	
High-level Hg <sup>0</sup> gas	Equal to the calibration span	Each calibration error test.	
Mid-level Hg <sup>0</sup> gas	40 to 60% of calibration span	Each calibration error test.	
Low-level Hg <sup>0</sup> gas	10 to 30% of calibration span	Each calibration error test.	

26-11

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
High-level HgCl <sub>2</sub> gas	Equal to the calibration span	Each system integrity check (if it better represents C <sub>native</sub> than the mid level gas).	
Mid-level HgCl <sub>2</sub>	40 to 60% of calibration span	Each system gas integrity check (if it better represents C <sub>native</sub> than the high level gas).	

26-12

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Zero gas	Each system integrity check.		
Dynamic spike gas ( $C_{\text{native}} \geq 1 \mu\text{g}/\text{m}^3$ )	A high-concentration $\text{HgCl}_2$ gas, used to produce a spiked sample concentration that is 150 to 200% of the native concentration	Pre-test; dynamic spiking not required until 1/1/09.	

26-13

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Dynamic spike gas ( $C_{\text{native}} < 1 \mu\text{g}/\text{m}^3$ )	A high-concentration $\text{HgCl}_2$ gas, used to produce a spiked sample concentration that is 1 to 2 $\mu\text{g}/\text{m}^3$ above the native concentration	Pre-test; dynamic spiking not required until 1/1/09.	
Sample Extraction	Probe material	Inert to sample constituents (e.g., PFA Teflon, or quartz if stack >500 °F)	Each run.

26-14

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Sample Extraction	Probe, filter and sample line temperature	For dry-basis analyzers, keep sample above the dew point, by heating prior to moisture removal For wet-basis analyzers, keep sample above dew point at all times, by heating or dilution	Each run.
Sample Extraction	Calibration valve material	Inert to sample constituents (e.g., PFA Teflon or PFA Teflon coated)	Each test.
Sample Extraction	Manifold material	Inert to sample constituents	Each test.

26-15

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Particulate Removal	Filter inertness	Pass calibration error check	Each calibration error check.
System Calibration Performance	System calibration error (CE) test	CE $\leq 5.0\%$ of the calibration span for the low-, mid- or high-level $\text{Hg}^0$ calibration gas Alternative specification: $\leq 0.5 \mu\text{g}/\text{m}^3$ absolute difference between system response and reference value	Before initial run and after a failed system integrity check or drift test.

26-16

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
System Calibration Performance	System integrity check	Error $\leq 5.0\%$ of the calibration span for the zero and mid- or high-level $\text{HgCl}_2$ calibration gas Alternative specification: $\leq 0.5 \mu\text{g}/\text{m}^3$ absolute difference between system response and reference value	Before initial run, after each run, at the beginning of subsequent test days, and after a failed system integrity check or drift test.

26-17

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
System Performance	System response time	Used to determine minimum sampling time per point	During initial 3-point system calibration error test.
System Performance	Drift	$\leq 3.0\%$ of calibration span for the zero and mid- or high-level gas Alternative specification: $\leq 0.3 \mu\text{g}/\text{m}^3$ absolute difference between pre- and post-run system calibration error percentages.	At least once per test day.

26-18

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
System Performance	Minimum sampling time	The greater of two times the system response time or 10 minutes. Concentrating systems must also include at least 4 cycles	Each sampling point.

26-19

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
System Performance	Percentage spike recovery and relative standard deviation	Percentage spike recovery, at the target level: $100 \pm 10\%$ Relative standard deviation: $\leq 5$ percent Alternative specification: absolute difference between calculated and measured spike values $\leq 0.5 \mu\text{g}/\text{m}^3$	Before initial run; dynamic spiking not required until 1/1/09.

26-20

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Sample Point Selection	Number and Location of Sample Points	For emission testing applications, use 12 points, located according to Method 1 in appendix A-1 to this part, unless the results of a stratification test allow fewer points to be used	Prior to first run.

26-21

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Sample Point Selection	Stratification Test (See section 8.1.3).	If the Hg concentration <sup>2</sup> at each traverse point during the stratification test is: <ul style="list-style-type: none"> <li>• Within <math>\pm 5\%</math> of mean, use 1-point sampling (at the point closest to the mean); or</li> <li>• Not within <math>\pm 5\%</math> of mean, but is within <math>\pm 10\%</math> of mean, use 3-point sampling. Locate points according to section 8.1.3.2.2 of this method. Alternatively, if the Hg concentration at each point is:</li> </ul>	Prior to first run. Prior to 1/1/09, you may (1) forgo stratification testing and use 3 sampling points (as per section 8.1.3.2.2) or (2) perform a SO <sub>2</sub> stratification test (see sections 6.5.6.1 and 6.5.6.3 of appendix A to part 75),

26-22

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Sample Point Selection	Stratification Test (See section 8.1.3).	<ul style="list-style-type: none"> <li>• Within <math>\pm 0.2 \mu\text{g}/\text{m}^3</math> of mean, use 1-point sampling (at the point closest to the mean); or</li> <li>• Not within <math>\pm 0.2 \mu\text{g}/\text{m}^3</math> of mean, but is within <math>\pm 0.5 \mu\text{g}/\text{m}^3</math> of mean, use 3-point sampling. Locate points according to section 8.1.3.2.2 of this method.</li> </ul>	in lieu of a Hg stratification test. If the test location is unstratified or minimally stratified for SO <sub>2</sub> , it can be considered unstratified or minimally stratified for Hg also.

26-23

EPA Method 30A – QA/QC

Process or element	QA/QC specification	Acceptance criteria	Checking frequency
Data Recording	Frequency	Once per cycle	During run.
Data Parameters	Sample concentration and calibration span	All analyzer readings during dynamic spiking tests within 120% of calibration span	Each spike injection.
Data Parameters	Sample concentration and calibration span	Average Hg concentration for the run	Each run.

26-24

EPA Method 30B

**Determination of Total Vapor-Phase Mercury Emissions from Coal-Fired Combustion Sources Using Carbon Sorbent Traps**

- Sample point selection
- Analytical procedures
- Measurement system performance tests
- Sampling procedures
- Sampling handling
- QA/QC


26-25

Sorbent Traps as a Reference Method and for Appendix K

- Both are sorbent trap methods
- Both are procedural not proscribed methods
- **But:**
- A reference method is designed to certify or prove another method is working properly. In this case, a continuous Hg monitor (CMM).
- Appendix K is a CMM.

26-26

**Differences Between Method 30B and Appendix K Carbon Traps**



26-27

Sample Point Selection

- Do a Long-line traverse for the RATA or,
- Conduct a 12-point mercury stratification test prior to the RATA.

26-28

Analytical Procedures

- Modified EPA Method 1631 Digestion Procedures followed by analysis using cold-vapor atomic fluorescence (CVAf)
- Thermal desorption – Ohio Lumex RA-915+ Hg analyzer with RP-324 attachment
- Thermal combustion – Leeman, Leco, Milestone

26-29

Measurement System Performance Tests

- Determination of minimum mass of Hg to be collected
- Analytical matrix test (wet analysis method)
- Hg<sup>0</sup> and HgCl<sub>2</sub> analytical bias test (instrumental analysis method)
- Field recovery test

26-30

**Determination of Minimum Mass of Hg to Be Collected**

- Perform a multipoint calibration of the analyzer at a minimum of three points (the linear coefficient  $r^2$  must be  $\geq 0.99$ ).
- All field samples analyzed must fall within the range of the calibration curve.
- Lowest point in your calibration curve must be  $\geq 10$ , the minimum detection limit of your instrument (MDL).
- Select a calibration check standard that is  $>2$  times the lowest concentration in your calibration curve.
- Minimum sample time is 30 minutes.

26-31

**Hg<sup>0</sup> and HgCl<sub>2</sub> Analytical Bias Test**

- This test defines the bounds within which the field samples must be to be valid.
- Only done once for each sorbent type or instrument.
- Analyze the front section of three sorbent traps spiked with Hg<sup>0</sup> at the lower and upper concentrations (must be spiked with vapor-phase Hg<sup>0</sup>).
- Analyze the front section of three sorbent traps spiked with HgCl<sub>2</sub> at the lower and upper concentrations (liquid standards may be used).
- To be valid, the average recovery of each set of three samples must be between 90% and 110% of the known value.

26-32

**Field Recovery Test**

- Done once for each unit tested.
- Requires three sets of dual-train tests using one Hg<sup>0</sup>-spiked trap (first section) paired with a nonspiked trap.
- Based on the Hg mass to be collected on the first section of the trap, the spike must be within 50% to 150% of this mass.
- Sample the stack gas and analyze traps using the same sampling procedures and analytical methods as for the standard field samples

26-33

**Field Recovery Test**

- The average of the percentage of the spike recovered must be between 85% and 115% to begin the RATA.
- It is acceptable to perform the field recovery test concurrent with the actual test run using a quad probe.
- It is also acceptable to use field recovery test data as part of the RATA if the difference between the spiked and unspiked samples after subtracting out the spike has a RD of  $\leq 10\%$ .

26-34

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Gas flow meter calibration (At 3 settings or points)	Calibration factor (Y) at each flow rate must be within $\pm 2\%$ of the average value (Y)	Prior to initial use and when post-test check is not within $\pm 5\%$ of Y	Recalibrate at 3 points until the acceptance criteria are met.
Gas flow meter post-test calibration check (Single-point)	Calibration factor (Y) must be within $\pm 5\%$ of the Y value from the most recent 3-point calibration	After each field test. For mass flow meters, must be done on-site, using stack gas	Recalibrate gas flow meter at 3 points to determine a new value of Y. For mass flow meters, must be done on-site, using stack gas. Apply the new Y value to the field test data.

26-35

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Temperature sensor calibration	Absolute temperature measured by sensor within $\pm 1.5\%$ of a reference sensor	Prior to initial use and before each test thereafter	Recalibrate; sensor may not be used until specification is met.
Barometer calibration	Absolute pressure measured by instrument within $\pm 10$ mm Hg of reading with a mercury barometer or NIST traceable barometer	Prior to initial use and before each test thereafter	Recalibrate; instrument may not be used until specification is met.

26-36

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Pre-test leak check	≤4% of target sampling rate	Prior to sampling	Sampling shall not commence until the leak check is passed.
Post-test leak check	≤4% of average sampling rate	After sampling	Sample invalidated.*
Analytical matrix interference test (wet chemical analysis, only)	Establish minimum dilution (if any) needed to eliminate sorbent matrix interferences	Prior to analyzing any field samples; repeat for each type of sorbent used	Field sample results not validated.

26-37

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Analytical bias test	Average recovery between 90% and 110% for Hg <sup>0</sup> and HgCl <sub>2</sub> at each of the 2 spike concentration levels	Prior to analyzing field samples and prior to use of new sorbent media	Field samples shall not be analyzed until the percent recovery criteria has been met.
Multipoint analyzer calibration	Each analyzer reading within ±10% of true value and r <sup>2</sup> ≥0.99	On the day of analysis, before analyzing any samples	Recalibrate until successful.

26-38

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Analysis of independent calibration standard	Within ±10% of true value	Following daily calibration, prior to analyzing field samples	Recalibrate and repeat independent standard analysis until successful.
Analysis of continuing calibration verification standard (CCVS)	Within ±10% of true value	Following daily calibration, after analyzing ≤10 field samples, and at end of each set of analyses	Recalibrate and repeat independent standard analysis, reanalyze samples until successful, if possible; for destructive techniques, samples invalidated.

26-39

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Test run total sample volume	Within ±20% of total volume	Each individual sample	Sample invalidated.
Sorbent trap section 2 breakthrough	For compliance/emissions testing: ≤10% of section 1 Hg mass for Hg concentrations >1 µg/dscm;	Every sample	Sample invalidated.*
	≤20% of section 1 Hg mass for Hg concentrations ≤1 µg/dscm		

26-40

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
	≤50% of section 1 Hg mass if the stack Hg concentration is ≤30% of the Hg concentration that is equivalent to the applicable emission limit		
Sorbent trap section 2 breakthrough	For relative accuracy testing: ≤10% of section 1 Hg mass for Hg concentrations >1 µg/dscm;		

26-41

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
	≤50% of section 1 Hg mass if the stack Hg concentration is ≤30% of the Hg concentration that is equivalent to the applicable emission limit		
Sorbent trap section 2 breakthrough	For relative accuracy testing: ≤10% of section 1 Hg mass for Hg concentrations >1 µg/dscm;		

26-42



QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
	≤20% of section 1 Hg mass for Hg concentrations ≤1 µg/dscm and >0.5 µg/dscm;		
	≤50% of section 1 Hg mass for Hg concentrations ≤0.5 µg/dscm >0.1 µg/dscm;		
	no criterion for Hg concentrations ≤0.1 µg/dscm (must meet all other QA/QC specifications)		

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Paired sorbent trap agreement	≤10% Relative Deviation (RD) mass for Hg concentrations >1 µg/dscm;	Every run	Run invalidated.*
	≤20% RD or ≤0.2 µg/dscm absolute difference for Hg concentrations ≤1 µg/dscm		

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Sample analysis	Within valid calibration range (within calibration curve)	All Section 1 samples where stack Hg concentration is ≥0.02 µg/dscm except in case where stack Hg concentration is ≤30% of the applicable emission limit	Reanalyze at more concentrated level if possible, samples invalidated if not within calibrated range.

QA/QC test or specification	Acceptance criteria	Frequency	Consequences if not met
Sample analysis	Within bounds of Hg <sup>0</sup> and HgCl <sub>2</sub> Analytical Bias Test	All Section 1 samples where stack Hg concentration is ≥0.5 µg/dscm	Expand bounds of Hg <sup>0</sup> and HgCl <sub>2</sub> Analytical Bias Test; if not successful, samples invalidated.
Field recovery test	Average recovery between 85% and 115% for Hg <sup>0</sup>	Once per field test	Field sample runs not validated without successful field recovery test.